



Designation: ~~C957-06~~ Designation: C957/C957M - 10

# Standard Specification for High-Solids Content, Cold Liquid-Applied Elastomeric Waterproofing Membrane With Integral Wearing Surface<sup>1</sup>

This standard is issued under the fixed designation C957/C957M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reappraisal. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reappraisal.

## 1. Scope

1.1 This specification describes the required properties and test methods for a cold liquid-applied elastomeric membrane for waterproofing building decks not subject to hydrostatic pressure. The specification applies only to a membrane system that has an integral wearing surface. This specification does not include specific requirements for skid resistance or fire retardance, although both may be important in specific uses.

1.2 The type of membrane system described in this specification is used for pedestrian and vehicular traffic and in high-abrasion applications. The membrane may be single- or multi-component, and may consist of one or more coats (for example base coat, top coat, etc.). The coat(s) may be built to the desired thickness in one or more applications. One coat (base coat) provides the primary waterproofing function and normally comprises the major amount of organic material in the membrane. The function of the top coat(s) is to resist wear and weather. Aggregate may be used as a component of the membrane system, as all or part of a course, to increase wear and skid resistance.

1.3 The committee with jurisdiction over this standard is not aware of any comparable standards published by other organizations.

~~1.4 Test methods in this specification require a minimum 0.5-mm (0.020-in.) base coat dry film thickness. Actual thickness required for a particular application and the use of aggregate in topcoats shall be established by the membrane manufacturer.~~

~~1.5 The values stated in SI units are to be regarded as the standard. The values given in parentheses are provided for information purposes only.~~

1.4 Test methods in this specification require a minimum 0.5-mm [0.020-in.] base coat dry film thickness. Actual thickness required for a particular application and the use of aggregate in topcoats shall be established by the membrane manufacturer.

1.5 The values stated in either SI units or inch-pound units are to be regarded separately as standard. The values stated in each system may not be exact equivalents; therefore, each system shall be used independently of the other. Combining values from the two systems may result in non-conformance with the standard.

1.6 The following safety hazards caveat pertains only to the test method portion, Section 5, of this specification: *This standard does not purport to address all of the safety problems, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

## 2. Referenced Documents

### 2.1 ASTM Standards:<sup>2</sup>

C501 Test Method for Relative Resistance to Wear of Unglazed Ceramic Tile by the Taber Abraser

~~C717 Terminology of Building Seals and Sealants~~ ~~C719 Test Method for Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement (Hoekman Cycle)~~

~~C794 Test Method for Adhesion-in-Peel of Elastomeric Joint Sealants~~ ~~C836 Specification for High-Solids Content, Cold Liquid-Applied Elastomeric Waterproofing Membrane for Use with Separate Wearing Course~~

C1250 Test Method for Nonvolatile Content of Cold Liquid-Applied Elastomeric Waterproofing Membranes

C1305 Test Method for Crack Bridging Ability of Liquid-Applied Waterproofing Membrane

C1442 Practice for Conducting Tests on Sealants Using Artificial Weathering Apparatus

<sup>1</sup> This specification is under the jurisdiction of ASTM Committee ~~C24~~ on Building Seals and Sealants and is the direct responsibility of Subcommittee ~~C24.80~~ on Building Deck Waterproofing Systems (Disbanded 6/06).

Current edition approved July 1, 2006. Published August 2006. Originally approved in 1981. Last previous edition approved in 2005 as C957-05a. DOI: ~~10.1520/C0957-06.D08~~ on Roofing and Waterproofing and is the direct responsibility of Subcommittee ~~D08.22~~ on Waterproofing and Dampproofing Systems.

Current edition approved May 1, 2010. Published May 2010. Originally approved in 1981. Last previous edition approved in 2006 as C957-06. DOI: ~~10.1520/C0957\_C0957M-10~~.

<sup>2</sup> For referenced ASTM standards, visit the ASTM website, [www.astm.org](http://www.astm.org), or contact ASTM Customer Service at [service@astm.org](mailto:service@astm.org). For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

- D412 Test Methods for Vulcanized Rubber and Thermoplastic Elastomers Tension
- D471 Test Method for Rubber Property Effect of Liquids
- D609 Practice for Preparation of Cold-Rolled Steel Panels for Testing Paint, Varnish, Conversion Coatings, and Related Coating Products
- D1133 Test Method for Kauri-Butanol Value of Hydrocarbon Solvents
- D2370 Test Method for Tensile Properties of Organic Coatings
- G113 Terminology Relating to Natural and Artificial Weathering Tests of Nonmetallic Materials

**iTeh Standards**  
**(<https://standards.itih.ai>)**  
**Document Preview**

[ASTM C957/C957M-10](#)

<https://standards.itih.ai/catalog/standards/sist/2ee3c5f0-84d3-48cc-a072-cb55d3eacac/astm-c957-c957m-10>