

SLOVENSKI STANDARD

SIST EN 50397-3:2022

01-oktober-2022

Nadomešča:
SIST EN 50397-3:2010

Oplaščeni vodniki za nadzemne vode in ustrezeni pribor za naznačene izmenične napetosti nad 1 kV, ki ne presegajo 36 kV - 3. del: Vodilo za uporabo

Covered conductors for overhead lines and the related accessories for rated voltages above 1 kV a.c. and not exceeding 36 kV a.c. - Part 3: Guide to use

Kunststoffumhüllte Leiter und zugehörige Armaturen für Freileitungen mit Nennspannungen über 1 kV und nicht mehr als 36 kV Wechselspannung - Teil 3: Leitfaden für die Verwendung

Conducteurs gainés pour lignes aériennes et accessoires associés pour des tensions assignées supérieures à 1 kV en courant alternatif et ne dépassant pas 36 kV en courant alternatif - Partie 3: Guide d'emploi

Ta slovenski standard je istoveten z: EN 50397-3:2022

ICS:

29.060.20	Kabli	Cables
29.240.20	Daljinovodi	Power transmission and distribution lines

SIST EN 50397-3:2022 **en**

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 50397-3

July 2022

ICS 29.240.20

Supersedes EN 50397-3:2010

English Version

**Covered conductors for overhead lines and the related
accessories for rated voltages above 1 kV a.c. and not
exceeding 36 kV a.c. - Part 3: Guide to use**

Conducteurs gainés pour lignes aériennes et accessoires
associés pour des tensions assignées supérieures à 1 kV
en courant alternatif et ne dépassant pas 36 kV en courant
alternatif - Partie 3: Guide d'emploi

Kunststoffumhüllte Leiter und zugehörige Armaturen für
Freileitungen mit Nennspannungen über 1 kV und nicht
mehr als 36 kV Wechselspannung - Teil 3: Leitfadens für die
Verwendung

This European Standard was approved by CENELEC on 2022-06-27. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN 50397-3:2022 (E)**Contents****Page**

European foreword	4
Introduction.....	5
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	6
4 Covered conductors	7
4.1 Recommendations for selection of covered conductors	7
4.2 Recommendation for storage and transport	8
4.3 Recommendation for installation of covered conductors	11
4.4 Other recommendations	14
5 Accessories.....	14
5.1 General.....	14
5.2 Joints	14
5.3 Insulators	15
5.4 Fittings	15
5.5 Earthing devices.....	17
5.6 Arc protection devices	18
5.7 Surge arresters	19
5.8 Bird protection.....	19
5.9 Corona protection.....	19
Bibliography.....	20

SIST EN 50397-3:2022

<https://standards.iteh.ai/catalog/standards/sist/48637a63-c51b-4518-89b4-25e1390ee29e/sist-en-50397-3-2022>

Figures

Figure 1 — View from the top.....	9
Figure 2 — Keep the drum standing upright, using wedges in the heels of the flanges.....	9
Figure 3 — Only drums with protection lagging may be piled flange on flange. Lower layer to be secured over full drum width	9
Figure 4 — Not recommended	10
Figure 5 — Drums may be lifted either by crane or fork-lift truck	10
Figure 6 — Rolling the drums.....	10
Figure 7 — Recommended direction	11
Figure 8 — Not recommended direction	11
Figure 9 — Unwind this way.....	12
Figure 10 — Never unwind this way	13
Figure 11 — Example of a joint.....	14
Figure 12 — Example of a tie.....	15
Figure 13 — Example of a bolted tension clamp.....	16
Figure 14 — Example of a helical fitting	16
Figure 15 — Example of a wedge type tension clamp	17
Figure 16 — Example of a tee off connection	17
Figure 17 — Example for an earthing device.....	17
Figure 18 — Arc phase to phase.....	18
Figure 19 — Arc phase to cross arm	18
Figure 20 — Example of two types of arc protection devices.....	18
Figure 21 — Example of arc protection device for angle constructions	19
Figure 22 — Example of arc protection device combined with surge arrester	19

EN 50397-3:2022 (E)**European foreword**

This document (EN 50397-3:2022) has been prepared by CLC/TC 20 "Electric cables".

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2023-06-27
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2025-06-27

This document supersedes EN 50397-3:2010, and all of its amendments and corrigenda (if any).

EN 50397-3:2022 has been updated editorially with respect to EN 50397-3:2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 50397-3:2022
<https://standards.iteh.ai/catalog/standards/sist/48637a63-c51b-4518-89b4-25e1390ee29e/sist-en-50397-3-2022>

Introduction

EN 50397 “*Covered conductors for overhead lines and the related accessories for rated voltages above 1 kV a.c. and not exceeding 36 kV a.c.*” consists of three parts. These are:

- Part 1: Covered conductors;
- Part 2: Accessories for covered conductors - Tests and acceptance criteria;
- Part 3: Guide to use.

This Part 3 “Guide to use” assumes that the user will benefit from a single document that gives guidance on all the equipment specified within the other two parts.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 50397-3:2022

<https://standards.iteh.ai/catalog/standards/sist/48637a63-c51b-4518-89b4-25e1390ee29e/sist-en-50397-3-2022>

EN 50397-3:2022 (E)

1 Scope

This part of EN 50397 provides general recommendations for the selection, storage, transportation and installation of the covered conductors and the related accessories specified in EN 50397-1 and EN 50397-2, unless otherwise specified. Safety regulations and environmental regulations as well as rules for installation and mechanical design are not considered in this Guide to use, as they are covered by relevant national regulations and laws. Relevant national regulations are not considered in this guide, but it is advised that they are always consulted as appropriate.

NOTE The term “national regulations” is used throughout this guide. It can include specific safety regulations, rules of installation and other relevant instructions which, depending upon the particular country or district, can exist in a legislative (mandatory) form, or as a non-mandatory code of practice. In addition, certain specific utilities can have their own safety practices.

It is assumed that the design of installations, the purchase and installation of covered conductors and of the related accessories specified in this document are entrusted to suitably skilled and competent people. In case of doubt as to the suitability of covered conductors and the related accessories for a particular use, further specific information is expected to be obtained from the manufacturer.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50397-1:2006, *Covered conductors for overhead lines and the related accessories for rated voltages above 1 kV a.c. and not exceeding 36 kV a.c. — Part 1: Covered conductors*

EN 50397-2, *Covered conductors for overhead lines and the related accessories for rated voltages above 1 kV AC and not exceeding 36 kV AC — Part 2: Accessories for covered conductors — Tests and acceptance criteria*

EN 50182:2001¹, *Conductors for overhead lines — Round wire concentric lay stranded conductors*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1

rated tensile strength

RTS

estimate of the conductor breaking load calculated using the specified tensile properties of the components wires

Note 1 to entry: See EN 50397-1:2006, 4.2.1.

¹ As impacted by EN 50182:2001/AC:2013, EN 50182:2001/corrigendum Apr. 2004, EN 50182:2001/corrigendum Jul. 2001 and EN 50182:2001/corrigendum Jun. 2005.

3.2**specified minimum failure load****SMFL**

minimum load, specified by the purchaser or declared by the supplier, at which mechanical failure will not take place

Note 1 to entry: From the probabilistic point of view, the specified minimum failure load corresponds to the value having the probability of e % in the distribution function of the strength of the fitting. The exclusion limit e % is usually taken within 2 % to 5 % with 10 % being the upper limit (see IEC 60826).

3.3**slippage factor****X-value**

ratio between the tensile force on the covering of the conductor when a certain slippage starts to occur and the RTS of the conductor

Note 1 to entry: See EN 50397-1:2006, Annex D.

Note 2 to entry: An X-value of e.g. 100 % means that at a force up to RTS no relative slippage between the covering and the conductor occurs.

4 Covered conductors**4.1 Recommendations for selection of covered conductors****4.1.1 General**

Covered conductors specified in EN 50397-1 are equipped with a polymeric covering as protection against accidental contact with grounded parts or other live covered conductors. Covered conductors are not touch proof, so they shall to be treated as non-protected plain conductors with regard to protection against electric shock.

The use of covered conductors is only permissible in air and mounted on suitable insulators, which are at least specified for the rated voltage of the overhead line.

4.1.2 Power frequency range

Covered conductors are intended to be used in the power frequency range of 49 Hz to 61 Hz.

4.1.3 Current rating

Reference shall be made either to EN 50397-1:2006, Annex A, to EN 50182 or to the manufacturer's specifications to obtain the current ratings of the selected conductor cross sections and the maximum permissible conductor temperature for the covering material as given in EN 50397-1:2006, 4.2.3.

If covered conductors in accordance with EN 50397-1 are exposed to strong solar radiation or high temperature ambient conditions, the current carrying capacity shall be reduced accordingly.

4.1.4 Operating conditions

In addition to the current ratings, due regard shall be given to:

- a) the capability of the covered conductor to withstand the worst anticipated fault conditions of the system;
- b) the earth loop impedance;
- c) the operating characteristics of the connected equipment;
- d) the voltage drop requirements for long distance conditions.

EN 50397-3:2022 (E)

In certain cases, longitudinal watertight conductor constructions can be necessary to avoid corrosive effects to the conductor and to obtain a sufficient life time of the overhead line system.

4.2 Recommendation for storage and transport**4.2.1 General**

Suitable protection, appropriate to the choice of covered conductors and the installation conditions, shall be provided against mechanical damage.

Covered conductors stored at temperatures which are below those recommended for installation shall not be subject to any mechanical stress including shocks, impact, bending and torsion. It is recommended not to store complete reels in conditions, where the maximum permissible conductor temperature as given in EN 50397-1:2006, 4.2.3 is exceeded.

4.2.2 Sealing and drumming**4.2.2.1 Clearance and lagging**

In general, it is recommended to use lagging or other equivalent protection to avoid damage to the covered conductor. If lagging is used the thickness shall be appropriate.

The distance between the outer layer of the covered conductor on the filled drum and the ground or lagging shall be sufficient to avoid damage to the covered conductor. It is recommended to use a clearance of at least 50 mm.

4.2.2.2 Barrel diameter

The barrel diameter of delivery drums shall not be smaller than $30 \times D$, where D is the outer diameter of the covered conductor.

4.2.2.3 Sealing

The ends of covered conductors shall be sealed to prevent ingress of moisture during transport and storage. The possibility of damage to moisture seals during transport and storage shall be borne in mind. Where such damage may have occurred, the conductor end shall be inspected and the seal remade.

4.2.2.4 Handling

When handling drums, suitable precautions shall be taken to avoid damage to the covered conductor and injury to people. Due regard shall be paid to the mass of the drum, the method and direction of rolling and the method of lifting. Drums shall be stored only on even and solid ground.

4.2.2.5 Drum condition

Drums shall be regularly inspected during storage to assess their physical condition. Care shall be taken to avoid damage to the covered conductor caused by nails and staples used either in drum manufacturing or when applying laggings. Laggings, where applied, shall not be removed from drums until the covered conductor is about to be installed.

Care shall be taken to avoid deterioration of the drums. Drums shall be stored so that the drum flanges do not contact products on other drums. See Figure 1.




Figure 1 — View from the top

Drums shall be stored with the drum axis horizontal. See Figures 2, 3 and 4.

4.2.3 Transport

4.2.3.1 Carriers

Only suitable carriers shall be used.

4.2.3.2 Drum axis position

Drums shall be transported with the drum axis horizontal and any drum movement shall be avoided.




Figure 2 — Keep the drum standing upright, using wedges in the heels of the flanges




Figure 3 — Only drums with protection lagging may be piled flange on flange. Lower layer to be secured over full drum width