

EUROPEAN STANDARD

EN 17887-2

NORME EUROPÉENNE

EUROPÄISCHE NORM

May 2024

ICS 91.120.10

English Version

Thermal performance of buildings - In situ testing of completed buildings - Part 2: Steady-state data analysis for aggregate heat loss test

Performance thermique des bâtiments - Essais in situ des bâtiments achevés - Partie 2 : Analyse des données en régime stationnaire pour l'essai de déperdition thermique globale

Wärmetechnisches Verhalten von Gebäuden - In-situ-Prüfung an fertiggestellten Gebäuden - Teil 2: Auswertung stationärer Daten für die Prüfung des Gesamtwärmeverlustes

This European Standard was approved by CEN on 27 February 2024.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.

[SIST EN 17887-2:2024](https://standards.iteh.ai/catalog/standards/sist/7be50559-aa2f-450a-8286-8d181472a8b2/sist-en-17887-2-2024)

<https://standards.iteh.ai/catalog/standards/sist/7be50559-aa2f-450a-8286-8d181472a8b2/sist-en-17887-2-2024>



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

	Page
European foreword	3
Introduction.....	4
1 Scope	5
2 Normative references.....	5
3 Terms, definitions and symbols	5
3.1 Terms and definitions.....	5
3.2 Symbols	7
4 Principle.....	9
5 Uncertainty	9
6 Input data	10
6.1 Raw data.....	10
6.2 Irregularities and gaps in the data	10
6.3 Cleaning data.....	11
6.4 Filtering (averaging)	11
6.5 Checking averaged data.....	11
7 Data analysis.....	12
7.1 General	12
7.2 Simple linear regression using the Siviour method	13
7.3 Multiple linear regression (MLR) techniques	13
7.3.1 General	13
7.4 Validation: residuals analysis	14
7.5 Normality of residuals	14
7.6 Autocorrelation test.....	16
8 Test report	17
8.1 General	17
8.2 Data on the measured building/ structure.....	17
8.3 Description of the experimental set-up.....	17
8.4 Conditions during measurement.....	17
8.5 Data pre-processing.....	18
8.6 Aggregate heat transfer coefficient and associated uncertainties estimation.....	18
8.7 Supplementary and supporting measurements.....	19
Annex A (normative) Limitations and sources of errors.....	20
Annex B (normative) Process for estimating experimental uncertainty	24
Annex C (normative) Data analysis methods.....	30
Annex D (informative) Example of completed building heat loss test data analysis	39
Annex E (informative) Practical recommendations.....	50
Bibliography	52

European foreword

This document (EN 17887-2:2024) has been prepared by Technical Committee CEN/TC 89 “Thermal performance of buildings and building components”, the secretariat of which is held by SIS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2024, and conflicting national standards shall be withdrawn at the latest by November 2024.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

[SIST EN 17887-2:2024](https://standards.itih.ai/catalog/standards/sist/7be50559-aa2f-450a-8286-8d181472a8b2/sist-en-17887-2-2024)

<https://standards.itih.ai/catalog/standards/sist/7be50559-aa2f-450a-8286-8d181472a8b2/sist-en-17887-2-2024>

EN 17887-2:2024 (E)

Introduction

EN 17887-1 describes a test methodology that enables the actual *in situ* completed building aggregate heat loss (building heat transfer coefficient) to be quantified. This test method is termed the aggregate heat loss test method. The building heat transfer coefficient is defined in EN ISO 13789 as the sum of the transmission and ventilation heat transfer coefficients. The transmission heat transfer coefficient is defined in EN ISO 13789 as the heat flow rate due to thermal transmission through the fabric of a building, divided by the difference between the environment temperatures on either side of the construction. The ventilation heat transfer coefficient is defined in EN ISO 13789 as the heat flow rate due to air entering a conditioned space either by infiltration or ventilation, divided by the temperature difference between the internal air and the supply air temperature. In this method, only the heat flow rate via infiltration is considered.

This document principally covers numerical methods based on steady-state linear regression techniques. The results obtained using these methods are only valid under the assumption that, in first approximation, the data can be described by these mathematical and physical laws. Statistical tests to check the validity of these assumptions are therefore given. It also results in the determination of an aggregate building heat transfer coefficient for the tested building, along with the uncertainty associated with this coefficient. Both the aggregate building heat transfer coefficient and its uncertainty can be calculated as an output of this document. The reporting format relating to the test data and the resulting analysis is also described.

This document is highly linked with EN 17887-1 to which it applies exclusively. It is also complimentary to EN 17888-1 which deals exclusively with opaque building structures especially built for the purpose of *in situ* testing.

This document describes the input data required to undertake the analysis, various statistical methods that can be used to analyse the data, the uncertainty associated with the measurements, and the reporting format.

The data analysis methods described are only applicable to data sets that have been recorded in an unoccupied building. Although the analysis method does take account of solar radiation gains, the method is also not suitable for predicting solar gains in order to correct space heating demand.

Detailed requirements concerning the test procedure and the data recording are specified in EN 17887-1.

[SIST EN 17887-2:2024](https://standards.iteh.ai/catalog/standards/sist/7be50559-aa2f-450a-8286-8d181472a8b2/sist-en-17887-2-2024)

<https://standards.iteh.ai/catalog/standards/sist/7be50559-aa2f-450a-8286-8d181472a8b2/sist-en-17887-2-2024>

1 Scope

This document specifies the steady-state data analysis methods to evaluate the data from 'the aggregate heat loss test'. These analysis methods enable the actual *in situ* aggregate heat loss (building heat transfer coefficient) to be estimated.

NOTE The aggregate heat loss method is specified in EN 17887-1:2024.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5479, *Statistical interpretation of data — Tests for departure from the normal distribution*

EN 17887-1:2024, *Thermal performance of buildings — In situ testing of completed buildings — Part 1: Data collection for aggregate heat loss test*

3 Terms, definitions and symbols

For the purposes of this document, the following terms, definitions and symbols apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1 Terms and definitions (<https://standards.iteh.ai>)

3.1.1

aggregate heat transfer coefficient

sum of the transmission and infiltration component of the ventilation heat transfer coefficient based upon measurement according to this test standard [SIST EN 17887-2:2024](https://standards.iteh.ai/catalog/standards/sist/7be50559-aa2f-450a-8286-8d181472a8b2/sist-en-17887-2-2024)

<https://standards.iteh.ai/catalog/standards/sist/7be50559-aa2f-450a-8286-8d181472a8b2/sist-en-17887-2-2024>

3.1.2

external (internal) air temperature

temperature of the external (internal) air measured by external (internal) air temperature sensor

3.1.3

heat transfer coefficient

heat flow rate divided by temperature difference between two environments; specifically used for heat transfer coefficient by transmission or ventilation

[SOURCE: EN ISO 13789:2017, 3.5]

3.1.4

internal building temperature

mean air temperature of all of the measured internal room temperatures

3.1.5

internal room temperature

air temperature measured at the geometric centre of the room

EN 17887-2:2024 (E)**3.1.6****solar heat gain**

heat provided by solar radiation entering, directly or indirectly (after absorption in building elements), into the building through windows, opaque walls and roofs, or passive solar devices such as sunspaces, transparent insulation and solar walls

Note 1 to entry: Active solar devices such as solar collectors are considered part of the technical building system.

[SOURCE: ISO 52000 1:2017, 3.6.10]

3.1.7**temperature difference**

difference between the internal completed building temperature and external air temperature

3.1.8**transmission heat transfer coefficient**

heat flow rate due to thermal transmission through the fabric of a building, divided by the difference between the environment temperatures on either side of the construction

Note 1 to entry: By convention, if the heat is transferred between a conditioned space and the external environment, the sign is positive if the heat flow is from the space to outside (heat loss).

[SOURCE: EN ISO 13789:2017, 3.6]

3.1.9**ventilation heat transfer coefficient**

heat flow rate due to air entering a conditioned space by infiltration or ventilation, divided by the temperature difference between the internal air and the supply air temperature

Note 1 to entry: The supply temperature for infiltration is equal to the external temperature.

Note 2 to entry: In this analysis, the intended ventilation component of the ventilation heat transfer coefficient is typically omitted and only the infiltration component is included in the heat transfer coefficient, as intended ventilation routes are sealed during the test.

<https://standards.iteh.ai/catalog/standards/sist/7be50559-aa2f-450a-8286-8d181472a8b2/sist-en-17887-2-2024>

[SOURCE: EN ISO 13789:2017, 3.7, modified – Note 2 to entry has been added]

3.1.10**Global solar irradiance**

measured or calculated solar irradiance related to the south vertical wall or façade that is expected to receive the highest proportion of solar gains

Note 1 to entry: Longwave and shortwave radiation exchanges to the sky are not included

3.2 Symbols

Table 1 summaries the symbols and units referred to within this standard.

Table 1 — Symbols and units

Symbol	Description	Unit
Inputs for the regression analyses		
P_h	Electrical heating power	W
q_{sw}	Global solar irradiance (measured or calculated solar irradiance related to the south vertical wall or façade that is expected to receive the highest proportion of solar gains)	W/m ²
T_i	Internal air temperature	°C
T_e	External air temperature	°C
ΔT	Temperature difference between the internal completed building and external air	K
Parameters		
H_{agg}	Aggregate heat transfer coefficient	W/K
H	Heat transfer coefficient (global, including losses by transmission or ventilation or air infiltration)	W/K
H_{tr}	Transmission heat transfer coefficient	W/K
H_v	Ventilation heat transfer coefficient	W/K
H_i	Internal gain coefficient	W/K
H_e	External gain coefficient	W/K
B_o	Bias term	W/K
A_{sw}	Equivalent solar aperture	m ²
Θ	Vector of the parameters of the model	-
X	Explicative matrix of the model	-
Y	Vector of the explicated values of the model	-
Intermediary quantities		
B'_0	Intercept for the inverted linear regression	W/m ²
B'_1	Slope for the inverted linear regression	m ²
β^*_1	Dimensionless slope	-
A, H, d, λ_1, λ_2	Internal parameter	-
SF	Scale factor	-
λ	Lagrange weight coefficient	-
Common statistical notation		
r^2	Pearson correlation coefficient	-
r	Coefficient of determination	-

EN 17887-2:2024 (E)

Symbol	Description	Unit
ε	Residuals of the model	W or W/K
$t_{1-\frac{\alpha}{2}}^{n-1}$	Student coefficient for a bilateral Student law with (n-2) freedom degrees	-
$F_{(\alpha;v_1;v_2)}$	Fisher coefficient for $v_1 = 1$ and $\alpha = 5\%$, with $v_2 = (n-2)$ freedom degrees	-
n	Number of points used for the regression	-
n_{sensors}	Number of sensors deployed	
$n_{\text{party wall}}$	Number of party walls	
Var(θ)	Variance-covariance matrix for the vector of parameters of the model	-
ACF	Autocorrelation function	-
Other index and notation		
B	Bolted: table, vector or matrix	-
B^T	Transposed B matrix	-
B^{-1}	Inverted B matrix	-
x^*	Dimensionless	-
\hat{X}	Best estimate of the random variable X	-
\bar{X}	Average of the random variable X	-
Var(X)	Standard variance of the random variable X	-
Cov(X,Y)	Covariance between random variables X and Y	-
$s(x)$	Experimental standard deviation of the random variable X	-
$u(x)$	Standard uncertainty of the X quantity	-
$U(x)$	Enlarged uncertainty of the X quantity (with a 95 % bilateral confident interval)	-
k	Coverage factor used for expanded uncertainty (k = 2 for 95 % confidence interval)	

4 Principle

The completed building aggregate heat loss analysis shall be calculated by the following energy balance equation, assuming that the heating power input (P_h) is balanced by thermal losses and solar radiation transfer:

$$P_h = H_{agg} \cdot (T_i - T_e) - A_{sw} \cdot q_{sw}$$

where

- P_h is the electrical energy supplied by heaters and dissipated by fans [W];
- H_{agg} is the aggregate heat transfer coefficient, which combines the transmission heat transfer coefficient and the infiltration component of the ventilation heat transfer coefficient [W/K];
- $T_i - T_e = \Delta T$ is the temperature difference between inside and outside air [K];
- A_{sw} is the solar aperture [m²];
- q_{sw}^* is the measured or calculated solar irradiance [W/m²].

The aggregate heat transfer coefficient H_{agg} and the solar aperture A_{sw} express the relationship between the electrical heating power P_h , q_{sw} and ΔT variables in the regression analysis. The measured solar irradiance should be obtained in accordance with EN 17887-1:2024 6.2.1.

The solar aperture is a parameter that describes the solar gains incident the building as a whole, including diffuse gains, direct gains through glazing of all orientations and those from solar radiation incident upon opaque elements. It can be read as a global solar aperture, which includes the influence of non-perpendicular incidence of solar radiation, geometry and orientation of the building structure (including possible shading), solar absorption at opaque surfaces, solar energy transmittance factor and glazing surface of the building envelope. A_{sw} can be estimated experimentally from the completed building aggregate heat loss test data by regression analysis. The aggregate heat transfer coefficient H_{agg} can be identified as a mix between heat losses by transmission and, because ventilation openings are sealed during the test, the infiltration component of the ventilation through the envelope of the tested building, H_v .

$$H_{agg} = H_{tr} + H_v$$

The aggregate heat transfer coefficient can be deduced from quasi-steady-state measurements using the energy balance Formula. Assuming this energy balance model holds, several identification techniques, all based on linear regression methods, can be used to estimate the parameters of interest. Specifically, simple or multiple linear regression techniques can be applied on the completed building aggregated heat loss test measurement data (time averaged data points for P_h , q_{sw} and ΔT).

5 Uncertainty

The accuracy, reproducibility and interpretation of heat transfer coefficient estimates are limited by several factors related to both experimental and statistical uncertainties. The margin of uncertainty in the completed building aggregated heat loss test results is associated with a number of limitations and sources of error listed in Annex A. Attention shall be given to these limitations and sources of error listed in Annex A within both data collection and data analysis. Remaining uncertainty within estimates of the heat transfer coefficient shall then be estimated and stated alongside any results.

Two methods of estimating uncertainty are presented in this document:

- a) experimental uncertainty shall be estimated based upon the GUM method (JCGM 100:2008) and can incorporate both Type A (statistical analysis of observations) and Type B (non-statistical analysis, e.g. prior knowledge, previous experiments etc.), providing a stated uncertainty for an estimate of the heat transfer coefficient. An example of this analysis is given in Annex B;

EN 17887-2:2024 (E)

- b) statistical uncertainty shall be estimated based on the residuals between best estimates and measured data points. Statistical uncertainty is defined in Annex B and shall be used to determine the most appropriate regression method. Statistical uncertainty can be combined with experimental uncertainty to provide an increased error estimate (8.6).

The heat transfer coefficient, H [W/K], the solar aperture A_{SW} [m²], and associated uncertainties, shall be indicated in the report according to Clause 8.6.

6 Input data**6.1 Raw data**

The raw data set requires a minimum of 15 days of continuous recordings without gaps. Measurements in the raw data set shall be non-biased and meet these requirements:

- sensors shall be calibrated in order to correct constant error (non-biased sensors);
- measurements are representative of the physical parameter. For instance, internal temperature measurements shall be averaged from several non-biased temperature sensors in order to represent the spatial dispersion due to air stratification.

NOTE Requirements to reach these conditions are described in EN 17887-1.

The raw data set shall contain all the information necessary to undertake the data analysis.

6.2 Irregularities and gaps in the data

An analysis of the raw data are key to reduce difficulties in the subsequent modelling and provide meaningful results. This analysis shall aim at pointing out unusual phenomena, so-called irregularities, as well as outliers, measurement errors and missing data. These issues are often introduced either in the experiment set-up, by the measuring apparatus, or the data handling. A list of often-encountered phenomena found in the raw data set that can introduce problems, such as nonlinearity and outliers in the modelling and estimation step, is given in Annex A.

It is firstly required to plot the raw data set (for all input variables) as a function of the time step as recorded in EN 17887-1, in order to check for outliers, measurement errors, missing data and any potential irregularities.

NOTE Scatter plots of pairs of measurements like energy consumption vs temperature difference can also be insightful to show patterns and correlations between variables.

All these irregularities shall be removed from the raw data set. In the end, the quality of the remaining data set obtained (cleaned data set) shall be tested so that:

- in total, all irregularities shall not represent more than 10 % of the global amount of data;
- irregularities for each data input (i.e., T_i , T_e , q_{SW} and P_h) shall not represent more than 15 % each (i.e. no more than 15 % irregularities for T_i , data set, even if there are no other irregularities for T_e , q_{SW} and P_h);
- time without data (or with irregularities) shall not exceed 50 min (based upon a 24-h aggregation period) or 4 % for the P_h measurement, as this will be measured as accumulated flow using an energy meter;
- time without data (or with irregularities) shall not exceed 3 h for T_i , T_e , and q_{SW} measurements. If any of the above irregularities are exceeded, then the test is deemed to be invalid.

Any irregularity removed shall be recorded in the report, along with a brief justification of the reasons for their removal (see 8.5).

6.3 Cleaning data

Often, the data recorded from the beginning of the test will need to be removed, as the building will be in the process of being heated-up and the thermal mass charged. Once the thermal mass of the building has charged, the electrical energy input into the building should stabilize and only be influenced by external environmental conditions.

Any experimental overheating periods due to uncontrolled heat input from solar gains shall be excluded to maintain a constant mean internal temperature during the completed building heat loss test.

Irregularities on T_i , T_e , and q_{SW}^* shall be corrected by linear interpolations and recorded in the report, along with a brief justification of the reasons for correction and description of the interpolation method (see 8.5).

6.4 Filtering (averaging)

The effects of dynamic behaviour shall be minimized by low pass filtering the time series; by resampling the time series - i.e. aggregating the measured data points into longer time intervals (e.g. 24 h). The appropriate resampling interval depends on how fast the building fabric responds to external environmental conditions: for insulated buildings, one day (24-h) averages are usually appropriate, whereas for high performance (very well insulated or heavy weight) buildings a higher resampling interval may be needed.

The following procedure shall be undertaken to select an appropriate resampling interval:

- a) start with a short resampling interval (i.e. 24 h averages), check averaged data (see 6.5) and apply statistical analysis (see Clause 7);
- b) analyse residuals for autocorrelation and check that the cross-correlation to the inputs, especially to solar radiation, is not significant (see model validation step Clause 7);
- c) if residuals are not auto-correlated and there is no significant cross-correlation, stop the resampling and provide the results (see Clause 8);
- d) if residuals are auto-correlated or there is significant cross-correlation, increase the resampling time by 24 h until white noise residuals are obtained (see 7.6);
- e) the same averaging interval shall be used for all the signals.

It is important that an integer of 24 h is used to minimize bias from dynamic effects. Additionally, although a daily average using the time period 00:00 to 23:59 is common, a time period of 06:00 to 05:59 should be considered and is often more appropriate, as it allows more time for solar gains to remerge from the thermal mass of a tested building within the same aggregation period. Dawn-to-dawn or a similar interval can also be considered.

A simple check of raw 24-h total power input against average 24-h temperature difference across the valid test period can be useful as a check on the regression process itself, particularly when there is not a wide spread in data points.

If resampling is applied, the resampling interval shall be recorded in the report (see 8.5).

6.5 Checking averaged data

Linear regression shall be applied only for “regular” groups of points after averaging over integer 24-h periods (i.e. not applied to data sets at shorter time intervals – e.g. 1-h data), meaning that outliers can be removed. Checking outliers is simpler by using Siviour analysis (even if not used to determine the parameters of interest in Clause 7). It is then required to plot, for each averaged data, Y as a function of X where:

$$X = \begin{bmatrix} \frac{q_{sw,1}}{\Delta T_1} \\ \dots \\ \frac{q_{sw,n}}{\Delta T_n} \end{bmatrix} \quad \text{and} \quad Y = \begin{bmatrix} \frac{P_{h,1}}{\Delta T_1} \\ \dots \\ \frac{P_{h,n}}{\Delta T_n} \end{bmatrix}$$

All outliers identified shall lead to the removal of the corresponding averaged data from the data set used for statistical analysis. The outlier removed shall be recorded in the report, along with a brief justification of the reasons for their removal (see Clause 8).

7 Data analysis

7.1 General

The data analysis techniques within Annex C shall be used.

The parameters of interest shall be determined by applying simple or multiple linear regression techniques according to Table 2, based on the energy balance Formula, such as:

Table 2 — Regression techniques

Linear regression techniques	Description
Simple linear regression using the Siviour method (see 7.2)	<p>This simple method of linear regression is driven by normalized measurement uncertainties on variables Y and X (see 7.2).</p> <p>There are three cases (see Annex C) where residuals are used to apply the least square method between experimental points and estimations:</p> <ul style="list-style-type: none"> — the vertical distance; — the horizontal distance; — the orthogonal distance.
Multilinear regression (see 7.3)	<p>Multiple regression is a more complex broader class of regression that encompasses linear and nonlinear regressions with multiple explanatory variables.</p> <p>Two options are proposed (see 7.3.1, Annex C):</p> <ul style="list-style-type: none"> — biased energy balance model; — unbiased energy balance model. <p>Although a unbiased energy balance model (e.g. zero intercept) can represent a simplification of real world processes, it is typically adopted over biased (non-zero intercept) models.</p>

NOTE Methods to calculate and correct for solar gains based upon measured solar radiation and assumed building characteristics (e.g. glazed areas, g-values) are omitted from this document due to the significant uncertainty introduced by assumptions regarding building and glazing properties, alongside increased significance for accurate and complete solar radiation measurements.