



SLOVENSKI STANDARD

SIST EN IEC 61784-3-3:2021

01-oktober-2021

Nadomešča:
SIST EN 61784-3-3:2018

Industrijska komunikacijska omrežja - Profili - 3-3. del: Funkcijska varnost procesnih vodil - Dodatne specifikacije za CPF 3

Industrial communication networks - Profiles - Part 3-3: Functional safety fieldbuses - Additional specifications for CPF 3

Industrielle Kommunikationsnetze - Profile - Teil 3-3: Funktional sichere Übertragung bei Feldbussen - Zusätzliche Festlegungen für die Kommunikationsprofilfamilie 3
(standards.iteh.ai)

Réseaux de communication industriels - Profils - Partie 3-3: Bus de terrain de sécurité fonctionnelle - Spécifications supplémentaires pour CPF 3
<https://standards.iteh.ai/catalog/standards/sist/0aa/16c3-2acf-486c-95b7-99195f593bf2/sist-en-iec-61784-3-3-2021>

Ta slovenski standard je istoveten z: **EN IEC 61784-3-3:2021**

ICS:

25.040.40	Merjenje in krmiljenje industrijskih postopkov	Industrial process measurement and control
35.100.05	Večslojne uporabniške rešitve	Multilayer applications

SIST EN IEC 61784-3-3:2021

en,fr,de

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

[SIST EN IEC 61784-3-3:2021](#)

<https://standards.iteh.ai/catalog/standards/sist/08a716c5-2acf-486c-95b7-99195f593bf2/sist-en-iec-61784-3-3-2021>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN IEC 61784-3-3

June 2021

ICS 25.040.40; 35.100.05

Supersedes EN 61784-3-3:2017 and all of its
amendments and corrigenda (if any)

English Version

**Industrial communication networks - Profiles - Part 3-3:
Functional safety fieldbuses - Additional specifications for CPF 3
(IEC 61784-3-3:2021)**

Réseaux de communication industriels - Profils - Partie 3-3:
Bus de terrain de sécurité fonctionnelle - Spécifications
supplémentaires pour CPF 3
(IEC 61784-3-3:2021)

Industrielle Kommunikationsnetze - Profile - Teil 3-3:
Funktional sichere Übertragung bei Feldbussen -
Zusätzliche Festlegungen für die
Kommunikationsprofilfamilie 3
(IEC 61784-3-3:2021)

This European Standard was approved by CENELEC on 2021-06-09. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

iTeh STANDARD PREVIEW

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.
[\(standards.iteh.ai\)](https://standards.iteh.ai)

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member [into its own language and notified](#) to the CEN-CENELEC Management Centre has the same status as the official versions.

<https://standards.iteh.ai/catalog/standards/sist/08a716c5-2acf-486c-95b7-99195f593bf2/sist-en-iec-61784-3-3-2021>

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 61784-3-3:2021 (E)**European foreword**

The text of document 65C/1083/FDIS, future edition 4 of IEC 61784-3-3, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61784-3-3:2021.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2022-03-09
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2024-06-09

This document supersedes EN 61784-3-3:2017 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61784-3-3:2021 was approved by CENELEC as a European Standard without any modification.

iTeh STANDARD PREVIEW

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

(standards.iteh.ai)

IEC 60870-5-1	NOTE	Harmonized as EN 60870-5-1 <small>SIST EN IEC 61784-3-3:2021</small>
IEC 61000-1-2	NOTE	Harmonized as EN 61000-1-2 <small>99195f593bf2/sist-en-iec-61784-3-3-2021</small>
IEC 61131-6	NOTE	Harmonized as EN 61131-6
IEC 61158 (series)	NOTE	Harmonized as EN 61158 (series)
IEC 61496 (series)	NOTE	Harmonized as EN IEC 61496 (series)
IEC 61508-1:2010	NOTE	Harmonized as EN 61508-1:2010 (not modified)
IEC 61508-4:2010	NOTE	Harmonized as EN 61508-4:2010 (not modified)
IEC 61508-5:2010	NOTE	Harmonized as EN 61508-5:2010 (not modified)
IEC 61508-6:2010	NOTE	Harmonized as EN 61508-6:2010 (not modified)
IEC 61158-3-3	NOTE	Harmonized as EN 61158-3-3
IEC 61158-4-3	NOTE	Harmonized as EN IEC 61158-4-3
IEC 61158-5 (series)	NOTE	Harmonized as EN 61158-5 (series)
IEC 61784-3 (series)	NOTE	Harmonized as EN 61784-3 (series)
IEC 61784-5 (series)	NOTE	Harmonized as EN IEC 61784-5 (series)
IEC 61800-5-2	NOTE	Harmonized as EN 61800-5-2
IEC 61804 (series)	NOTE	Harmonized as EN IEC 61804 (series)
ISO 10218-1	NOTE	Harmonized as EN ISO 10218-1
ISO 13849 (series)	NOTE	Harmonized as EN ISO 13849 (series)

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60204-1	-	Safety of machinery - Electrical equipment of machines - Part 1: General requirements	EN 60204-1	-
IEC 61000-6-7	-	Electromagnetic compatibility (EMC) - Part 6-7: Generic standards - Immunity requirements for equipment intended to perform functions in a safety-related system (functional safety) in industrial locations	EN 61000-6-7	-
IEC 61010-2-201	2017	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 2-201: Particular requirements for control equipment	EN IEC 61010-2-201	2018 https://standards.techai.catelog/standards/sist/08a/1bcs-2aci-486c-95b7-99195b93b2/sist-en-iec-61784-3-3-2021
IEC 61158-2	-	Industrial communication networks - Fieldbus specifications - Part 2: Physical layer specification and service definition	EN 61158-2	-
IEC 61158-5-3	-	Industrial communication networks - Fieldbus specifications - Part 5-3: Application layer service definition - Type 3 elements	EN 61158-5-3	-
IEC 61158-5-10	-	Industrial communication networks - Fieldbus specifications - Part 5-10: Application layer service definition - Type 10 elements	EN 61158-5-10	-
IEC 61158-6-3	-	Industrial communication networks - Fieldbus specifications - Part 6-3: Application layer protocol specification - Type 3 elements	EN 61158-6-3	-
IEC 61158-6-10	-	Industrial communication networks - Fieldbus specifications - Part 6-10: Application layer protocol specification - Type 10 elements	EN 61158-6-10	-
IEC 61326-3-1	-	Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 3-1: Immunity requirements for safety-related systems and for equipment intended to perform safety-related functions (functional safety) & General industrial applications	EN 61326-3-1	-

EN IEC 61784-3-3:2021 (E)

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61326-3-2	-	Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 3-2: Immunity requirements for safety-related systems and for equipment intended to perform safety-related functions (functional safety) - Industrial applications with specified electromagnetic environment	EN IEC 61326-3-2	-
IEC 61508	series	Functional safety of electrical/electronic/programmable electronic safety-related systems	of EN 61508	series
IEC 61508-2	-	Functional safety of electrical/electronic/programmable electronic safety-related systems - Part 2: Requirements for electrical/electronic/programmable electronic safety-related systems (see Functional Safety and IEC 61508)	of EN 61508-2	-
IEC 61511	series	Functional safety - Safety instrumented systems for the process industry sector	EN 61511	series
IEC 61784-1	-	Industrial communication networks - Profiles EN IEC 61784-1 Part 1: Fieldbus profiles	EN IEC 61784-1	-
IEC 61784-2	-	Industrial communication networks - Profiles - EN IEC 61784-2 Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC/IEEE 8802-3	EN IEC 61784-2	-
IEC 61784-3	2021	Industrial communication networks - Profiles - EN IEC 61784-3 Part 3: Functional safety fieldbuses - General rules and profile definitions	EN IEC 61784-3	2021
IEC 61784-5-3	-	Industrial communication networks – Profiles – EN IEC 61784-5-3 Part 5-3: Installation of fieldbuses – Installation profiles for CPF 3	EN IEC 61784-5-3	-
IEC 61918	2018	Industrial communication networks - EN IEC 61918 Installation of communication networks in industrial premises	EN IEC 61918	2018
IEC 62061	-	Safety of machinery - Functional safety of EN IEC 62061 safety-related control systems	EN IEC 62061	-
IEC 62280	2014	Railway applications - Communication, - signalling and processing systems - Safety related communication in transmission systems	EN IEC 62280	-
IEC 62443	series	Security for industrial automation and control systems	EN IEC 62443	series
ISO 13849-1	2015	Safety of machinery - Safety-related parts of EN ISO 13849-1 control systems - Part 1: General principles for design	EN ISO 13849-1	2015
ISO 13849-2	2012	Safety of machinery - Safety-related parts of EN ISO 13849-2 control systems - Part 2: Validation	EN ISO 13849-2	2012

iTEN STANDARD REVIEW

Standards iTEN.net



INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – Profiles –
Part 3-3: Functional safety fieldbuses – Additional specifications for CPF 3
(standards.iec.ai)**

**Réseaux de communication industriels – Profils –
Partie 3-3: Bus de terrain de sécurité fonctionnelle – Spécifications
supplémentaires pour CPF 3**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100.05

ISBN 978-2-8322-9749-0

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD	9
0 Introduction	11
0.1 General.....	11
0.2 Patent declaration.....	12
1 Scope	14
2 Normative references	14
3 Terms, definitions, symbols, abbreviated terms and conventions	16
3.1 Terms and definitions.....	16
3.1.1 Common terms and definitions.....	16
3.1.2 CPF 3: Additional terms and definitions	22
3.2 Symbols and abbreviated terms	27
3.2.1 Common symbols and abbreviated terms.....	27
3.2.2 CPF 3: Additional symbols and abbreviated terms	28
3.3 Conventions.....	29
4 Overview of FSCP 3/1 (PROFIsafe™).....	29
5 General	32
5.1 External documents providing specifications for the profile	32
5.2 Safety functional requirements	32
5.3 Safety measures	32
5.4 Safety communication layer structure.....	33
5.4.1 Principle of FSCP 3/1 safety communications	33
5.4.2 CPF _{h3} communication structures	35
5.5 Relationships with FAL (and DLL, PhL)	37
5.5.1 Device model.....	37
5.5.2 Application and communication relationships	38
5.5.3 Data types	38
6 Safety communication layer services	39
6.1 F-Host driver services	39
6.2 F-Device driver services	43
6.3 Diagnosis.....	45
6.3.1 Safety alarm generation.....	45
6.3.2 F-(Sub)Module safety layer diagnosis	45
7 Safety communication layer protocol	46
7.1 Safety PDU format	46
7.1.1 Safety PDU structure	46
7.1.2 Safety IO data	47
7.1.3 Status and Control Byte.....	47
7.1.4 (Virtual) MonitoringNumber	49
7.1.5 (Virtual) MNR mechanism (F_CRC_Seed=0)	50
7.1.6 (Virtual) MNR mechanism (F_CRC_Seed=1)	50
7.1.7 CRC2 Signature (F_CRC_Seed=0)	52
7.1.8 CRC2 Signature (F_CRC_Seed=1)	53
7.1.9 Non-safety IO data	54
7.2 FSCP 3/1 behavior.....	54
7.2.1 General	54

7.2.2	F-Host driver state diagram	55
7.2.3	F-Device driver state diagram	58
7.2.4	F-Device driver restart	62
7.2.5	Sequence diagrams	62
7.2.6	Timing diagram for a MonitoringNumber reset	69
7.2.7	Monitoring of safety times	69
7.3	Reaction in the event of a malfunction	72
7.3.1	Corruption of safety data	72
7.3.2	Unintended repetition	72
7.3.3	Incorrect sequence	73
7.3.4	Loss	73
7.3.5	Unacceptable delay	73
7.3.6	Insertion	73
7.3.7	Masquerade	73
7.3.8	Addressing	73
7.3.9	Out-of-sequence	74
7.3.10	Loop-back	74
7.3.11	Network boundaries and router	74
7.4	F-Startup and parameter change at runtime	75
7.4.1	Standard startup procedure	75
8	Safety communication layer management <i>iTeh STANDARD REVIEW</i> (standards.iteh.ai)	75
8.1	F-Parameter	75
8.1.1	Summary	75
8.1.2	F_Source/Destination_Address (Codename)	76
8.1.3	F_WD_Time (F-Watchdog time) <i>SIST EN IEC 61784-3-3:2021</i> https://standards.iteh.ai/catalog/standards/sist/03a716c5-2acf-486c-95b7-	77
8.1.4	F_WD_Time_2 (secondary F-Watchdog time) <i>secondary F-Watchdog time</i>	77
8.1.5	F_Prm_Flag1 (Parameters for the safety layer management)	77
8.1.6	F_Prm_Flag2 (Parameters for the safety layer management)	80
8.1.7	F_iPar_CRC (value of iPar_CRC across iParameters)	81
8.1.8	F_Par_CRC calculation (across F-Parameters)	81
8.1.9	Structure of the F-Parameter record data object	82
8.2	iParameter and iPar_CRC	82
8.3	Safety parameterization	83
8.3.1	Objectives	83
8.3.2	GSDL and GSDML safety extensions	84
8.3.3	Securing safety parameters and GSD data	86
8.4	Safety configuration	90
8.4.1	Order of IO data types	90
8.4.2	Securing the safety IO data description	90
8.4.3	DataItem data type section examples	91
8.5	Data type information usage	95
8.5.1	F-Host Channel driver	95
8.5.2	Rules for standard F-Host Channel drivers	96
8.5.3	Recommendations for the use of F-Host Channel drivers	97
8.6	Safety parameter assignment mechanisms	98
8.6.1	F-Parameter assignment	98
8.6.2	General iParameter assignment	98
8.6.3	System integration requirements for iParameterization tools	98
8.6.4	iPar-Server	100

9	System requirements	111
9.1	Indicators and switches	111
9.2	Installation guidelines	111
9.3	Safety function response time	111
9.3.1	Model	111
9.3.2	Calculation and optimization	113
9.3.3	Adjustment of watchdog times for FSCP 3/1	115
9.3.4	Engineering tool support	116
9.3.5	Retries (repetition of messages)	116
9.4	Duration of demands	117
9.5	Constraints for the calculation of system characteristics	117
9.5.1	Probabilistic considerations	117
9.5.2	Safety related assumptions	119
9.5.3	Non safety related constraints (availability)	120
9.6	Maintenance	120
9.6.1	F-(Sub)Module commissioning / replacement	120
9.6.2	Identification and maintenance functions	120
9.7	Safety manual	121
9.8	Wireless transmission channels	122
9.8.1	Black channel approach	122
9.8.2	Availability	122
9.8.3	Security measures	122
9.8.4	Stationary and mobile applications	122
9.9	Relationship between functional safety and security	123
9.10	Conformance classes	123
10	Assessment	125
10.1	Safety policy	125
10.2	Obligations	125
Annex A (informative)	Additional information for functional safety communication profiles of CPF 3	126
A.1	Hash function calculation	126
A.2	Example values for MonitoringNumbers (MNR)	130
Annex B (informative)	Information for assessment of the functional safety communication profiles of CPF 3	131
Annex C (normative)	Optional features	132
C.1	Reaction on Device_Fault in F-Host	132
C.1.1	Situation	132
C.1.2	Documentation for the user	132
C.1.3	Optional extensions of F-Host driver Transition Table	132
C.1.4	Recommendation for the case without Extensions of F-Host driver Transitions	135
C.2	Optional extensions of F-Host driver to "Disable F-(Sub)Module"	135
C.3	Combination of "Disable F-(Sub)Module" and "reaction on Device_Fault"	139
C.4	FSCP 3/1 and PROFlenergy	141
C.4.1	Use of FSCP 3/1-Devices with PROFlenergy	141
C.4.2	Sequence in case of PROFlenergy power off on	141
C.5	Requirement multiple F-Hosts communicate with single F-(Sub)Module	141
C.6	FSCP 3/1 PiR	142
Bibliography	143	

Figure 1 – Relationships of IEC 61784-3 with other standards (machinery)	11
Figure 2 – Relationships of IEC 61784-3 with other standards (process).....	12
Figure 3 – Basic communication preconditions for FSCP 3/1.....	30
Figure 4 – Structure of an FSCP 3/1 safety PDU.....	30
Figure 5 – Safety communication on CPF 3	31
Figure 6 – Standard CPF 3 transmission system	34
Figure 7 – Safety layer architecture	35
Figure 8 – Basic communication layers	35
Figure 9 – Crossing network borders with routers	36
Figure 10 – Complete safety transmission paths	37
Figure 11 – IO Device model.....	38
Figure 12 – FSCP 3/1 communication structure	39
Figure 13 – F application interface of F-Host driver instances	40
Figure 14 – Motivation for "Channel-related Passivation"	41
Figure 15 – F-Device driver interfaces	43
Figure 16 – Safety PDU for CPF 3	47
Figure 17 – Status Byte.....	47
iTeh STANDARD PREVIEW	
Figure 18 – Control Byte	48
Figure 19 – The Toggle Bit function.....	49
Figure 20 – MonitoringNumber integration	50
Figure 21 – F-Host driver CRC2 signature generation (F_CRC_Seed=0) <small>SIST EN IEC 61784-3-3:2021 https://standards.iteh.ai/catalog/standards/sist/08a716c5-zaci-486c-95b7- 99192938/sist/en/iec61784-3-3-2021</small>	52
Figure 22 – Details of the CRC2 signature calculation (F_CRC_Seed=0).....	53
Figure 23 – CRC2 signature calculation (F_CRC_Seed=1)	53
Figure 24 – Details of the CRC2 signature calculation (F_CRC_Seed=1).....	54
Figure 25 – Safety layer communication relationship.....	54
Figure 26 – F-Host driver state diagram	55
Figure 27 – F-Device driver state diagram	59
Figure 28 – Interaction F-Host driver / F-Device driver during start-up	63
Figure 29 – Interaction F-Host driver / F-Device driver during F-Host power off > on.....	64
Figure 30 – Interaction F-Host driver / F-Device driver with delayed power on	65
Figure 31 – Interaction F-Host driver / F-Device driver during power off → on.....	66
Figure 32 – Interaction while F-Host driver recognizes CRC error.....	67
Figure 33 – Interaction while F-Device driver recognizes CRC error.....	68
Figure 34 – Impact of the MNR reset signal	69
Figure 35 – Monitoring the message transit time F-Host ↔ F-(Sub)Module	70
Figure 36 – Extended watchdog time on request.....	72
Figure 37 – Effect of F_WD_Time_2	77
Figure 38 – F_Prm_Flag1	78
Figure 39 – F_Check_iPar	78
Figure 40 – F_SIL	78
Figure 41 – F_CRC_Length	79
Figure 42 – F_CRC_Seed	79

Figure 43 – F_Prm_Flag2	80
Figure 44 – F_Passivation	80
Figure 45 – F_Block_ID	80
Figure 46 – F_Par_Version	81
Figure 47 – F-Parameter.....	82
Figure 48 – iParameter block	83
Figure 49 – F-Parameter extension within the GSDML specification.....	85
Figure 50 – F_Par_CRC signature including iPar_CRC	86
Figure 51 – F-Host Channel driver as "glue" between F-(Sub)Module and application program.....	96
Figure 52 – Layout example of an F-Host Channel driver	97
Figure 53 – F-Parameter assignment for F-(Sub)Modules	98
Figure 54 – System integration of CPD-Tools.....	99
Figure 55 – iPar-Server mechanism (commissioning).....	100
Figure 56 – iPar-Server mechanism (for example F-(Sub)Module replacement)	102
Figure 57 – iPar-Server request coding ("status model")	103
Figure 58 – Coding of SR_Type	104
Figure 59 – iPar-Server request coding ("alarm model").....	105
Figure 60 – iTeh STANDARD PREVIEW (standards.iteh.ai)	108
Figure 61 – Example safety function with a critical response time path	112
Figure 62 – Simplified typical response time model.....	112
Figure 63 – Frequency distributions of typical response times of the model	113
https://standards.iteh.ai/catalog/standards/sist/08a716c5-2acf-486c-95b7-99195b593bf2/sist-en-ic-61784-3-3-2021	114
Figure 65 – Timing sections forming the FSCP 3/1 F_WD_Time	115
Figure 66 – Frequency distribution of response times with message retries	116
Figure 67 – Residual error probabilities for the 24-bit CRC polynomial.....	117
Figure 68 – Residual error probabilities for the 32-bit CRC polynomial.....	118
Figure 69 – Monitoring of corrupted messages.....	119
Figure A.1 – Typical "C" procedure of a cyclic redundancy check.....	126
Figure C.1 – F-Host driver application interface with feature Reaction on Device_Fault	132
Figure C.2 – F-Host driver application interface with feature Disable F-(Sub)Module	136
Figure C.3 – Timing diagram to use Disable F-(Sub)Module.....	136
 Table 1 – Deployed measures to master errors	33
Table 2 – Data types for FSCP 3/1.....	38
Table 3 – F_MessageTrailer for FSCP 3/1	38
Table 4 – Safety layer diagnosis messages	45
Table 5 – Buffer entry on CRC2 error.....	46
Table 6 – MonitoringNumber of an F-Host driver SPDU	50
Table 7 – MonitoringNumber of an F-Device driver SPDU	50
Table 8 – MonitoringNumber of an F-Host driver SPDU	51
Table 9 – MonitoringNumber of an F-Device driver SPDU	51
Table 10 – Definition of terms used in F-Host driver state diagram.....	55

Table 11 – F-Host driver states and transitions	56
Table 12 – Definition of terms used in Figure 27	59
Table 13 – F-Device driver states and transitions.....	60
Table 14 – SIL monitor times	71
Table 15 – Safety network boundaries	75
Table 16 – Codename octet order	76
Table 17 – Allowed combinations of F_CRC_Seed and F_Passivation	79
Table 18 – GSDL keywords for F-Parameters and F-IO structures	84
Table 19 – Algorithm to build CRC0	87
Table 20 – GSD example in GSDL notation.....	88
Table 21 – GSD example in GSDML notation.....	89
Table 22 – Serialized octet stream for the examples	89
Table 23 – Order of IO data types	90
Table 24 – IO data structure items	91
Table 25 – DataItem section for F_IN_OUT_1.....	92
Table 26 – DATA_STRUCTURE_CRC for F_IN_OUT_1	92
Table 27 – DataItem section for F_IN_OUT_2.....	93
Table 28 – DATA_STRUCTURE_CRC for F_IN_OUT_2	93
Table 29 – DataItem section for F_IN_OUT_5.....	94
Table 30 – DATA_STRUCTURE_CRC for F_IN_OUT_5.....	94
Table 31 – DataItem section for F_IN_OUT_6	95
Table 32 – DATA_STRUCTURE_CRC for F_IN_OUT_6	95
Table 33 – Sample F-Host Channel drivers.....	96
Table 34 – Requirements for iParameterization.....	99
Table 35 – Specifier for the iPar-Server Request	104
Table 36 – Structure of the Read_RES_PDU ("read record").....	106
Table 37 – Structure of the Write_REQ_PDU ("write record").....	106
Table 38 – Structure of the Pull_RES_PDU ("Pull").....	106
Table 39 – Structure of the Push_REQ_PDU ("Push").....	107
Table 40 – iPar-Server states and transitions.....	109
Table 41 – iPar-Server management measures.....	110
Table 42 – Definition of terms in Figure 69.....	119
Table 43 – Information to be included in the safety manual	121
Table 44 – F-Host conformance class requirements	123
Table 45 – Main characteristics of protocol versions	124
Table 46 – F-Host driver / F-Device driver conformance matrix	124
Table A.1 – The table "Crctab24" for 24 bit CRC signature calculations	127
Table A.2 – The table "Crctab32" for 32 bit CRC signature calculations	128
Table A.3 – The table "Crctab16" for 16 bit CRC signature calculations	129
Table A.4 – Values of CN_incrNR_64 and MNR for F-Host PDU	130
Table C.1 – Definition of additional terms used in driver transitions	133
Table C.2 – F-Host driver transitions – added with reaction on Device_Fault	133
Table C.3 – Prevent unintentional restart by application measures.....	135

Table C.4 – F-Host driver transitions – with feature Disable F-(Sub)Module	137
Table C.5 – F-Host driver transitions – added with "reaction on Device_Fault" and "Disable F-(Sub)Module"	139

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN IEC 61784-3-3:2021](#)
<https://standards.iteh.ai/catalog/standards/sist/08a716c5-2acf-486c-95b7-99195f593bf2/sist-en-iec-61784-3-3-2021>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
PROFILES –****Part 3-3: Functional safety fieldbuses –
Additional specifications for CPF 3****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61784-3-3 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- editorial changes regarding timeliness, transformation of comments in the chart into instructions;
- use abbreviations of PROFINET;
- information added about checks and safety manual for PROFIsafe Address Type 1 and 2;
- information added about PFDavg, support of automatic test, add diagnosis messages;