

SLOVENSKI STANDARD

SIST EN IEC 61784-3-8:2021

01-oktober-2021

Nadomešča:

SIST EN 61784-3-8:2018

Industrijska komunikacijska omrežja - Profili - 3-8. del: Funkcijska varnost procesnih vodil - Dodatne specifikacije za CPF 8 (IEC 61784-3-8:2021)

Industrial communication networks - Profiles - Part 3-8: Functional safety fieldbuses - Additional specifications for CPF8 (IEC 61784-3-8:2021)

Industrielle Kommunikationsnetze - Profile - Teil 3-8: Funktionale sichere Übertragung bei Feldbussen - Zusätzliche Festlegungen für die Kommunikationsprofilfamilie 8 (IEC 61784-3-8:2021)

Réseaux de communication industriels - Profils - Partie 3-8: Bus de terrain de sécurité fonctionnelle - Spécifications supplémentaires pour CPF 8 (IEC 61784-3-8:2021)

Ta slovenski standard je istoveten z: EN IEC 61784-3-8:2021

ICS:

25.040.40	Merjenje in krmiljenje industrijskih postopkov	Industrial process measurement and control
35.100.05	Večslojne uporabniške rešitve	Multilayer applications

SIST EN IEC 61784-3-8:2021

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN IEC 61784-3-8:2021](#)

<https://standards.iteh.ai/catalog/standards/sist/f64f54ca-8814-4061-a1c1-f7f272eee76f/sist-en-iec-61784-3-8-2021>

EUROPEAN STANDARD

EN IEC 61784-3-8

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2021

ICS 25.040.40; 35.100.05

Supersedes EN 61784-3-8:2017 and all of its
amendments and corrigenda (if any)

English Version

Industrial communication networks - Profiles - Part 3-8:
Functional safety fieldbuses - Additional specifications for CPF8
(IEC 61784-3-8:2021)

Réseaux de communication industriels - Profils - Partie 3-8:
Bus de terrain de sécurité fonctionnelle - Spécifications
supplémentaires pour CPF 8
(IEC 61784-3-8:2021)

Industrielle Kommunikationsnetze - Profile - Teil 3-8:
Funktional sichere Übertragung bei Feldbussen -
Zusätzliche Festlegungen für die
Kommunikationsprofilfamilie 8
(IEC 61784-3-8:2021)

This European Standard was approved by CENELEC on 2021-06-23. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 61784-3-8:2021 (E)**European foreword**

The text of document 65C/1083/FDIS, future edition 3 of IEC 61784-3-8, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61784-3-8:2021.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2022-03-23 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2024-06-23 document have to be withdrawn

This document supersedes EN 61784-3-8:2017 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61784-3-8:2021 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

<u>SIST EN IEC 61784-3-8:2021</u>		
IEC 61000-1-2	NOTE	Harmonized as EN 61000-1-2
IEC 61000-6-7	NOTE	Harmonized as EN 61000-6-7
IEC 61010-2-201	NOTE	Harmonized as EN IEC 61010-2-201
IEC 61131-6	NOTE	Harmonized as EN 61131-6
IEC 61158-1	NOTE	Harmonized as EN IEC 61158-1
IEC 61158-5 (series)	NOTE	Harmonized as EN 61158-5 (series)
IEC 61496 (series)	NOTE	Harmonized as EN IEC 61496 (series)
IEC 61508-1:2010	NOTE	Harmonized as EN 61508-1:2010 (not modified)
IEC 61508-4:2010	NOTE	Harmonized as EN 61508-4:2010 (not modified)
IEC 61508-5:2010	NOTE	Harmonized as EN 61508-5:2010 (not modified)
IEC 61784-3 (series)	NOTE	Harmonized as EN 61784-3 (series)
IEC 61784-5 (series)	NOTE	Harmonized as EN IEC 61784-5 (series)
IEC 61800-5-2	NOTE	Harmonized as EN 61800-5-2
IEC 61918:2018	NOTE	Harmonized as EN IEC 61918:2018 (not modified)
IEC 62443 (series)	NOTE	Harmonized as EN IEC 62443 (series)
ISO 10218-1	NOTE	Harmonized as EN ISO 10218-1
ISO 13849 (series)	NOTE	Harmonized as EN ISO 13849 (series)
ISO 13849-1:2015	NOTE	Harmonized as EN ISO 13849-1:2015 (not modified)
ISO 13849-2	NOTE	Harmonized as EN ISO 13849-2

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61131-2	-	Industrial-process measurement and control - Programmable controllers - Part 2: Equipment requirements and tests	-	-
IEC 61158	series	Industrial communication networks - Fieldbus specifications	EN IEC 61158	series
IEC 61158-2	-	Industrial communication networks - Fieldbus specifications - Part 2: Physical layer specification and service definition	EN 61158-2	-
IEC 61158-3-18	-	Industrial communication networks - Fieldbus specifications - Part 3-18: Data-link layer service definition - Type 18 elements	EN 61158-3-18	-
IEC 61158-4-18	-	Industrial communication networks - Fieldbus specifications - Part 4-18: Data-link layer protocol specification - Type 18 elements	EN 61158-4-18	-
IEC 61158-5-18	-	Industrial communication networks - Fieldbus specifications - Part 5-18: Application layer service definition - Type 18 elements	EN 61158-5-18	-
IEC 61158-5-23	-	Industrial communication networks - Fieldbus specifications - Part 5-23: Application layer service definition - Type 23 elements	EN IEC 61158-5-23	-
IEC 61158-6-18	-	Industrial communication networks - Fieldbus specifications - Part 6-18: Application layer protocol specification - Type 18 elements	EN 61158-6-18	-
IEC 61158-6-23	-	Industrial communication networks - Fieldbus specifications - Part 6-23: Application layer protocol specification - Type 23 elements	EN IEC 61158-6-23	-

EN IEC 61784-3-8:2021 (E)

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61326-3-1	-	Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 3-1: Immunity requirements for safety-related systems and for equipment intended to perform safety-related functions (functional safety) - General industrial applications	EN 61326-3-1	-
IEC 61326-3-2	-	Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 3-2: Immunity requirements for safety-related systems and for equipment intended to perform safety-related functions (functional safety) - Industrial applications with specified electromagnetic environment	EN IEC 61326-3-2	-
IEC 61508	series	Functional safety of electrical/electronic/programmable electronic safety-related systems	EN 61508	series
IEC 61511	series	Functional safety - Safety instrumented systems for the process industry sector -	EN 61511	series
IEC 61784-1	-	Industrial communication networks - Profiles Part 1: Fieldbus profiles	EN IEC 61784-1	-
IEC 61784-2	-	Industrial communication networks - Profiles - Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC/IEEE 8802-3	EN IEC 61784-2	-
IEC 61784-3	2021	Industrial communication networks - Profiles - Part 3: Functional safety fieldbuses - General rules and profile definitions	EN IEC 61784-3	2021
IEC 62061	-	Safety of machinery - Functional safety of safety-related control systems	EN IEC 62061	-
ISO/IEC/IEEE 8802-3	-	Information technology - Telecommunications and information exchange between systems - Local and metropolitan area networks - Specific requirements - Part 3: Standard for Ethernet	-	-



IEC 61784-3-8

Edition 3.0 2021-05

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Industrial communication networks – Profiles –
Part 3-8: Functional safety fieldbuses – Additional specifications for CPF 8
(standards.itec.ai)

Réseaux de communication industriels – Profils –
Partie 3-8: Bus de terrain de sécurité fonctionnelle – Spécifications
supplémentaires pour CPF 8

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100.05

ISBN 978-2-8322-9751-3

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD	7
0 Introduction	9
0.1 General.....	9
0.2 Patent declaration.....	11
1 Scope.....	12
2 Normative references	12
3 Terms, definitions, symbols, abbreviated terms and conventions	13
3.1 Terms and definitions.....	13
3.1.1 Common terms and definitions.....	14
3.1.2 CPF 8: Additional terms and definitions	20
3.2 Symbols and abbreviated terms	21
3.2.1 Common symbols and abbreviated terms.....	21
3.2.2 CPF 8: Additional symbols and abbreviated terms	22
3.3 Conventions.....	22
4 Overview	22
5 General	22
6 Safety communication layer services.....	22
7 Safety communication layer protocol	23
8 Safety communication layer management	23
9 System requirements	23
10 Assessment.....	23
11 FSCP 8/1.....	23
11.1 Scope – FSCP 8/1	23
11.2 Normative references – FSCP 8/1	23
11.3 Terms, definitions, symbols, abbreviated terms and conventions – FSCP 8/1.....	23
11.4 Overview of FSCP 8/1 (CC-Link Safety™).....	23
11.5 General – FSCP 8/1	24
11.5.1 External documents providing specifications for the profile	24
11.5.2 Safety functional requirements	24
11.5.3 Safety measures.....	24
11.5.4 Safety communication layer structure	26
11.5.5 Relationships with FAL (and DLL, PhL).....	27
11.6 Safety communication layer services for FSCP 8/1	27
11.6.1 General	27
11.6.2 SASEs	27
11.6.3 SARs	28
11.6.4 Process data SAR ASEs.....	29
11.7 Safety communication layer protocol for FSCP 8/1	30
11.7.1 Safety PDU format.....	30
11.7.2 State description.....	38
11.8 Safety communication layer management for FSCP 8/1	43
11.8.1 General	43
11.8.2 Connection establishment and confirmation processing	43
11.8.3 Safety slave verification.....	43
11.9 System requirements for FSCP 8/1	44

11.9.1	Indicators and switches	44
11.9.2	Installation guidelines	45
11.9.3	Safety function response time.....	45
11.9.4	Duration of demands	47
11.9.5	Constraints for calculation of system characteristics	47
11.9.6	Maintenance	47
11.9.7	Safety manual	47
11.10	Assessment for FSCP 8/1	47
12	FSCP 8/2.....	48
12.1	Scope – FSCP 8/2	48
12.2	Normative references – FSCP 8/2.....	48
12.3	Terms, definitions, symbols, abbreviated terms and conventions – FSCP 8/2.....	48
12.4	Overview of FSCP 8/2 (CC-Link IE™ Safety communication function).....	48
12.5	General – FSCP 8/2.....	48
12.5.1	External documents providing specifications for the profile	48
12.5.2	Safety functional requirements	49
12.5.3	Safety measures.....	49
12.5.4	Safety communication layer structure	54
12.5.5	Relationships with FAL (and DLL, PhL).....	55
12.6	Safety communication layer services for FSCP 8/2	55
12.6.1	General	55
12.6.2	Connection reestablishment services	55
12.6.3	Data transmission services	56
12.6.4	Connection termination notification services	57
12.7	Safety communication layer protocol for FSCP 8/2	57
12.7.1	Safety PDU format	57
12.7.2	Safety FAL service protocol machine (SFSPM)	64
12.8	Safety communication layer management for FSCP 8/2	90
12.8.1	Parameter Definitions	90
12.8.2	Parameter Setup	94
12.8.3	Management Services	95
12.9	System requirements for FSCP 8/2	98
12.9.1	Indicators and switches	98
12.9.2	Installation guidelines	100
12.9.3	Safety function response time.....	100
12.9.4	Duration of demands	101
12.9.5	Constraints for calculation of system characteristics	101
12.9.6	Maintenance	102
12.9.7	Safety manual	102
12.10	Assessment for FSCP 8/2	103
Annex A (informative)	Additional information for functional safety communication profiles of CPF 8.....	104
A.1	Hash function calculation for FSCP 8/1	104
A.2	Hash function calculation for FSCP 8/2	104
A.3	Meaning of response time calculation formula for FSCP 8/2.....	105
Annex B (informative)	Information for assessment of the functional safety communication profiles of CPF 8.....	107
Bibliography.....		108

Figure 1 – Relationships of IEC 61784-3 with other standards (machinery)	9
Figure 2 – Relationships of IEC 61784-3 with other standards (process).....	10
Figure 3 – Relationship between SCL and the other layers of IEC 61158 Type 18.....	27
Figure 4 – State diagram	39
Figure 5 – Detection of unintended repetition.....	51
Figure 6 – Detection of incorrect sequence	51
Figure 7 – Detection of loss	52
Figure 8 – Detection of unacceptable delay by time stamps	53
Figure 9 – Detection of unacceptable delay by timer	53
Figure 10 – Protocol Hierarchy.....	54
Figure 11 – Safety PDU Structure	58
Figure 12 – CTRL Configuration.....	59
Figure 13 – SASE-M and SASE-S TS	62
Figure 14 – S-Data during safety refresh	62
Figure 15 – S-Data not during safety refresh.....	63
Figure 16 – S-Data header configuration.....	63
Figure 17 – CRC calculation	64
Figure 18 – Communication models	64
Figure 19 – SFSPM state transition diagram	65
Figure 20 – Connection establishment sequence	67
Figure 21 – Optional sequence during connection establishment sequence	68
Figure 22 – Communication sequence during safety refresh communication	68
Figure 23 – Offset measurement and generation sequence during safety refresh communication.....	69
Figure 24 – SFSPM-M state transition diagram	70
Figure 25 – Sequence other than during safety refresh	74
Figure 26 – S-Connect-req.....	74
Figure 27 – S-InitConfirmNetPrm-req	75
Figure 28 – net_prm_list	75
Figure 29 – S-InitVerifyStnPrm-req	75
Figure 30 – stn_prm_list	76
Figure 31 – S-InvokeFunc-req.....	76
Figure 32 – S-WriteErrorInfo-req.....	77
Figure 33 – date_and_time_of_occurrence.....	78
Figure 34 – SFSPM-S state transition diagram.....	79
Figure 35 – Sequence other than during safety refresh	84
Figure 36 – S-Connect-rsp.....	84
Figure 37 – S-InitConfirmNetPrm-rsp	85
Figure 38 – S-InitVerifyStnPrm-rsp	85
Figure 39 – S-InvokeFunc-rsp.....	86
Figure 40 – Offset calculation procedure of safety clock	87
Figure 41 – Relationship between transmission interval fluctuation and transmission_interval	91
Figure 42 – Calculation of allowable_refresh_interval	93

Figure 43 – Calculation of allowable_delay	94
Figure 44 – Calculation of response time between safety PLCs	100
Figure 45 – Constraints on N_{SE} and m	102
Figure A.1 – Allowable_delay and offset calculation deviation	105
Table 1 – Selection of the various measures for possible errors	25
Table 2 – M1 safety device manager attribute format	31
Table 3 – S1 safety device manager attribute format	31
Table 4 – M1 safety connection manager attribute format	31
Table 5 – S1 safety connection manager attribute format	31
Table 6 – M1 safety cyclic transmission attribute format	32
Table 7 – S1 safety cyclic transmission attribute format	33
Table 8 – M1 safety device manager attribute encoding	33
Table 9 – S1 safety device manager attribute encoding	34
Table 10 – M1 safety connection manager attribute encoding	34
Table 11 – S1 safety connection manager attribute encoding	34
Table 12 – M1 safety cyclic transmission attribute encoding	35
Table 13 – S1 safety cyclic transmission attribute encoding	37
Table 14 – Safety master monitor timer operation	41
Table 15 – Safety slave monitor timer operation	41
Table 16 – Safety data monitor timer operation	41
Table 17 – Details of connection establishment and confirmation processing	43
Table 18 – Details of slave information verification processing	43
Table 19 – Details of safety slave parameter transmission processing	44
Table 20 – Monitor LEDs	45
Table 21 – Safety function response time calculation	46
Table 22 – Safety function response time definition of terms	46
Table 23 – Selection of the various measures for possible errors	50
Table 24 – SS-Start	55
Table 25 – SS-Restart	55
Table 26 – SS-InvokeFunc	56
Table 27 – SS-Read	56
Table 28 – SS-Write	57
Table 29 – SS-Terminate	57
Table 30 – Safety PDU elements	58
Table 31 – CTRL Elements	59
Table 32 – State list	65
Table 33 – SFSPM-M timers	70
Table 34 – SFSPM-M state transition table	71
Table 35 – support_functions	74
Table 36 – error_category	77
Table 37 – error_category for AL errors	77
Table 38 – error_code	78

Table 39 – SFSPM-S timers.....	79
Table 40 – SFSPM-S state transition table.....	80
Table 41 – Parameters used by safety communication layer	90
Table 42 – SM-SetSafetyStationInfo	95
Table 43 – Safety station information setting parameters of SM-SetSafetyStationInfo	95
Table 44 – SM-SetSafetyNetworkParameter	96
Table 45 – Safety network parameters of SM-SetSafetyNetworkParameter	96
Table 46 – SM-GetSafetyStationInfo	96
Table 47 – Safety station information parameters of SM-GetSafetyStationInfo (Request).....	97
Table 48 – Safety station information parameters of SM-GetSafetyStationInfo (Response).....	97
Table 49 – SM-GetSafetyNetworkParameter	97
Table 50 – Parameters of SM-GetSafetyNetworkParameter request.....	97
Table 51 – Parameters of SM-GetSafetyNetworkParameter response	98
Table 52 – Monitor LEDs	99
Table 53 – Communication port monitor LEDs	99
Table A.1 – Residual error probability for FSCP 8/1 CRC.....	104
Table A.2 – Residual error probability for FSCP 8/2 CRC.....	105

ITEH STANDARD PREVIEW
(standards.iteh.ai)

SIST EN IEC 61784-3-8:2021

<https://standards.iteh.ai/catalog/standards/sist/f64f54ca-8814-4061-a1c1-f7f272eee76f/sist-en-iec-61784-3-8-2021>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
PROFILES –****Part 3-8: Functional safety fieldbuses –
Additional specifications for CPF 8**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61784-3-8 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This third edition cancels and replaces the second edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- structured for compliance with IEC 61784-3 Ed.4;
- general editorial changes and clarifications;
- safety measures (11.5.3);

- safety application service elements (11.6.2);
- safety PDU format (11.7.1);
- constraints for calculations of system characteristics (11.9.5);
- safety measures (12.5.3);
- safety PDU format (12.7.1);
- behaviour (12.7.2);
- constraints for calculations of system characteristics (12.9.5);
- hash function calculations (Annex A).

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/1083/FDIS	65C/1087/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

A list of all parts of the IEC 61784-3 series, published under the general title *Industrial communication networks – Profiles – Functional safety fieldbuses*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.


0 Introduction

0.1 General

The IEC 61158 (all parts) fieldbus standard together with its companion standards IEC 61784-1 and IEC 61784-2 defines a set of communication protocols that enable distributed control of automation applications. Fieldbus technology is now considered well accepted and well proven. Thus fieldbus enhancements continue to emerge, addressing applications for areas such as real time and safety-related applications.

IEC 61784-3 (all parts) explains the relevant principles for functional safety communications with reference to IEC 61508 (all parts) and specifies several safety communication layers (profiles and corresponding protocols) based on the communication profiles and protocol layers of IEC 61784-1, IEC 61784-2 and IEC 61158 (all parts). It does not cover electrical safety and intrinsic safety aspects. It also does not cover security aspects, nor does it provide any requirements for security.

Figure 1 shows the relationships between IEC 61784-3 (all parts) and relevant safety and fieldbus standards in a machinery environment.



NOTE IEC 62061 specifies the relationship between PL (Category) and SIL.

Figure 1 – Relationships of IEC 61784-3 with other standards (machinery)

Figure 2 shows the relationships between IEC 61784-3 (all parts) and relevant safety and fieldbus standards in a process environment.