



SLOVENSKI STANDARD
SIST EN ISO 16890-3:2024

01-november-2024

Zračni filtri pri splošnem prezračevanju - 3. del: Ugotavljanje gravimetrijske učinkovitosti in odpornosti pretoka zraka v odvisnosti od mase zajetega preskusnega prahu (ISO 16890-3:2024)

Air filters for general ventilation - Part 3: Determination of the gravimetric efficiency and the air flow resistance versus the mass of test dust captured (ISO 16890-3:2024)

Luftfilter für die allgemeine Raumlufttechnik - Teil 3: Ermittlung des gravimetrischen Wirkungsgrades sowie des Durchflusswiderstandes im Vergleich zu der aufgenommenen Masse von Prüfstaub (ISO 16890-3:2024)

Filtres à air de ventilation générale - Partie 3: Détermination de l'efficacité gravimétrique et de la résistance à l'écoulement de l'air par rapport à la quantité de poussière d'essai retenue (ISO 16890-3:2024)

<https://standards.iteh.ai>
<https://standards.iteh.ai/catalog/standards/sist/15a4a046-5990-4db4-b24e-b7af4e56ae90/sist-en-iso-16890-3-2024>

Ta slovenski standard je istoveten z: EN ISO 16890-3:2024

ICS:

91.140.30	Prezračevalni in klimatski sistemi	Ventilation and air-conditioning systems
-----------	------------------------------------	--

SIST EN ISO 16890-3:2024

en,fr,de

EUROPEAN STANDARD

EN ISO 16890-3

NORME EUROPÉENNE

EUROPÄISCHE NORM

September 2024

ICS 91.140.30

Supersedes EN ISO 16890-3:2016

English Version

Air filters for general ventilation - Part 3: Determination of the gravimetric efficiency and the air flow resistance versus the mass of test dust captured (ISO 16890-3:2024)

Filtres à air de ventilation générale - Partie 3: Détermination de l'efficacité gravimétrique et de la résistance à l'écoulement de l'air par rapport à la quantité de poussière d'essai retenue (ISO 16890-3:2024)

Luftfilter für die allgemeine Raumlufttechnik - Teil 3: Ermittlung des gravimetrischen Wirkungsgrades sowie des Durchflusswiderstandes im Vergleich zu der aufgenommenen Masse von Prüfstaub (ISO 16890-3:2024)

This European Standard was approved by CEN on 24 August 2024.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	3

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

[SIST EN ISO 16890-3:2024](https://standards.itih.ai/catalog/standards/sist/15a4a046-5990-4db4-b24e-b7af4e56ae90/sist-en-iso-16890-3-2024)

<https://standards.itih.ai/catalog/standards/sist/15a4a046-5990-4db4-b24e-b7af4e56ae90/sist-en-iso-16890-3-2024>

European foreword

This document (EN ISO 16890-3:2024) has been prepared by Technical Committee ISO/TC 142 "Cleaning equipment for air and other gases" in collaboration with Technical Committee CEN/TC 195 "Cleaning equipment for air and other gases" the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2025, and conflicting national standards shall be withdrawn at the latest by March 2025.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 16890-3:2016.

Any feedback and questions on this document should be directed to the users' national standards body/national committee. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

(<https://standards.iteh.ai>)

Endorsement notice

The text of ISO 16890-3:2024 has been approved by CEN as EN ISO 16890-3:2024 without any modification.

[SIST EN ISO 16890-3:2024](https://standards.iteh.ai)

<https://standards.iteh.ai/catalog/standards/sist/15a4a046-5990-4db4-b24e-b7af4e56ae90/sist-en-iso-16890-3-2024>



International Standard

ISO 16890-3

Air filters for general ventilation —

Part 3:

Determination of the gravimetric efficiency and the air flow resistance versus the mass of test dust captured

Filtres à air de ventilation générale —

*Partie 3: Détermination de l'efficacité gravimétrique et de la
résistance à l'écoulement de l'air par rapport à la quantité de
poussière d'essai retenue*

**Second edition
2024-08**

ISO 16890-3:2024(en)

iTeh Standards (<https://standards.iteh.ai>) Document Preview

[SIST EN ISO 16890-3:2024](https://standards.iteh.ai/catalog/standards/sist/15a4a046-5990-4db4-b24e-b7af4e56ae90/sist-en-iso-16890-3-2024)

<https://standards.iteh.ai/catalog/standards/sist/15a4a046-5990-4db4-b24e-b7af4e56ae90/sist-en-iso-16890-3-2024>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2024

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

ISO 16890-3:2024(en)

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
3.1 Air flow and resistance.....	2
3.2 Test device.....	2
3.3 Gravimetric efficiency.....	3
4 Symbols	4
5 General test device requirements	5
5.1 Test device requirements.....	5
5.2 Test device preparation.....	5
6 Loading dust	5
7 Test equipment	5
7.1 Test rig.....	5
7.2 Upstream mixing orifice.....	5
7.3 Liquid aerosol testing devices.....	6
7.4 Dust feeder.....	6
7.5 Final filter.....	10
8 Qualification of test rig and apparatus	11
8.1 Schedule of qualification testing requirements.....	11
8.2 Dust feeder air flow rate.....	11
8.3 Final filter efficiency qualification test.....	12
9 Test sequence dust-loading procedure	12
9.1 Test procedure for the filter.....	12
9.1.1 Preparation of the test device.....	12
9.1.2 Initial resistance to air flow.....	12
9.2 Dust loading.....	13
9.2.1 Dust loading procedure.....	13
9.2.2 Arrestance.....	13
9.2.3 Test dust capacity.....	14
10 Reporting results	14
10.1 General.....	14
10.2 Required reporting elements.....	14
10.2.1 Report values.....	14
10.2.2 Report summary.....	15
10.2.3 Report details.....	16
Annex A (informative) Resistance to air flow calculation	20
Bibliography	22

ISO 16890-3:2024(en)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 142, *Cleaning equipment for air and other gases*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 195, *Cleaning equipment for air and other gases*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 16890-3:2016), which has been technically revised.

The main changes are as follows:

- the initial loading step has been revised from 30 g to 60 g throughout the document.

A list of all parts in the ISO 16890 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

ISO 16890-3:2024(en)

Introduction

The effects of particulate matter (PM) on human health have been extensively studied in the past decades. The results are that fine dust can be a serious health hazard, contributing to or even causing respiratory and cardiovascular diseases. For the outdoor environment, the U.S. Environmental Protection Agency (EPA), the World Health Organization (WHO), the European Union, and other national agencies have established acceptable air quality standards according to concentrations of particulate matter classified per their aerodynamic sizes, defined as $PM_{2,5}$ and PM_{10} , and measured according to strict prescriptive methods and sampling times.

Since there is growing interest in relating indoor air quality to outdoors, the ISO 16890 series classifies ventilation filters according to their efficiencies measured with an optical diameter between $0,3 \mu\text{m}$ and $x \mu\text{m}$ and relating the result to historic global average ambient PM concentrations. Although not exactly equivalent to filter performance of national ambient air quality standards at PM, the classification scheme presented in the ISO 16890 series yields a level of correspondence to the effectiveness of the filter for ambient particle concentrations. It is however recognized that the correspondence based on global averages may not be exactly the same at a specific location since local ambient particle concentration may be different than the global average.

The particle size ranges shown in [Table 1](#) are used in the ISO 16890 series for the listed efficiency values.

Table 1 — Optical particle diameter size ranges for the definition of the efficiencies, ePM_x

Efficiency	Size range μm
ePM_{10}	$0,3 \leq x \leq 10$
$ePM_{2,5}$	$0,3 \leq x \leq 2,5$
ePM_1	$0,3 \leq x \leq 1$

Air filters for general ventilation are widely used in heating, ventilation and air-conditioning applications of buildings. In this application, air filters significantly influence the indoor air quality and, hence, the health of people, by reducing the concentration of particulate matter. To enable design engineers and maintenance personnel to choose the correct filter types, there is an interest from international trade and manufacturing for a well-defined, common method of testing and classifying air filters according to their particle efficiencies, especially with respect to the removal of particulate matter. Current regional standards are applying totally different testing and classification methods, which do not allow any comparison with each other, and thus hinder global trade with common products. Additionally, the current industry standards have known limitations by generating results which often are far away from filter performance in service, i.e. overstating the particle removal efficiency of many products. With the ISO 16890 series, a completely new approach for a classification system is adopted, which gives more meaningful results compared to the existing standards.

The ISO 16890 series describes the equipment, materials, technical specifications, requirements, qualifications and procedures to produce the laboratory performance data and efficiency classification based upon the measured fractional efficiency converted into a particulate matter efficiency (ePM) reporting system.

Air filter elements according to the ISO 16890 series are evaluated in the laboratory by their ability to remove aerosol particulate expressed as the efficiency values ePM_1 , $ePM_{2,5}$ and ePM_{10} . The air filter elements can then be classified according to the procedures defined in ISO 16890-1. The particulate removal efficiency of the filter element is measured as a function of the particle size in the range of $0,3 \mu\text{m}$ to $10 \mu\text{m}$ of the unloaded and unconditioned filter element as per the procedures defined in ISO 16890-2. After the initial particulate removal efficiency testing, the air filter element is conditioned according to the procedures defined in ISO 16890-4 and the particulate removal efficiency is repeated on the conditioned filter element. This is done to provide information about the intensity of any electrostatic removal mechanism which may or may not be present with the filter element for test. The average efficiency of the filter is determined by calculating the mean between the initial efficiency and the conditioned efficiency for each size range. The average efficiency is used to calculate the ePM_x efficiencies by weighting these values to the standardized and normalized particle size distribution of the related ambient aerosol fraction. When comparing filters