

SLOVENSKI STANDARD SIST EN 14841:2023

01-september-2023

Nadomešča: SIST EN 14841:2014

Oprema in pribor za utekočinjeni naftni plin (UNP) - Postopek polnjenja in praznjenja železniških cistern za UNP

LPG equipment and accessories - Filling and discharge procedures for LPG rail tankers

Flüssiggas-Geräte und Ausrüstungsteile - Füll- und Entleerungsverfahren für Eisenbahnkesselwagen für Flüssiggas (LPG)

Équipements pour GPL et leurs accessoires - Procédures de chargement et déchargement des wagons-citernes pour GPL

Ta slovenski standard je istoveten z: EN 14841:2023

ICS:

23.020.20 Posode in vsebniki, montirani Vessels and containers na vozila mounted on vehicles
45.060.20 Železniški vagoni Trailing stock

SIST EN 14841:2023

en,fr,de



iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>SIST EN 14841:2023</u> https://standards.iteh.ai/catalog/standards/sist/d75b7c70-9c38-4d19-b4a5-0e64ad327cf8/sist-en-14841-2023

SIST EN 14841:2023

EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

EN 14841

May 2023

ICS 23.020.20; 45.060.20

Supersedes EN 14841:2013

English Version

LPG equipment and accessories - Filling and discharge procedures for LPG rail tankers

Équipements pour GPL et leurs accessoires -Procédures de chargement et déchargement des wagons-citernes pour GPL Flüssiggas-Geräte und Ausrüstungsteile - Füll- und Entleerungsverfahren für Eisenbahnkesselwagen für Flüssiggas (LPG)

This European Standard was approved by CEN on 24 April 2023.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.

https://standards.iteh.ai/catalog/standards/sist/d75b7c70-9c38-4d19-b4a5-0e64ad327cf8/sist-en-14841-2023



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

SIST EN 14841:2023

EN 14841:2023 (E)

Contents

European foreword		
Introduction4		ł
1 Scop	ppe5	5
2 Nor	rmative references5	5
3 Terr	rms and definitions	5
4 Gen	neral operation	5
5 Pro	ocedures	5
5.1 Gen	neral5	5
5.2 Filli	ing6	ó
5.2.1 Prej	eparation for filling	5
	ing operations	
	npletion of filling	
5.2.4 Pred	ecautions against overfilling	7
5.3 Disc	charge	3
	eparation for discharge	
	charge operations	
5.3.3 Com	npletion of discharge)
	charging by pumps	
	charging by compressor)
5.4 Inte	charging by compressor)
	nttps://standards.iten.ai/catalog/standards/sist/d/bb/c/0-9c38-4d19-04a3-	ĺ
	ergency procedure	
Annex A (informative) Safety recommendations11		
Bibliograpl	3ibliography12	

European foreword

This document (EN 14841:2023) has been prepared by Technical Committee CEN/TC 286 "Liquefied petroleum gas equipment and accessories", the secretariat of which is held by NSAI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2023, and conflicting national standards shall be withdrawn at the latest by November 2023.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 14841:2013.

In comparison with the previous edition, the following technical modifications have been made:

- Removal of the Annex A on the Environmental checklist;
- Addition of a reference to CEN/TS 16765;
- A new Annex A was added giving recommendations on the personal protection equipment;
- Updating of the Introduction;
- In addition to the discharge of LPG, requirements for the filling of LPG were also added;
- The document was harmonized in both the filling and the discharge sections with EN 13776;
- A new clause on Integrate shut down systems was added.

https://standards.iteh.ai/catalog/standards/sist/d75b7c70-9c38-4d19-b4a5-

This document will be submitted for reference in: en-14841-2023

— the technical annexes of the ADR [5].

NOTE These regulations take precedence over any clause of this standard. It is emphasized that RID/ADR are being revised regularly at intervals of two years which can lead to temporary non-compliances with the clauses of this standard.

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

[—] the RID [4]; and/or

Introduction

This document calls for the use of substances and procedures that can be injurious to health if adequate precautions are not taken. It refers only to technical suitability and does not absolve the user from legal obligations relating to health and safety at any stage.

The frequencies of the different types of pressure vessel inspection are given by the relevant international regulations concerning the transport of dangerous goods.

Protection of the environment is a key political issue in Europe and elsewhere. For CEN/TC 286 this is covered in CEN/TS 16765 [1], and this Technical Specification should be read in conjunction with this document. CEN/TS 16765 provides guidance on the environmental aspects to be considered regarding equipment and accessories produced for the LPG industry and the following is addressed:

- a) design;
- b) manufacture;
- c) packaging;
- d) use and operation; and
- e) disposal.

It is recommended that companies using this document develop an environmental management policy. For guidance, see EN ISO 14001 [2].

It has been assumed in the drafting of this document that the execution of its provisions is entrusted to appropriately qualified and experienced people.

All pressures are gauge pressures unless otherwise stated. 41:2023

NOTE This document requires measurement of material properties, dimensions and pressures. All such measurements are subject to a degree of uncertainty due to tolerances in measuring equipment, etc. It can be beneficial to refer to the leaflet "Measurement uncertainty leaflet" SP INFO 2000 27 [3].

1 Scope

This document specifies procedures for filling, discharge and handling operations as well as emergency procedures for rail tankers used for the transport of liquefied petroleum gas (LPG).

This document does not apply to "tank containers" and "batteries of receptacles".

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

CEN/TS 16769, LPG equipment and accessories - Terminology

3 Terms and definitions

For the purposes of this document, the terms and definitions given in CEN/TS 16769 apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <u>https://www.iso.org/obp</u>
- IEC Electropedia: available at https://www.electropedia.org/

4 General operation

Handling operations such as: Standards.iteh.al)

- accepting rail tankers upon arrival;
 - SIST EN 14841:2023
- filling and/or discharge of LPG; and og/standards/sist/d75b7c70-9c38-4d19-b4a5-
- 0e64ad327cf8/sist-en-14841-20
- preparation and returning rail tanker

shall be carried out under the supervision of a competent person (e.g. operator of the site) and shall be in accordance with the site procedures.

5 Procedures

5.1 General

Site procedures in written form including emergency procedures shall be available, understood and followed by all persons involved in each operation. This shall be achieved by training and supervision. The responsibilities of the persons involved shall be clearly specified.

The procedures shall include a check of the rail tanker that is to be carried out before it is accepted. This shall include:

- the marking;
- a check of the integrity of the rail tanker;
- a check of tamper evident seals; and
- an identification check of LPG quality and grade.

EN 14841:2023 (E)

In case of transfer to/from another tanker, the procedures shall also include the check of that other tanker.

Where deficiencies are found, they shall be recorded and reported to the appropriate body (e.g. rail tanker loader) and the rail tanker operator. A rail tanker shall not be filled and/or discharged until any necessary remedial work has been completed.

Copies of checklists and deficiency reports shall be retained.

Personnel carrying out LPG transfer operations shall wear personal protection equipment. The operations of filling and discharging shall be done under constant supervision.

NOTE 1 Recommendations for personal protection equipment are given in Annex A.

The filling and discharge areas shall be inspected for fire hazards prior to beginning operations. Suitable fire protection shall be readily available.

NOTE 2 Responsibilities for fire protection are subject to national regulations.

5.2 Filling

5.2.1 Preparation for filling

5.2.1.1 The rail tanker to be filled shall be moved to the filling area and positioned in accordance with the site procedures.

5.2.1.2 Any device provided to check the loaded quantity (e.g. by weight) shall be operational.

5.2.1.3 Parking brakes and railway wheel chock or other equivalent means shall be applied to prevent unintended movement of any rail tanker involved during filling. The site, where the rail tankers are parked for filling shall be isolated from other rail traffic. If fitted, anti-drive-away interlocks shall be engaged.

https://standards.iteh.ai/catalog/standards/sist/d75b7c70-9c38-4d19-b4a5-

5.2.1.4 The electrostatic potential of the rail tanker and the discharging pressure vessel shall then be equalised before the LPG hoses or loading arms are connected.

5.2.1.5 All rail tanker valves shall be checked to ensure that they are in the closed position.

5.2.1.6 Blanking caps or blind flanges shall be removed from the liquid and vapour connections (where fitted and when used) to be used.

5.2.1.7 Ensure that the site is safe for filling LPG and adequate ullage capacity is available. Specific requirements for this shall be part of the site procedures.

5.2.1.8 Hoses and loading arms shall be checked for kinks, wear or obvious damage. Fill-couplings, seals and necessary attachments shall be examined to ensure compatibility and that no dirt or any other foreign matter is present before connection.

5.2.1.9 Connections shall be properly made before starting to fill. Hoses/loading arms shall not be fully extended in making the connections. A check shall be made for any sign of leakage before filling commences. Any leakage shall be rectified before proceeding.

5.2.1.10 If any rail tanker involved in the filling is equipped with foot valve(s), an emergency ripcord shall be connected to the rail hook that will shut down the foot valve in the event of unintended movement of that rail tanker.

5.2.1.11 Precautions shall be taken to ensure that the grade of LPG to be filled is correctly identified and that the rail tanker is suitable for the intended load and that it is correctly labelled (see RID, 4.3.3.2.5 [4]).

NOTE In the RID [4] the terms "placarding" and "orange-coloured plate marking" are used in place of "labelling".

5.2.1.12 Where fitted, rail tanker loading control systems shall be connected.

5.2.2 Filling operations

Transfer couplings (hoses or loading arms) shall be connected without submitting them to any abnormal stresses. The rail tanker, product terminal and vapour return valves, where applicable, shall be opened in the required sequence and manner in accordance with the site procedures. The connections between the transfer couplings and the rail tanker shall be checked for leakage. Further periodic leakage checks shall be carried out directly after the product transfer operation has begun. In case any leakage is detected, the filling operations shall be stopped immediately in order to make the transfer couplings gastight.

It can be necessary to reduce the transfer rates in order to ensure that the maximum fill is not exceeded.

5.2.3 Completion of filling

5.2.3.1 The filling shall be stopped when the maximum fill level of the receiving rail tanker is reached.

5.2.3.2 The rail tanker, product terminal and vapour return valves, where applicable, shall be closed in the required sequence and manner in accordance with the site procedures ensuring that valves closest to the pressure vessel of the rail tanker are closed first. Then the ripcord(s) shall be disconnected.

5.2.3.3 Any LPG between the transfer couplings shall be vented in a safe manner before fully disconnecting.

5.2.3.4 After disconnection of the filling line and any other connections to the rail tanker (vapour return or tanker loading control) all valves of the rail tanker shall be properly closed and the lines stowed. Blanking caps and blind flanges shall be secured in place and checked for leaks.

5.2.3.5 A final check shall be made to ensure that the rail tanker is in a fit condition to be moved away. There shall be no sign of leakage. The connection made to equalize the electrostatic potential shall be disconnected. The connection for equalising the electrostatic potential of the discharging pressure vessel and the receiving pressure vessel shall not be disconnected until hoses/loading arms are disconnected and stowed.

5.2.3.6 Anti-drive-away interlocks shall stay engaged until the rail tanker(s) can be safely moved.

5.2.3.7 The correct quantity of LPG loaded (as per dataplate of the pressure vessel, see RID, 4.3.3.2.5 [4]) shall be verified. Before leaving the site, verification that the road tanker displays the appropriate hazard warning shall be ensured.

5.2.4 Precautions against overfilling

5.2.4.1 Gauging devices shall be monitored continuously during the filling operation, to ensure that the rail tanker is not overfilled.

5.2.4.2 If a rail tanker is accidentally overfilled, the excess LPG shall be removed in a controlled manner without delay, before departure of the rail tanker.

5.2.4.3 When filling by weight, the tare of the vehicle shall be determined i.e. by weighing before every filling operation to ensure that the vehicle is not overfilled.

5.3 Discharge

5.3.1 Preparation for discharge

5.3.1.1 The discharging rail tanker shall be moved to the discharge area and positioned in accordance with the site procedures.

5.3.1.2 Any device provided to check the discharged quantity shall be operational.

5.3.1.3 Parking brakes and railway wheel chock or other equivalent means shall be applied to prevent unintended movement of any rail tanker involved during discharge. The site, where the rail tankers are parked for discharging, shall be isolated from other rail traffic. If fitted, anti-drive-away interlocks shall be engaged.

5.3.1.4 The electrostatic potential of the rail tanker and the receiving pressure vessel shall then be equalised before the LPG hoses or loading arms are connected.

5.3.1.5 All rail tanker valves shall be checked to ensure that they are in the closed position.

5.3.1.6 Blanking caps or blind flanges shall be removed from the liquid and vapour connections to be used.

5.3.1.7 It shall be checked that the site is safe for discharging LPG and adequate storage capacity is available. Specific requirements for this shall be part of the site procedures.

5.3.1.8 Hoses and loading arms shall be checked for kinks, wear or obvious damage. If they show wear or damage, they shall not be used in discharge operations until rectified. 38-4d19-b4a5-

5.3.1.9 Fill-couplings, seals and necessary attachments shall be examined to ensure compatibility and that no dirt or any other foreign matter is present before connection.

5.3.1.10 Connections shall be properly made before starting to discharge. Hoses/loading arms shall not be fully extended in making the connections. A check shall be made for any sign of leakage before discharging commences. Any leakage shall be rectified before proceeding.

5.3.1.11 If any rail tanker involved in the discharge is equipped with foot valve(s) an emergency ripcord shall be connected to the rail hook that will shut down the foot valve in the event of unintended movement of that tanker.

5.3.2 Discharge operations

The transfer couplings (hoses or loading arms) shall be connected without submitting them to any abnormal stresses. The rail tanker, product terminal and vapour return valves, where applicable, shall be opened in the required sequence and manner in accordance with the site procedures. The connections between the transfer couplings and the rail tanker shall be checked for leakage. Further periodic leakage checks shall be carried out directly after the product transfer operation has begun. In case any leakage is detected, the discharge operations shall be stopped immediately in order to make the transfer couplings gas-tight.

It can be necessary to reduce the transfer rates in order to ensure that the maximum fill is not exceeded.