

ISO/TC 282/SC 3

Secretariat: JISC

Voting begins on:
2020-03-03

Voting terminates on:
2020-04-28

Guidelines for performance evaluation of treatment technologies for water reuse systems —

Part 3: Ozone treatment technology

PREVIEW
iTeh STANDARD
(standards.itih.ai)
Full standard:
<https://standards.itih.ai/catalog/standards/sist/a619096-e006-4098-907a-71f560ea72c1/iso-20468-3-2020>

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.



Reference number
ISO/FDIS 20468-3:2020(E)

© ISO 2020

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/a7619096-e006-4098-907a-71f560ea72c1/iso-20468-3-2020>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms, definitions and abbreviated terms	1
3.1 Terms and definitions	1
3.2 Abbreviated terms	2
4 System configuration	2
4.1 General	2
4.2 Ozone system for water treatment	3
4.2.1 Feed gas supply unit	3
4.2.2 Ozone generation unit	3
4.2.3 Ozone contact unit	3
4.2.4 Off-gas ozone treatment unit	3
4.2.5 Ozone measuring system	4
5 Principles and general guidelines for performance evaluation	4
5.1 General	4
5.2 Functional requirements	4
5.2.1 General	4
5.2.2 Performance evaluation procedures	5
5.3 Non-functional requirements	7
5.3.1 Performance characteristics	7
5.3.2 Environmental and economic key factors	7
5.3.3 Safety requirements	8
Annex A (informative) Main treatment technologies and target constituents for water reuse	9
Annex B (informative) Reuse water quality parameters	10
Annex C (informative) Ozone concentration monitoring points	23
Annex D (informative) Ozone generation control methods	25
Bibliography	26

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 282, *Water reuse*, Subcommittee SC 3, *Risk and performance evaluation of water reuse system*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

The rapidly growing global market for water reuse technologies inevitably demands standards which are applicable on a world-wide basis. Many regions in the world are facing water shortages, and there is great interest in the use of technologies that can treat wastewater and make the reuse water available for a wide range of reuse applications that can satisfy non-potable water demands, thereby conserving precious potable water supplies. Simultaneously, the implementation of water reuse schemes is raising public and regulatory concerns regarding potential human health, environmental and societal impacts. This has led to an increasing need to specify various aspects of water reuse projects and there is a growing need on behalf of regulators, reuse technology suppliers, and users of those technologies for international standardization. Without ISO water reuse standards, a great number of opportunities for sustainable development based on water reuse will be lost.

Standardization needs to include objective specification and evaluation of levels of service and water reuse system performance dependability, including safety, environmental protection, and resilience and cost-effectiveness considerations. Hence, appropriate methods are needed to evaluate the performance of water reuse systems.

The performance of treatment technologies for water reuse, inter alia, should be evaluated properly in order to select the most appropriate technologies in an unbiased way to achieve the objectives of the water reuse project. Despite considerable research and development on treatment technologies, such scientific knowledge is largely held within commercial interests. Given less than ideal communication between producers and users of reuse technologies with regards to treatment performance, clear information as to what to measure on the one hand and what level of performance is required on the other is currently missing. To address these challenges, this document provides methods and tools, which can be accepted by most stakeholders, to evaluate the performance of treatment technologies for water reuse systems from multitude of applications.

Based on the discussion in the meetings of ISO/TC 282/SC 3, ISO 20468-1 titled “Guidelines for performance evaluation of treatment technologies for water reuse systems — Part 1: General” has been developed to establish the standard of generic aspects for performance evaluation. In this context, this document stipulating specific ways of performance evaluation of ozone treatment technology, commonly known as ozonation, for water reuse systems, based on ISO 20468-1 as the generic standard, is established herein.

Ozone (O_3) is an allotrope of oxygen (O_2) and is the second strongest oxidiser after fluorine. Its strong oxidative decomposition power makes it effective as a disinfectant and in removal of oxidizable constituents in water. There are cases where ozonation at high doses is used to remove micro-pollutants in wastewater for environmental protection.

In various types of water reuse systems, the disinfection and the removal of colour and odour are essential. Then it can be said that ozone technology plays an important role to improve these water qualities for the purpose of water reuse, working well with secondary or tertiary treated water as shown in Figure 1 of ISO 20468-1:2018 and in [Annex A](#).

In this guideline, the dedicated features to ozone technology for water reuse are instructed and the requirements for proper and accurate evaluation of ozone system for water reuse are offered.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standards/sist/a7619096-e006-4098-907a-71f560ea72c1/iso-20468-3-2020>

Guidelines for performance evaluation of treatment technologies for water reuse systems —

Part 3: Ozone treatment technology

1 Scope

This document specifies performance evaluation methods of treatment technology using ozone for water reuse systems. It deals with how to measure typical parameters which indicate performance of ozone treatment technology.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 20670, *Water reuse — Vocabulary*

3 Terms, definitions and abbreviated terms

For the purposes of this document, the following terms and definitions given in ISO 20670 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1 Terms and definitions

3.1.1

ambient ozone concentration

concentration of ozone existing in the air or surrounding the ozone treatment apparatus

3.1.2

exhaust residual ozone concentration

ozone concentration at the outlet of an off-gas ozone treatment unit

3.1.3

generated ozone amount

quantity of ozone generated in a unit time

3.1.4

generated ozone concentration

ozone concentration in the gas phase at the outlet of an ozone generator

3.1.5

off-gas ozone concentration

ozone concentration at the outlet of an ozone contactor

3.1.6

ozone concentration

volume, mass or mole of ozone in a unit volume or mass of gas or liquid

3.1.7

ozone concentration monitor

instrument capable of measuring ozone concentration in samples continuously

3.1.8

ozone demand

amount of ozone consumed to oxidize material in water

3.1.9

ozone dose

mass of ozone injected into a unit volume of water

Note 1 to entry: Ozone dose is expressed in units of mass-per-volume concentration (g/m^3 or mg/l).

3.1.10

residual ozone concentration

dissolved ozone concentration measured after a given contact time

Note 1 to entry: It is expressed in mg/l .

3.1.11

transferred ozone dose

mass of ozone applied into a unit volume of water

Note 1 to entry: Transferred ozone dose is expressed in units of mass-per-volume concentration (g/m^3 or mg/l).

3.2 Abbreviated terms

CT product of residual concentration and time

EPDM ethylene propylene diene monomer

FRP fiber-reinforced plastic

GHG greenhouse gases

LOX liquid oxygen

LRVs log-reduction values

PTFE polytetrafluoroethylene

4 System configuration

4.1 General

The ozone system for water treatment consists of:

- a feed gas supply unit
- an ozone generation unit
- an ozone contact unit
- an off-gas ozone treatment unit

Depending on the water treatment efficiency and performance to be achieved, pre-treatment and/or post-treatment can be added to the ozone system. For example, sand filtration as the typical pre-treatment process to remove suspended impurities including ozone scavengers and inorganic matter enhances treated water quality and reduces ineffective ozone consumption. On the other hand, post-treatment such as biological activated carbon process removes residual particles and dissolved matter which are not decomposed and/or are generated as by-products during ozonation. In order to retain bactericidal effects after ozonation, post disinfection such as chlorine disinfection can be added.

4.2 Ozone system for water treatment

4.2.1 Feed gas supply unit

The feed gas supply unit is using either air or oxygen gas to the ozone generation unit. An air-fed ozone system uses compressed air directly from the atmosphere. An oxygen-fed ozone system uses LOX or concentrated oxygen fed by an oxygen concentrator. Typically, the oxygen concentrator increases oxygen concentration by absorbing nitrogen selectively from air.

4.2.2 Ozone generation unit

The ozone generation unit typically consists of:

- ozone generator(s)
- a power supply
- a cooling system

Corona discharge is currently the most common ozone generation method.

4.2.3 Ozone contact unit

The ozone contact unit typically consists of:

- an ozone dissolution system
- ozone contactor(s)

The ozone contactor is a vessel where ozone is dissolved in water and reacts with target substance(s), followed by the ozone dissolution system which dissolves ozone gas in water. Mass transfer of ozone is a critical aspect of water ozonation. Dissolution devices include bubble diffusion, down flow tube injection, venturi injection, radial diffuser, static mixers and mechanical agitation. These applicable dissolution devices should be selected depending on the space limitation for system installation, electric power charge and so on. The method of ozone gas dissolution used also depends on system design and method of ozone generation used.

4.2.4 Off-gas ozone treatment unit

Since ozone is a very strong oxidant, any unreacted ozone in the off-gas can be harmful to the environment and endanger human health. Consequently, it shall be converted to oxygen and neutralized before the off-gas is released to atmosphere.

The off-gas ozone treatment unit typically consists of an off-gas ozone destruction unit and an off-gas ozone suction unit. The off-gas ozone suction unit withdraws off-gas ozone from the ozone contactor and draws it into the off-gas ozone destruction unit. The off-gas ozone destruction unit converts ozone residual exhausted from the ozone contactor to oxygen by using such methods as activated carbon, catalyst media and heat, or combination of heat and catalyst media.

4.2.5 Ozone measuring system

Various types of ozone monitors are available for measuring ozone concentrations. The typical configuration of ozone treatment system as well as the monitoring points of ozone concentration are shown in [Figure 1](#).




Figure 1 — Typical configuration of ozonation system and ozone concentration monitoring points

The high concentration ozone monitor, residual ozone concentration monitor and off-gas ozone concentration monitor are installed to measure ozone concentration at key locations in the ozonation system for the purpose of controlling ozone generation and dose. Specific descriptions about ozone generation control methods are shown in [Annex D](#).

The exhaust and ambient ozone monitors measure ozone concentrations to verify safe operating conditions. The control system works automatically for system shutdown or stopping ozone production if needed.

5 Principles and general guidelines for performance evaluation

5.1 General

Based on the principles and general guidelines for performance verification described in ISO 20468-1:2018^[1], this document also specifies two kinds of performance requirements:

- functional requirements
- non-functional requirements

5.2 Functional requirements

5.2.1 General

Functional requirements consist of two parts; water quality based performance and process-based performance, both of which strongly influence the conformity of produced water quality to water reuse regulations and related standards.

Water quality based performance for ozone treatment includes the potential reduction of disease causing microorganisms that can be present and the removal of specific constituents such as colour and odour ([Annex A](#)). They are generally expressed as a logarithmic-scale reduction and a residual constituent concentration in the treated reuse water, respectively. On the other hand, ultra-violet absorbance and ultra-violet transmission can be used as surrogate indicators to check the removal efficacy of dissolved organic carbon. These water quality parameters and indicators should be in accordance with the water reuse regulations and standards stipulated in respective countries (examples in [Annex B](#)).

The reduction in, or residual concentration of, *Escherichia coli*, enterococci bacteria, thermo-tolerant coliform bacteria and total coliform bacteria can be used as potential indicators of microorganisms to assess the effectiveness of ozone disinfection in reducing pathogenic microorganisms that can be present in the source water. Quantification of these microbial indicators can be carried out by using analysis methods stipulated in ISO 6222:1999[2].

The reduction of concentration in pharmaceutical and personal care products and other contaminants of emerging concern, as well as colour and odour, can also be functional requirements for some reuse applications. Colour and odour can be quantified by the methods stipulated in Standard Methods for the Examination of Water and Wastewater[3]. The analytical methods and water quality parameters should be required by the regulations in respective countries.

The CT approach could be used for wastewater ozonation but is much less relevant than in drinking water. It is noted that a sufficient ozone dose to achieve the targeted water quality should be transferred to the effluent resulting in detection of residual ozone concentration.

Ideally, supplied ozone should be used completely in the reactor. However, if the off-gas ozone concentration indicates zero, it is practically impossible to correctly estimate transferred ozone dose. Therefore, the concentration of off-gas ozone before the destruction should be as low as possible by providing just enough amount of ozone for treatment.

On the other hand, process-based performance for ozone treatment is concerned with the functional performance of main units of ozone treatment system such as ozone generators and contactors and is assessed by monitoring the ozone concentration in different points ([Annex C](#) and [D](#)). The dependability of these units is also important as a part of process-based performance since failure in ozone generators and/or contactors can lead to releasing insufficient transferred ozone into water.

Failure in off-gas ozone treatment units can raise an issue of undestroyed ozone gas leaking to rooms, with the possibility of personnel injury and/or property damage in the worst-case situation. Then the dependability of off-gas ozone treatment units should be included into non-functional requirements.

5.2.2 Performance evaluation procedures

5.2.2.1 STEP1 — Setting performance criteria and objectives

An ozone treatment system is expected to improve water quality parameters such as *E. coli*, thermo-tolerant coliforms, colour and odour. The water quality standards for these parameters as water-quality based performance criteria should be set for the purpose of water reuse.

Those reuse water quality parameters are standardized in some countries for landscape, amenity and other purposes, as illustrated in [Annex B](#).

The values of the reclaimed water quality parameters should be some of the values that presented in Annex A of ISO 20761:2018[4].

In addition, to ensure the functionality and reliability of water reclamation processes for pathogen control in the case of high risk of exposure, the health risk management strategy can also include targets for log-reduction values (LRVs). Other water quality parameters can be relevant for specific non-potable water applications, such as those described in ISO 16075-1, ISO 16075-2, ISO 16075-3:2015, ISO 16075-4:2016[5] for irrigation. Further information on the risk assessment and management approach can be found in ISO 20426:2018[6], ISO 20761:2018 and in Australian Guidelines for Water Recycling[7].