



**SLOVENSKI STANDARD**  
**SIST EN IEC 60730-2-14:2019/oprA1:2021**  
**01-december-2021**

---

**Avtomatske električne krmilne naprave - 2-14. del: Posebne zahteve za električna prožila**

Automatic electrical controls - Part 2-14: Particular requirements for electric actuators

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

**Ta slovenski standard je istoveten z: EN IEC 60730-2-14:2019/prA1**

[SIST EN IEC 60730-2-14:2019/oprA1:2021](https://standards.iteh.ai/catalog/standards/sist/f4263277-3429-4b1a-b252-3c41d2cd1154/sist-en-iec-60730-2-14-2019-opra1-2021)

<https://standards.iteh.ai/catalog/standards/sist/f4263277-3429-4b1a-b252-3c41d2cd1154/sist-en-iec-60730-2-14-2019-opra1-2021>

**ICS:**

29.120.01	Električna dodatna oprema na splošno	Electrical accessories in general
97.120	Avtomatske krmilne naprave za dom	Automatic controls for household use

**SIST EN IEC 60730-2-14:2019/oprA1:2021**

**en**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN IEC 60730-2-14:2019/oprA1:2021](https://standards.iteh.ai/catalog/standards/sist/f4263277-3429-4b1a-b252-3c41d2cd1154/sist-en-iec-60730-2-14-2019-opra1-2021)  
<https://standards.iteh.ai/catalog/standards/sist/f4263277-3429-4b1a-b252-3c41d2cd1154/sist-en-iec-60730-2-14-2019-opra1-2021>

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**DRAFT**  
**EN IEC 60730-2-14:2019**

**prA1**

October 2021

ICS 29.120.01; 97.120

English Version

**Automatic electrical controls - Part 2-14: Particular requirements  
for electric actuators  
(IEC 60730-2-14:2017/A1:2019)**

Dispositifs de commande électrique automatiques -  
Partie 2-14: Exigences particulières pour les actionneurs  
électriques  
(IEC 60730-2-14:2017/A1:2019)

Elektrische Geräte für den Hausgebrauch und ähnliche  
Zwecke - Prüfvorschrift für die Bestimmung der  
Luftschallemission - Teil 2-14: Besondere Anforderungen  
an Kühlgeräte, Tiefkühlgeräte und Gefriergeräte  
(IEC 60730-2-14:2017/A1:2019)

This draft amendment prA1, if approved, will modify the European Standard EN IEC 60730-2-14:2019; it is submitted to CENELEC members for enquiry.

Deadline for CENELEC: 2021-12-31.

The text of this draft consists of the text of IEC 60730-2-14:2017/A1:2019.

If this draft becomes an amendment, CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this amendment the status of a national standard without any alteration.

This draft amendment was established by CENELEC in three official versions (English, French, German).

A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

**EN IEC 60730-2-14:2019/prA1:2021 (E)****European foreword**

This document (EN IEC 60730-2-14:2019/prA1:2021) consists of the text of IEC 60730-2-14:2017/AMD1:2019 prepared by IEC/TC 72 "Automatic electrical controls".

This document is currently submitted to the Enquiry.

The following dates are proposed:

- latest date by which the existence of this document (doa) dor + 6 months  
has to be announced at national level
- latest date by which this document has to be (dop) dor + 12 months  
implemented at national level by publication of an  
identical national standard or by endorsement
- latest date by which the national standards (dow) dor + 36 months  
conflicting with this document have to be withdrawn (to be confirmed or  
modified when voting)

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN IEC 60730-2-14:2019/oprA1:2021](https://standards.iteh.ai/catalog/standards/sist/f4263277-3429-4b1a-b252-3c41d2cd1154/sist-en-iec-60730-2-14-2019-opra1-2021)  
<https://standards.iteh.ai/catalog/standards/sist/f4263277-3429-4b1a-b252-3c41d2cd1154/sist-en-iec-60730-2-14-2019-opra1-2021>



IEC 60730-2-14

Edition 2.0 2019-03

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

AMENDMENT 1  
AMENDEMENT 1

**Automatic electrical controls –**  
**Part 2-14: Particular requirements for electric actuators**  
(standards.iteh.ai)

**Dispositifs de commande électrique automatiques –**  
**Partie 2-14: Exigences particulières pour les actionneurs électriques**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

ICS 29.120.01; 97.120

ISBN 978-2-8322-6561-1

**Warning! Make sure that you obtained this publication from an authorized distributor.**  
**Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## FOREWORD

This amendment has been prepared by IEC technical committee 72: Automatic electrical controls.

The text of this amendment is based on the following documents:

FDIS	Report on voting
72/1168FDIS	72/1175/RVD

Full information on the voting for the approval of this amendment can be found in the report on voting indicated in the above table.

The committee has decided that the contents of this amendment and the base publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN IEC 60730-2-14:2019/oprA1:2021](https://standards.iteh.ai/catalog/standards/sist/f4263277-3429-4b1a-b252-3c41d2cd1154/sist-en-iec-60730-2-14-2019-oprA1-2021)  
<https://standards.iteh.ai/catalog/standards/sist/f4263277-3429-4b1a-b252-3c41d2cd1154/sist-en-iec-60730-2-14-2019-oprA1-2021>

## FOREWORD

*Replace the paragraph reading "This Part 2-14 is intended...", with the following:*

This part 2-14 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the fifth edition of that standard (2013) including its amendment 1 (2015). Consideration may be given to future editions of, or amendments to, IEC 60730-1.

**1 Scope and normative references****1.1** *Add the following new text:*

This part 2-14 applies to **electric actuators** powered by primary or secondary batteries, requirements for which are contained within the standard, including Annex V.

*Add the following new subclauses:*

**1.1.5** Void.

**1.1.6** Void.

**1.1.7** *Replacement:*

IEC 60730-2-14:2017/AMD1:2019  
© IEC 2019

– 3 –

This part 2-14 applies also to **electric actuators** incorporating **electronic devices**, requirements for which are contained in Annex H.

#### 1.1.8 Replacement:

This part 2-14 applies also to **electric actuators** using NTC or PTC **thermistors**, requirements for which are contained in Annex J.

#### 1.1.9 Replacement:

This part 2-14 applies to the electrical and **functional safety** of **electric actuators** capable of receiving and responding to communications signals, including signals for power billing rate and demand response.

The signals may be transmitted to or received from external units being part of the **electric actuator** (wired), or to and from external units, which are not part of the **electric actuator** (wireless) under test.

#### 1.1.10 Replacement:

This part 2-14 does not address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the control system.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

## 2 Terms and definitions

Add the following new definition: [SIST EN IEC 60730-2-14:2019/oprA1:2021](https://standards.iteh.ai/catalog/standards/sist/f4263277-3429-4b1a-b252-3c41d2cd1154/sist-en-iec-60730-2-14-2019-opra1-2021)  
<https://standards.iteh.ai/catalog/standards/sist/f4263277-3429-4b1a-b252-3c41d2cd1154/sist-en-iec-60730-2-14-2019-opra1-2021>

### 2.3.106

#### **maximum rated mechanical load**

maximum mechanical resistance to the active movement of an actuator under normal operating conditions

Note 1 to entry: See also 6.4.102.1 and 6.4.102.2.

## 6 Classification

### 6.4.102.1 Rotary movement

Add the following new note:

NOTE **Maximum rated mechanical load** for rotary movement actuators can be declared in terms of rated torque (for the complete **angular rotation**) or, alternatively, in terms of maximum torque, running torque and percentage of the angular rotation in which the maximum torque occurs. The value of the percentage of the angular rotation in which the maximum torque occurs is independent from any specific position within the travel of the actuator; maximum torque can be reached at any position within the actuator travel (e.g. at start position, at end position, at each end, in the middle, etc.).

### 6.4.102.2 Linear movement

Add the following new note:

NOTE **Maximum rated mechanical load** for linear movement actuators can be declared in terms of rated force (for the complete **stroke**) or, alternatively, in terms of maximum force, running force and percentage of the stroke in which the maximum force occurs. The value of the percentage of the stroke in which the maximum force occurs is

independent from any specific position within the travel of the actuator; maximum force can be reached at any position within the actuator travel (e.g. at start position, at end position, at each end, in the middle, etc.).

## 7 Information

**Table 1 – (7.2 of edition 3) – Required information and methods of providing information**

Replace, in item 27, "automatic action<sup>102</sup>" with "automatic action<sup>bb</sup>".

Replace, in item 34, "operating time<sup>101, 103</sup>" with "operating time<sup>aa</sup>".

Add, in item 34, under "Method", footnote "cc" after "C", to read "C<sup>cc</sup>".

Replace the row for item 105 with the following:

105 <b>maximum rated mechanical load<sup>dd</sup></b>	2.3.106, 6.4.102.1, 6.4.102.2, 14.4, 15.5.102, 17.4.101	D
---	--	---

Replace the row "Additional notes" with the following:

<p><i>Additional footnotes:</i></p> <p><sup>aa</sup> This may be given as a maximum percentage of ON time of the power supply to avoid over-heating of the windings in a declared period of time.</p> <p><sup>bb</sup> <b>Electric actuators</b> are subjected to a minimum of 6 000 cycles.</p> <p><sup>cc</sup> For integrated and incorporated <b>electric actuators</b>, the method is D<sub>7-3429-4b1a-b252-2-41-2-41-151</sub>.</p> <p><sup>dd</sup> For test purposes, representative physical load may be defined by agreement between the manufacturer and testing authority (e.g. dedicated test device).</p>
--

### 17.4 Manual and mechanical conditions for the tests

Add, after 17.4.4, the following new text:

*Additional subclause:*

**17.4.101** The **electric actuator** shall be loaded with the **maximum rated mechanical load** (item 105 of Table 1).

## 25 Normal operation

Replace the existing text with the following:

This clause of Part 1 is applicable except as follows:

**25.2** *Not applicable.*



## 27 Abnormal operation

Delete subclause 27.3.

## Annex H – Requirements for electronic controls

### H.26.5 Voltage dips and voltage interruptions and voltage variations in the power supply network

#### H.26.5.1.2.101 Compliance

Renumber subclause H.26.5.1.2.101 as H.26.5.1.101.

In the first paragraph, replace the reference to “H.26.5.2” with “H.26.5.1.2”.

Replace the second paragraph with the following:

During the tests according to H.26.5.1.2 of an interruption of one cycle and of an interruption of one half-cycle of the supply waveform, the **control** shall continue to operate after restoration of the supply voltage from the position the **electric actuator** was in right before the interruption.

#### H.26.5.2.2 Test procedure

Add, after H.26.5.2.2, the following new text:

Additional subclause: [SIST EN IEC 60730-2-14:2019/oprA1:2021](https://standards.iteh.ai/catalog/standards/sist/f4263277-3429-4b1a-b252-3c41d2cd1154/sist-en-iec-60730-2-14-2019-oprA1-2021)  
<https://standards.iteh.ai/catalog/standards/sist/f4263277-3429-4b1a-b252-3c41d2cd1154/sist-en-iec-60730-2-14-2019-oprA1-2021>

#### H.26.5.2.101 Compliance

After the test according to H.26.5.2.2 of voltage test level 0 %  $V_R$ , the **electric actuator** shall provide normal operation.

During the tests according to H.26.5.2.2 of voltage test level 40 %  $V_R$ , the **control** shall continue to operate after restoration of the supply voltage from the position the **electric actuator** was in immediately before the interruption.

### H.26.8 Surge immunity test

#### H.26.8.101 Compliance

Replace, in the first paragraph, “H.26.9.3” with “H.26.8.3”.

### H.26.9 Electrical fast transient/ burst immunity test

Renumber subclause H.26.9.3.101 as H.26.9.101.

### H.26.13 Test of influence of supply frequency variations

#### H.26.13.3 Test procedure

Replace the reference to “Table H.19” with “Table H.22”.

#### H.26.13.101 Compliance

In the first paragraph, replace “H.26.12.3.2” with “H.26.13.3”.

**H.26.14 Power frequency magnetic field immunity test**

*In the second paragraph, replace "H.26.14.3.101" with "H.26.14.101" and "H.26.14.2" with "H.26.14.3".*

*Renumber subclause H.26.14.3.101 as H.26.14.101.*

**Annex AA – Regional differences****United States****7 Information****Table 1 – (7.2 of edition 3) – Required information and methods of providing information**

*Replace the existing text with the following:*

*Add, in items 101 and 102, under "Method", footnote "ee" after "D" to read "D<sup>ee</sup>".*

*Add the following new footnote:*

<sup>ee</sup> For independently mounted actuators, the method is C.