
Svetloba in razsvetljava - Merjenje in podajanje fotometrijskih podatkov svetlobnih virov in svetilk - 3. del: Podajanje podatkov za zasilno razsvetljavo delovnega mesta

Measurement and presentation of photometric data of lamps and luminaries - Part 3: Presentation of data for emergency lighting of work places

Licht und Beleuchtung - Messung und Darstellung photometrischer Daten von Lampen und Leuchten - Teil 3: Darstellung von Daten für die Notbeleuchtung von Arbeitsstätten
(standards.iteh.ai)

Lumière et éclairage - Mesurage et présentation des données photométriques des lampes et des luminaires - Partie 3 : Présentation des données pour l'éclairage de sécurité des lieux de travail
f871dde6b26d/sist-en-13032-3-2008

Ta slovenski standard je istoveten z: EN 13032-3:2007

ICS:

17.180.20	Barve in merjenje svetlobe	Colours and measurement of light
91.160.10	Notranja razsvetljava	Interior lighting

SIST EN 13032-3:2008**en,fr,de**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 13032-3:2008

<https://standards.iteh.ai/catalog/standards/sist/a4f71fc7-0810-43b2-ad67-f871dde6b26d/sist-en-13032-3-2008>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 13032-3

October 2007

ICS 17.180.20; 91.160.10

English Version

Measurement and presentation of photometric data of lamps and luminaires - Part 3: Presentation of data for emergency lighting of work places

Lumière et éclairage - Mesure et présentation des données
photométriques des lampes et des luminaires - Partie 3:
Présentation des données pour l'éclairage de sécurité des
lieux de travail

Licht und Beleuchtung - Messung und Darstellung
photometrischer Daten von Lampen und Leuchten - Teil 3:
Darstellung von Daten für die Notbeleuchtung von
Arbeitsstätten

This European Standard was approved by CEN on 26 August 2007.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

Page

Foreword	3
Introduction	4
1 Scope.....	5
2 Normative references	5
3 Terms and definitions.....	5
4 Essential lamp data.....	6
5 Luminaire data.....	7
5.1 Essential luminaire data	7
5.1.1 Luminaire code.....	7
5.1.2 Normalized intensity table.....	7
5.1.3 Luminaire maintenance factors (<i>LMF</i>)	8
5.1.4 Luminaire service correction factors (<i>LSCF</i>)- all data shall be declared.....	8
5.2 Useful luminaire data.....	8
5.2.1 Physical dimensions of the luminaire.....	8
5.2.2 Intensity diagram	8
5.2.3 Spacing tables.....	8
Annex A (informative) Illuminance calculation on a horizontal plane from a point source.....	9
Bibliography	10

SIST EN 13032-3:2008

<https://standards.iteh.ai/catalog/standards/sist/a4f71fc7-0810-43b2-ad67-f871dde6b26d/sist-en-13032-3-2008>

Foreword

This document (EN 13032-3:2007) has been prepared by Technical Committee CEN/TC 169 "Light and lighting", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2008, and conflicting national standards shall be withdrawn at the latest by April 2008.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 13032-3:2008

<https://standards.iteh.ai/catalog/standards/sist/a4f71fc7-0810-43b2-ad67-f871dde6b26d/sist-en-13032-3-2008>

EN 13032-3:2007 (E)

Introduction

This standard is to be used in conjunction with EN 13032-1. Emergency lighting is required by National Regulations in a number of European countries. This standard specifies the required data for emergency lighting as required by EN 1838.

For the application of this document the terms according to IEC 60050 also applies.

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 13032-3:2008

<https://standards.iteh.ai/catalog/standards/sist/a4f71fc7-0810-43b2-ad67-f871dde6b26d/sist-en-13032-3-2008>

1 Scope

This standard specifies the required data for lamps and luminaires to verify conformity with EN 1838. This standard does not define the data requirements for signage, as these can be found in EN 1838.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13032-1, *Light and lighting - Measurement and presentation of photometric data of lamps and luminaires - Part 1: Measurement and file format*

3 Terms and definitions

For the purposes of this European Standard, the following terms and definitions apply.

NOTE This clause defines terms and quantities that are in use and important to this standard, and which may not be given in IEC 60050.

3.1

correction factor

factor to modify the luminaire data as presented on a particular photometric data sheet to those of similar luminaires (for example: Ballast Lumen Factor, length, lumen corrections)

3.2

essential data

lamp and luminaire data required for the verification of conformity to the requirements of EN 1838

3.3

lamp code

any combination of letters and numbers by which the lamp type is identified

3.4

lamp dimensions

all dimensions of the lamp that are relevant for the luminaire

3.5

luminaire code

any combination of letters and numbers by which the luminaire type is identified

3.6

nominal lamp wattage (W_{lamp})

approximate wattage used to designate or identify the lamp

NOTE The nominal lamp wattage is also (incorrectly) known as rated lamp wattage.

3.7

useful data

lamp and luminaire data beneficial to the designers and users in the planning and operation of lighting installations

EN 13032-3:2007 (E)**3.8****emergency ballast lumen factor (EBLF)**

ratio of the luminous flux of the lamp supplied by the emergency ballast to the luminous flux of the same lamp operated with the appropriate reference ballast at its rated voltage and frequency. The emergency ballast lumen factor is the minimum of the values measured at the appropriate time after failure of the normal supply and continuously to the end of the rated time

$$\text{EBLF} = \text{BLF} \times F_{\text{TIME}} \quad (1)$$

3.9 **F_{TIME}**

minimum light output values measured during the emergency operating time period

3.10**practical emergency lamp flux (PELF)**

lowest luminous flux of the lamp observed during the rated duration of the emergency mode

$$\text{PELF} = \text{LDL} \times \text{EBLF} \quad (2)$$

where

LDL is the initial lighting design lumens at 100 h as declared by the manufacturer

4 Essential lamp data

The following lamp data shall be provided for verification:

a) lamp code;

b) lamp dimensions;

c) luminous flux (*LDL*);

d) lamp lumen maintenance factor (*LLMF*);

NOTE 1 The lamp lumen maintenance factor may be presented both as a graph or data in a table. However, to allow the designer to set up an optimal maintenance scheme, it is recommended to present these data in tabular form.

e) lamp survival factor (*LSF*);

NOTE 2 The lamp survival factor may be presented as a graph or as data in a table. However, to allow the designer to set up an optimal maintenance scheme, it is recommended to present these data in tabular form.

f) general colour rendering index (R_a);

g) nominal lamp wattage (W_{lamp}).

5 Luminaire data

5.1 Essential luminaire data

5.1.1 Luminaire code

5.1.2 Normalized intensity table

The tabulated luminous intensity values normalized to a total bare lamp flux in the luminaire of 1 000 lm shall be given in cd.klm^{-1} . The light intensity shall be declared for an ambient temperature of 25 °C and nominal voltage of the emergency ballast and measured in accordance with EN 13032-1. It shall take into account the thermal behaviour of the lamp in the luminaire due to the temperature generated by all the components inside the luminaire. An appropriate thermal correction factor shall be applied if the luminous intensity has been measured in other conditions e.g. with another ballast.

These values ($\text{cd}/1\ 000\ \text{lm}$) permit calculation of the Light Output Ratio (*LOR*) of the luminaire.

For luminaires with multiples lamps where light intensity distribution of the luminaire can be different when not all lamps are operated in the emergency mode, the distribution for emergency mode shall be reported.

The number of C-planes and γ angles at which the *I*-values shall be specified, is given in Table 1 and Table 2.

Table 1 — Number of C-planes for various intensity distributions

Luminous intensity distribution	C-planes	Escape routes only
Radially symmetric	One C-plane	0 ° and 90 °
Symmetric about two planes	Every 15 ° from 0 ° to 90 °	0 ° and 90 °
Symmetric about one plane	Every 15 ° from 0 ° to 180 ° or every 15 ° from 90 ° to 270 °	0 ° and 90 °
Asymmetric	Every 15 ° from 0 ° to 360 °	0 ° and 90 °

Table 2 — Number of γ angles for various types of luminaires

Type of luminaire	Downward Flux Fraction (<i>DFF</i>)	γ angles
Downlighting	> 0,9	Every 5 ° from 0 ° to 90 °
Downlighting with upward component	0,1 to 0,9	Every 5 ° from 0 ° to 180 °
Uplighting	< 0,1	Every 5 ° from 90 ° to 180 °

For floodlights used in indoor and/or outdoor lighting installations, the measurement and presentation of the normalised *I*-table may be in *B- β* instead of *C- γ* notation.

NOTE Luminaires with a concentrated intensity distribution may require more angles at which the luminous intensity data are presented (e.g. every 1 ° in the area where 90 % of the luminous flux is emitted).