

# SLOVENSKI STANDARD

## SIST EN 13828:2025

01-maj-2025

---

**Ventili v stavbah - Ročni krogelni ventili iz bakrene zlitine in krogelni ventili iz nerjavnega jekla za oskrbo s pitno vodo v stavbah - Preskusi in zahteve**

Building valves - Manually operated copper alloy and stainless steel ball valves for potable water supply in buildings -Tests and requirements

Gebäudeflammaturen - Handbetätigtes Kugelhähne aus Kupferlegierungen und nicht rostenden Stählen für Trinkwasseranlagen in Gebäuden - Prüfungen und Anforderungen

Robinetterie de bâtiment - Robinets d'arrêt à tourne sphérique actionnés à la main en alliage de cuivre et en acier inoxydable pour la distribution d'eau potable dans les bâtiments - Essais et exigences

**Ta slovenski standard je istoveten z: EN 13828:2025**

<https://standards.iteh.ai/catalog/standards/sist/ae1712bb-a4c8-4e28-8cce-6aa1e6945b26/sist-en-13828-2025>

---

**ICS:**

23.060.20	Zapirni ventili (kroglasti in pipe)	Ball and plug valves
91.140.60	Sistemi za oskrbo z vodo	Water supply systems

**SIST EN 13828:2025**

**en,fr,de**



**EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM**

**EN 13828**

February 2025

ICS 23.060.20

Supersedes EN 13828:2003

English Version

**Building valves - Manually operated copper alloy and stainless steel ball valves for potable water supply in buildings - Tests and requirements**

Robinetterie de bâtiment - Robinets d'arrêt à tournant sphérique actionnés à la main en alliage de cuivre et en acier inoxydable pour la distribution d'eau potable dans les bâtiments - Essais et exigences

Gebäudefarmenturen - Handbetätigtes Kugelhähne aus Kupferlegierungen und nichtrostenden Stählen für Trinkwasseranlagen in Gebäuden - Prüfungen und Anforderungen

This European Standard was approved by CEN on 20 January 2025.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.

<https://standards.nen.ai/catalog/standards/sist/ae1712bb-a4c8-4e28-8cce-6aa1e6945b26/sist-en-13828-2025>



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

## Contents

	Page
<b>European foreword.....</b>	<b>4</b>
<b>Introduction .....</b>	<b>5</b>
<b>1 Scope.....</b>	<b>6</b>
<b>2 Normative references.....</b>	<b>6</b>
<b>3 Terms and definitions .....</b>	<b>7</b>
<b>4 Designation.....</b>	<b>7</b>
<b>5 Design characteristics .....</b>	<b>8</b>
<b>5.1 Materials.....</b>	<b>8</b>
<b>5.1.1 General.....</b>	<b>8</b>
<b>5.1.2 Body materials .....</b>	<b>8</b>
<b>5.1.3 Corrosion resistance.....</b>	<b>8</b>
<b>5.1.4 Anti corrosive layer of the ball.....</b>	<b>8</b>
<b>5.2 Connection ends .....</b>	<b>8</b>
<b>5.2.1 General.....</b>	<b>8</b>
<b>5.2.2 Special cases.....</b>	<b>11</b>
<b>5.3 Operation.....</b>	<b>11</b>
<b>5.3.1 Closing direction.....</b>	<b>11</b>
<b>5.3.2 Operating devices .....</b>	<b>11</b>
<b>5.3.3 Connection between valve and actuator.....</b>	<b>11</b>
<b>5.4 Stops.....</b>	<b>11</b>
<b>5.5 Flow way area.....</b>	<b>12</b>
<b>5.5.1 Full bore.....</b>	<b>12</b>
<b>5.5.2 Reduced bore.....</b>	<b>12</b>
<b>5.6 Test and/or drainage points (design and position) .....</b>	<b>12</b>
<b>6 Performance characteristics.....</b>	<b>13</b>
<b>6.1 Test sequence .....</b>	<b>13</b>
<b>6.2 General.....</b>	<b>14</b>
<b>6.3 Operating torque .....</b>	<b>14</b>
<b>6.3.1 Apparatus.....</b>	<b>14</b>
<b>6.3.2 Procedure.....</b>	<b>14</b>
<b>6.3.3 Requirements .....</b>	<b>14</b>
<b>6.4 Resistance against torque .....</b>	<b>14</b>
<b>6.4.1 Principle .....</b>	<b>14</b>
<b>6.4.2 Apparatus.....</b>	<b>15</b>
<b>6.4.3 Procedure.....</b>	<b>15</b>
<b>6.4.4 Requirements .....</b>	<b>16</b>
<b>6.5 Resistance against bending .....</b>	<b>16</b>
<b>6.5.1 Principle .....</b>	<b>16</b>
<b>6.5.2 Apparatus.....</b>	<b>16</b>
<b>6.5.3 Procedure.....</b>	<b>17</b>
<b>6.5.4 Requirements .....</b>	<b>18</b>
<b>6.6 Torque test of the captive rotating nuts/tail pieces.....</b>	<b>18</b>
<b>6.6.1 General.....</b>	<b>18</b>
<b>6.6.2 Procedure.....</b>	<b>18</b>

6.6.3	Requirement.....	18
6.7	Stop resistance.....	19
6.7.1	Principle.....	19
6.7.2	Apparatus .....	19
6.7.3	Procedure .....	19
6.7.4	Requirements.....	19
6.8	Leak-tightness.....	19
6.8.1	Principle.....	19
6.8.2	Apparatus .....	19
6.8.3	Procedure .....	19
6.8.4	Requirements.....	20
6.9	Hydraulic strength .....	20
6.9.1	Principle.....	20
6.9.2	Apparatus .....	20
6.9.3	Procedure .....	20
6.9.4	Requirement.....	20
6.10	Replenish of water stored in space between ball and body .....	20
6.10.1	Principle.....	20
6.10.2	Procedure .....	20
6.10.3	Requirements.....	21
6.11	Resistance against pressure jumps.....	21
6.11.1	Principle.....	21
6.11.2	Apparatus .....	21
6.11.3	Test samples.....	22
6.11.4	Procedure .....	22
6.11.5	Requirements.....	23
6.12	Angular seal .....	23
6.12.1	Principle.....	23
6.12.2	Apparatus .....	23
6.12.3	Procedure .....	23
6.12.4	Requirement.....	23
7	Acoustic characteristics .....	23
7.1	General .....	23
7.2	Principle.....	23
7.3	Procedure .....	24
7.4	Determination of acoustic group .....	24
8	Mechanical endurance characteristics .....	24
8.1	Resistance against 90 °C water .....	24
8.1.1	Principle.....	24
8.1.2	Test installation .....	24
8.1.3	Conditions .....	24
8.1.4	Procedure .....	25
8.1.5	Requirements.....	25
8.2	Mechanical endurance of the control device .....	25
8.2.1	Principle.....	25
8.2.2	Test installation .....	25
8.2.3	Conditions .....	26
8.2.4	Procedure .....	26
8.2.5	Requirements.....	26
9	Marking .....	26
	Bibliography .....	28

## EN 13828:2025 (E)

### European foreword

This document (EN 13828:2025) has been prepared by Technical Committee CEN/TC 164 "Water supply", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2025, and conflicting national standards shall be withdrawn at the latest by August 2025.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document will supersede EN 13828:2003.

EN 13828:2025 includes the following significant technical changes with respect to EN 13828:2003:

- Scope has been revised;
- Tables 1, 2 and 4 were revised;
- Clause 2 has been updated;
- end connections were extended;
- full bore and half bore sizes were adapted;
- design requirements updated;
- test methods updated;
- marking updated.

[SIST EN 13828:2025](#)

<https://standards.iteh.ai/catalog/standards/sist/ae1712bb-a4c8-4e28-8cce-6aa1e6945b26/sist-en-13828-2025>

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

## **Introduction**

With respect to potential adverse effects on the quality of water intended for human consumption, caused by the product covered by this document:

- This document provides no information as to whether the product may be used without restriction in any of the member states of the EU or EFTA;
- It should be noted that, while awaiting the adoption of the verifiable European criteria, existing national regulations concerning the use and/or the characteristics of this product remain in force.
- The requirements with regard to the drinking water quality are specified in national regulations.

# iTeh Standards (<https://standards.iteh.ai>) Document Preview

[SIST EN 13828:2025](#)

<https://standards.iteh.ai/catalog/standards/sist/ae1712bb-a4c8-4e28-8cce-6aa1e6945b26/sist-en-13828-2025>

## EN 13828:2025 (E)

### 1 Scope

This document applies primarily to copper alloy and stainless steel ball valves with dimensions DN 6 to DN 100, for installations in buildings for potable water supply up to PN16 and a maximum distribution temperature of 65 °C. Occasional excursions up to 90 °C are permitted for a period of 1 h maximum.

The ball valves are classified by their nominal pressure being either PN10 or PN16.

This document specifies:

- the requirements of the materials and the design of ball valves;
- the mechanical, hydraulic and acoustic requirements of ball valves;
- the test methods to verify the requirements of ball valves;
- the marking requirements of ball valves.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 248, *Sanitary tapware - General specification for electrodeposited coatings of Ni-Cr*

EN 1254-2, *Copper and copper alloys - Plumbing fittings - Part 2: Compression fittings for use with copper tubes*

EN 1254-3, *Copper and copper alloys - Plumbing fittings - Part 3: Compression fittings for use with plastics and multilayer pipes*

EN 1254-4, *Copper and copper alloys - Plumbing fittings - Part 4: Threaded fittings*

<https://standards.iteh.ai/catalog/standards/sist/ae1712bb-a4c8-4e28-8cce-6aa1e6945b26/sist-en-13828-2025>

EN 1254-6, *Copper and copper alloys - Plumbing fittings - Part 6: Push-fit fittings for use with metallic tubes, plastics and multilayer pipes*

EN 1254-7, *Copper and copper alloys - Plumbing fittings - Part 7: Press fittings for use with metallic tubes*

EN 1254-8, *Copper and copper alloys - Plumbing fittings - Part 8: Press fittings for use with plastics and multilayer pipes*

EN 1254-20, *Copper and copper alloys - Plumbing fittings - Part 20: Definitions, thread dimensions, test methods, reference data and supporting information*

EN ISO 3822-1, *Acoustics - Laboratory tests on noise emission from appliances and equipment used in water supply installations - Part 1: Method of measurement (ISO 3822-1)*

EN ISO 3822-3, *Acoustics - Laboratory tests on noise emission from appliances and equipment used in water supply installations - Part 3: Mounting and operating conditions for in-line valves and appliances (ISO 3822-3)*

EN ISO 5211, *Industrial valves - Part-turn actuator attachments (ISO 5211)*

EN ISO 6509-1, *Corrosion of metals and alloys - Determination of dezincification resistance of copper alloys with zinc — Part 1: Test method (ISO 6509-1)*

EN ISO 9227, *Corrosion tests in artificial atmospheres - Salt spray tests (ISO 9227)*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

#### 3.1

##### **ball valve**

valve in which a ball, operated manually or via an actuator, rotates around an axis perpendicular to at least one of the directions of flow; the ball has a hole where in open position the water will flow through, in a straight or angled line

Note 1 to entry: Ball valves have a normal operating position of either fully open or fully closed. Ball valves will be opened or closed by a single turn through 90°.

Note 2 to entry: The following types are covered:

- straight pattern ball valves;
- angle pattern ball valves;
- three way valves (1 inlet, 2 outlets).

#### 3.2

##### **nominal size**

##### **DN**

nominal size of the ball valves is related to the size of the connection ends

Note 1 to entry: See Table 1.

[SIST EN 13828:2025](#)

<https://standards.iteh.ai/catalog/standards/sist/ae1712bb-a4c8-4e28-8cce-6aa1e6945b26/sist-en-13828-2025>

Note 2 to entry: For valves provided with connection ends in different sizes, the nominal size (DN) of the smallest connection end is leading and determines the minimum bore of the ball (Table 2 and Table 3).

### 4 Designation

The designation of a ball valve comprises:

- Design of the body (straight, angled or three way);
- type and material;
- nominal size (DN);
- bore (full or reduced);
- nominal pressure (PN);
- end connections;
- acoustic group (if applicable);
- number of this document, i.e. EN 13828.

EXAMPLE Straight pattern ball valve (S) of copper alloy, DN 25, PN 16, with threads Rp 1 on both sides, acoustic group 1, according to EN 13828.

# EN 13828:2025 (E)

## 5 Design characteristics

### 5.1 Materials

#### 5.1.1 General

All materials coming into contact with water intended for human consumption shall present no health risk nor cause any change to the water in terms of quality, appearance, smell or taste.

**NOTE** While awaiting the adoption of verifiable European criteria for testing materials in contact with water intended for human consumption, existing national regulations concerning the use and/or the characteristics of these products remain in force.

#### 5.1.2 Body materials

##### 5.1.2.1 General

All parts of the body shall be made of a copper alloy or stainless steel.

##### 5.1.2.2 Dezincification resistant copper alloy

Copper-zinc alloys containing more than 15 % zinc are subjected to dezincification when submitted to water capable of dezincification. In the countries where the use of products made of dezincification resistant materials is required, the materials used shall guarantee a dezincification depth less than 200 µm. For this purpose, materials shall be tested in accordance with EN ISO 6509-1 and the product shall be marked in compliance with the indications according to Clause 9.

##### 5.1.3 Corrosion resistance

The materials shall be corrosion resistant or protected against corrosion. The materials used shall not have an adverse effect on each other.

When tested to the neutral salt spray (NSS) test according to EN ISO 9227 for a duration of (96 ± 1) h, no corrosion which could impair the device's operation shall be revealed by visual examination (disregarding possible salt deposits). After the test, the valve shall not show any internal and/or external leakage when being tested according 6.8.

##### 5.1.4 Anti corrosive layer of the ball

Applied metallic anticorrosive protection layers shall fulfil the requirements of EN 248.

For this purpose, a separate ball shall be tested.

## 5.2 Connection ends







### 5.2.1 General

Connection ends shall comply with EN 1254 (all parts) with the exception of EN 1254-1 and EN 1254-4 (ends for capillary soldering or capillary brazing to copper tubes). Examples of connection ends are shown in Table 1.

Valves with threaded connection ends shall have flats on the body which, when used for fitting, shall accommodate commercially available tools.

The connection ends as applied shall be suitable (and approved as such) for the nominal pressure of the valve.

Table 1 — Examples for end connections and nominal sizes (DN)

Type		Dimension	DN 6	DN 8	DN 10	DN 15	DN 20	DN 25	DN 32	DN 40	DN 50	DN 65	DN 80	DN 100
Internal thread to EN 10226-1		A	R <sub>p</sub> or R <sub>c</sub> 1/8	R <sub>p</sub> or R <sub>c</sub> 1/4	R <sub>p</sub> or R <sub>c</sub> 3/8	R <sub>p</sub> or R <sub>c</sub> 1/2	R <sub>p</sub> or R <sub>c</sub> 3/4	R <sub>p</sub> or R <sub>c</sub> 7/8 R <sub>p</sub> or R <sub>c</sub> 1	R <sub>p</sub> or R <sub>c</sub> 1 1/4	R <sub>p</sub> or R <sub>c</sub> 1 1/2	R <sub>p</sub> or R <sub>c</sub> 2	R <sub>p</sub> or R <sub>c</sub> 2 1/2	R <sub>p</sub> or R <sub>c</sub> 3	R <sub>p</sub> or R <sub>c</sub> 4
External thread to EN 10226-1		A	R 1/8	R 1/4	R 3/8	R 1/2	R 3/4	R 1	R 1 1/4	R 1 1/2	R 2	R 2 1/2	R 3	R 4
Internal thread to ISO 228-1		A	G 1/8	G 1/4	G 3/8	G 1/2	G 3/4	G 1	G 1 1/4	G 1 1/2	G 2	G 2 1/2	G 3	G 4
Union end connections (nut) to ISO 228-1		A	—	G 3/8	G 1/2	G 3/4	G 7/8 G 1	G 1 1/4	G 1 1/2	G 1 3/4 G 2	G 2 3/8 G 2 1/2	—	—	—
external thread with shoulder to ISO 228-1		A	G 1/8 B	G 1/4 B	G 3/8 B	G 1/2 B	G 3/4 B	G 1 B	G 1 1/4 B	G 1 1/2 B G 1 3/4 B	G 2 B G 2 3/8 B <sup>a</sup>	G 2 1/2 B	G 3 B	G 4 B
external thread without shoulder to ISO 228-1		A	G 1/4 B	G 3/8 B	G 1/2 B	G 3/4 B	G 1 B	G 1 1/4 B	G 1 1/2 B G 1 3/4 B	G 2 B G 2 3/8 B <sup>a</sup>	G 2 1/2 B	G 3 B	G 4 B	—
Flat faced external thread to ISO 228-1		A	G 1/4 B	G 3/8 B	G 1/2 B	G 3/4 B	G 1 B	G 1 1/4 B	G 1 1/2 B G 1 3/4 B	G 2 B G 2 3/8 B <sup>a</sup>	G 2 1/2 B	G 3 B	G 3 1/2 B	—