

DRAFT INTERNATIONAL STANDARD

ISO/DIS 17584

ISO/TC 86/SC 8

Secretariat: ANSI

Voting begins on:
2021-03-31

Voting terminates on:
2021-06-23

Refrigerant properties

Propriétés des fluides frigorigènes

ICS: 71.100.45

iTeh STANDARD PREVIEW (standards.iteh.ai)

[ISO/DIS 17584](https://standards.iteh.ai/catalog/standards/sist/0c40f5ad-3bd6-4349-917b-2d5fbbe927ce/iso-dis-17584)

<https://standards.iteh.ai/catalog/standards/sist/0c40f5ad-3bd6-4349-917b-2d5fbbe927ce/iso-dis-17584>

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENT AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

This document is circulated as received from the committee secretariat.



Reference number
ISO/DIS 17584:2021(E)

© ISO 2021

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO/DIS 17584](https://standards.iteh.ai/catalog/standards/sist/0c40f5ad-3bd6-4349-917b-2d5fbb927ce/iso-dis-17584)

<https://standards.iteh.ai/catalog/standards/sist/0c40f5ad-3bd6-4349-917b-2d5fbb927ce/iso-dis-17584>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2021

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	vi
Introduction	vii
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Calculation of refrigerant properties	2
4.1 General	2
4.2 Pure-fluid equations of state	3
4.3 Mixture equation of state	6
4.4 Implementation	7
4.5 Alternative implementation	7
4.6 Certification of conformance	7
5 Specifications for individual refrigerants	7
5.1 General	7
5.2 R744 — Carbon dioxide	7
5.2.1 Range of validity	7
5.2.2 Reducing parameters, molar mass, and gas constant	9
5.2.3 Reference state parameters	9
5.3 R717 — Ammonia	10
5.3.1 Range of validity	10
5.3.2 Coefficients and exponents of the ideal-gas part [Equations (3) to (5)]	10
5.3.3 Coefficients and exponents of the real-gas part [Equation (2)]	11
5.3.4 Reducing parameters, molar mass, and gas constant	11
5.3.5 Reference state parameters	11
5.4 R12 — Dichlorodifluoromethane	14
5.4.1 Range of validity	14
5.4.2 Reducing parameters, molar mass, and gas constant	15
5.4.3 Reference state parameters	15
5.5 R22 — Chlorodifluoromethane	18
5.5.1 Range of validity	18
5.5.2 Reducing parameters, molar mass, and gas constant	19
5.5.3 Reference state parameters	19
5.6 R32 — Difluoromethane	22
5.6.1 Range of validity	22
5.6.2 Reducing parameters, molar mass, and gas constant	23
5.6.3 Reference state parameters	23
5.7 R123 — 2,2-dichloro-1,1,1-trifluoroethane	26
5.7.1 Range of validity	26
5.7.2 Reducing parameters, molar mass, and gas constant	27
5.7.3 Reference state parameters	27
5.8 R125 — Pentafluoroethane	30
5.8.1 Range of validity	30
5.8.2 Reducing parameters, molar mass, and gas constant	31
5.8.3 Reference state parameters	31
5.9 R134a — 1,1,1,2-tetrafluoroethane	33
5.9.1 Range of validity	33
5.9.2 Reducing parameters, molar mass, and gas constant	34
5.9.3 Reference state parameters	34
5.10 R143a — 1,1,1-trifluoroethane	37
5.10.1 Range of validity	37
5.10.2 Reducing parameters, molar mass, and gas constant	37
5.10.3 Reference state parameters	37

5.11	R152a — 1,1-difluoroethane.....	40
	5.11.1 Range of validity.....	40
	5.11.2 Reducing parameters, molar mass, and gas constant.....	41
	5.11.3 Reference state parameters.....	41
5.12	R404A — R125/143a/134a (44/52/4).....	44
	5.12.1 Composition of R404A.....	44
	5.12.2 Range of validity.....	44
	5.12.3 Interaction parameters (Equations 19 and 20).....	44
	5.12.4 Coefficients and exponents of the excess functions (Equation 21).....	44
	5.12.5 Reference state parameters.....	44
5.13	R407C — R32/125/134a (23/25/52).....	47
	5.13.1 Range of validity.....	47
	5.13.2 Interaction parameters (Equations 19 and 20).....	47
	5.13.3 Reference state parameters.....	47
5.14	R410A — R32/125 (50/50).....	50
	5.14.1 Range of validity.....	50
	5.14.2 Interaction parameters (Equations 9 and 20).....	50
	5.14.3 Reference state parameters.....	51
5.15	R507A — R125/143a (50/50).....	53
	5.15.1 Range of validity.....	53
	5.15.2 Interaction parameters [Equations (19) and (20)].....	53
	5.15.3 Reference state parameters.....	54
5.16	R290 — Propane.....	56
	5.16.1 Range of validity.....	56
	5.16.2 Coefficients and exponents of the ideal-gas part (Equations 3 to 5).....	56
	5.16.3 Coefficients and exponents of the real-gas part (Equation 2).....	56
	5.16.4 Reducing parameters, molar mass, and gas constant.....	57
	5.16.5 Reference state parameters.....	57
5.17	R600a — Isobutane.....	60
	5.17.1 Range of validity.....	60
	5.17.2 Coefficients and exponents of the ideal-gas part (Equations 3 to 5).....	60
	5.17.3 Coefficients and exponents of the real-gas part (Equation 2).....	61
	5.17.4 Reducing parameters, molar mass, and gas constant.....	61
	5.17.5 Reference state parameters.....	61
5.18	R1336mzz(Z) — (cis-1,1,1,4,4,4-hexafluorobutene).....	65
	5.18.1 Range of validity.....	65
	5.18.2 Coefficients and exponents of the ideal-gas part (Equations 3 to 5).....	65
	5.18.3 Coefficients and exponents of the real-gas part (Equation 2).....	65
	5.18.4 Reducing parameters, molar mass, and gas constant.....	65
	5.18.5 Reference state parameters.....	66
5.19	R1234ze(E) — trans-1,3,3,3-tetrafluoropropene.....	68
	5.19.1 Range of validity.....	68
	5.19.2 Coefficients and exponents of the ideal-gas part (Equations 3 to 5).....	68
	5.19.3 Coefficients and exponents of the real-gas part (Equation 2).....	68
	5.19.4 Reducing parameters, molar mass, and gas constant.....	69
	5.19.5 Reference state parameters.....	69
5.20	R1234yf — 2,3,3,3-tetrafluoropropene.....	71
	5.20.1 Range of validity.....	71
	5.20.2 Coefficients and exponents of the ideal-gas part (Equations 3 to 5).....	72
	5.20.3 Coefficients and exponents of the real-gas part (Equation 2).....	72
	5.20.4 Reducing parameters, molar mass, and gas constant.....	72
	5.20.5 Reference state parameters.....	72
5.21	R1233zd(E) — trans-1-chloro-3,3,3-trifluoropropene.....	75
	5.21.1 Range of validity.....	75
	5.21.2 Coefficients and exponents of the ideal-gas part (Equations 3 to 5).....	75
	5.21.3 Coefficients and exponents of the real-gas part (Equation 2).....	75
	5.21.4 Reducing parameters, molar mass, and gas constant.....	76
	5.21.5 Reference state parameters.....	76

Annex A (normative) Requirements for implementations claiming conformance with this International Standard	79
Annex B (informative) Calculation of pure-fluid thermodynamic properties from an equation of state	81
Annex C (informative) Calculation of mixture thermodynamic properties from an equation of state	84
Annex D (informative) Literature citations for equations of state and verification values	86
Annex E (informative) Variation of mixture properties due to composition tolerance	94
Bibliography	96

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO/DIS 17584](https://standards.iteh.ai/catalog/standards/sist/0c40f5ad-3bd6-4349-917b-2d5fbb927ce/iso-dis-17584)

<https://standards.iteh.ai/catalog/standards/sist/0c40f5ad-3bd6-4349-917b-2d5fbb927ce/iso-dis-17584>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 8, *Refrigerants and refrigeration lubricants*.

This second edition cancels and replaces the first edition (ISO 17584:2005), which has been technically revised.

The main changes compared to the previous edition are as follows:

- Addition of new refrigerants (R290, R600a, R1233zd(E), R1336mzz(Z), R1234yf, R1234ze(E));
- Update of Ammonia.

A list of all parts in the ISO 17584 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document, prepared by ISO/TC 86/SC 8/WG 7, is consistent with and is intended to complement ISO 817. The purpose of this International Standard is to address the differing performance ratings due to the differences between multiple property formulations, which is a problem especially in international trade. The fluids and properties included in this International Standard represent those for which sufficient high-quality data were available. While the working group recognizes the desirability of including additional fluids and including the transport properties of viscosity and thermal conductivity, the data and models for these were judged insufficient at this time to be worthy of designation as an International Standard. Therefore, the working group decided to prepare the present International Standard, incomplete though it might be, in a timely fashion rather than delay it awaiting additional data. The working group is continuing its efforts to add additional fluids and additional properties to this International Standard. It is anticipated that this International Standard will undergo regular reviews and revisions.

For applications such as performance rating of refrigeration equipment, having all parties adopt a consistent set of properties is more important than absolute accuracy. But consensus is easiest to achieve when high-quality property data are available.

With this in mind, the Working Group has taken as its starting point the results of Annex 18 Thermophysical Properties of the Environmentally Acceptable Refrigerants of the Heat Pump Programme of the International Energy Agency (McLinden and Watanabe [7]). Annex 18 reports the comprehensive evaluations of the available equations of state and recommended formulations for R123, R134a, R32, R125, and R143a. Wide participation was invited in this process, and anyone could submit an equation of state for evaluation. The formulations for R123, R134a, R32, and R143a adopted in this International Standard are the same as those recommended by Annex 18. (The recent equation of state for R125 adopted in this International Standard was shown to be more accurate than the older formulation recommended by Annex 18.)

A similar comparison of mixture models reported by Annex 18 facilitated the dissemination and adoption of a new mixture modelling approach. This model is based on Helmholtz energies for each of the mixture components, and it is the approach used in the NIST REFPROP refrigerant property database (Lemmon et al. [5]) and in the extensive tabulation of properties published by the Japan Society of Refrigerating and Air Conditioning Engineers (Tillner-Roth et al. [12]). The Lemmon and Jacobsen [2] model (implemented in the REFPROP database) is simpler than the Tillner-Roth et al. [12] model in that it avoids the ternary interactions terms required in the Tillner-Roth model, with practically the same representations of the experimental data. For these reasons, as well as the widespread use of REFPROP, the Lemmon and Jacobsen model was adopted as the basis for the mixture properties specified in this International Standard.

The one significant disadvantage of the formulations adopted here is their complexity. In recognition of this, this International Standard allows for “alternative implementations” for the properties. These can take the form of simpler equations of state that may be applicable over limited ranges of conditions or simple correlations of single properties (e.g., expressions for vapour pressure or the enthalpy of the saturated vapour). This International Standard does not restrict the form of such alternative implementations, but it does impose requirements, in the form of allowable tolerances (deviations from the standard values), given in [Annex A](#), which alternative implementations shall satisfy.

The question of allowable tolerances for alternative implementations generated the most controversy among the working group. In the working group discussions, some felt that the tolerances should be fairly large to encompass as many formulations in common use as possible. But others argued that this would defeat the very purpose of this International Standard, which was to harmonize the property values used across the industry. The concept of alternative implementations with their allowable tolerances was not intended to sanction the continued use of “incorrect” data but, rather, to provide for fast, application-specific equations that would be fitted to the properties specified in this International Standard. In the end, fairly strict tolerances were selected. The experiences and recommendations of the European Association of Compressor Manufacturers (ASERCOM) carried significant weight. They had experience with simplified property equations that were fitted to, and closely matched, several of

the same equations of state recommended in this International Standard. They recommended strict tolerances.

These tolerances do not necessarily represent the uncertainty of the original experimental data or of the equation of state in fitting the data. The allowable tolerances specified in [Annex A](#) were selected to result in “reasonable” differences in quantities derived from these properties, for example, a cycle efficiency or compressor rating. For example, the tolerances specified in [Annex A](#) result in an overall variation of approximately 2,5 % in the efficiency of an ideal refrigeration cycle operating between an evaporator temperature of -15 °C and a condenser temperature of 30 °C . By comparison, ISO 817 specifies that the primary energy balance for compressor tests agree with flow data within 4 %.

The tolerances are relative (i.e. plus or minus a percentage) for some properties and absolute for others (e.g. plus or minus a constant enthalpy value). Properties such as enthalpy and entropy, which can be negative, demand an absolute tolerance; any allowable percentage variation would be too strict at values near zero. The allowable tolerances for enthalpy and entropy are scaled by the enthalpy and entropy of vapourisation for each fluid. This scaling arose from a cycle analysis which revealed that a constant tolerance resulted in greatly differing sensitivities of the cycle efficiency depending on the enthalpy and entropy of vapourisation. By scaling the tolerance to the vapourisation values, a greater tolerance is allowed for fluids, such as ammonia, with high heats of vapourisation.

The tolerances apply to individual thermodynamic states. In cycle and equipment analyses, it is the differences in enthalpy and/or entropy between two different states that are important. However, it is not possible to specify, in a simple way, allowable tolerances based on pairs of states because of the large number of possible pairs of interest.

The values of C_v and C_p approach infinity at the critical point, but the actual values returned by the equation of state are large numbers that vary from computer to computer due to round-off errors in the calculations. According to critical-region theory, the speed of sound is zero at the critical point; all traditional equations of state (including the ones in this International Standard), however, do not reproduce this behaviour. Rather than list values that are inconsistent with either the theory or the specified equations of state, these points are not included as part of this International Standard.

The values of the gas constant, R , vary from fluid to fluid. Similarly, the number of significant figures given for the molecular mass, M , vary. The values for R and M are those from the original equation of state source from the literature. These values are adopted to maintain consistency with the original sources. The various values of R differ by less than 5×10^{-6} (equal to parts per million, a deprecated unit) from the currently accepted value of $8,314\ 462\ 618\ \text{J}/(\text{mol}\cdot\text{K})$ and result in similarly small differences in the properties. The compositions of the refrigerant blends (R400- and R500-series) are defined on a mass basis, but the equations of state are given on a molar basis. The mass compositions have been converted to the equivalent molar basis and listed in [Clause 5](#); a large number of significant figures are given for consistency with the tables of “verification values” given in [Annex D](#).

This International Standard anticipates regular reviews (see [Clause 6](#)) and will be reviewed every five years. Any interested party requesting the inclusion of additional refrigerant(s) to this International Standard or requesting the revision of one or more fluids specified in this International Standard should petition the ISO/TC 86 secretariat.

Refrigerant properties

1 Scope

This International Standard specifies thermophysical properties of several commonly used refrigerants and refrigerant blends.

This International Standard is applicable to the refrigerants R12¹⁾, R22¹⁾, R32²⁾, R123¹⁾, R125²⁾, R134a²⁾, R143a²⁾, R152a²⁾, R290, R600a, R717 (ammonia), R744 (carbon dioxide), R1233zd(E), R1336mzz(Z), R1234yf and R1234ze(E) and to the refrigerant blends R404A²⁾, R407C²⁾, R410A²⁾, and R507A²⁾. The following properties are included: density, pressure, internal energy, enthalpy, entropy, heat capacity at constant pressure, heat capacity at constant volume, speed of sound, and the Joule-Thomson coefficient, in both single-phase states and along the liquid-vapour saturation boundary. The numerical designation of these refrigerants is that defined in ISO 817.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 817, *Refrigerants — Designation system*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1

algorithm

procedure for the computation of refrigerant properties

Note 1 to entry: An algorithm is most often a computer program. An algorithm may also consist of one or more single-property correlations as allowed under 4.4.

3.2

blend

mixture of two or more chemical compounds

3.3

critical point

state at which the properties of the saturated liquid and those of the saturated vapour become equal

Note 1 to entry: Separate liquid and vapour phases do not exist above the critical point temperature for a pure fluid. This is more completely referred to as the “gas-liquid critical point” as other “critical points” can be defined.

- 1) Controlled substance under the Montreal Protocol, Annex A (R12) or Annex C Group I (R22, R123).
- 2) Controlled substance under the Montreal Protocol, Annex F or blend thereof.

**3.4
equation of state**

mathematical equation that is a complete and thermodynamically consistent representation of the thermodynamic properties of a fluid

Note 1 to entry: An equation of state most commonly expresses pressure or Helmholtz energy as a function of temperature, density, and (for a blend) composition. Other thermodynamic properties are obtained through integration and/or differentiation of the equation of state.

**3.5
fluid
refrigerant**

substance, present in liquid and/or gaseous states, used for heat transfer in a refrigerating system

Note 1 to entry: The fluid absorbs heat at a low temperature and low pressure, then releases the heat at a higher temperature and a higher pressure, usually through a change of state.

**3.6
liquid-vapour saturation**

state at which liquid and vapour phases of a fluid are in thermodynamic equilibrium with each other at a common temperature and pressure

Note 1 to entry: Such states exist from the triple point to the critical point.

**3.7
transport properties**

viscosity, thermal conductivity, and diffusion coefficient

**3.8
thermodynamic properties**

density, pressure, fugacity, internal energy, enthalpy, entropy, Gibbs and Helmholtz energies, heat capacities, speed of sound, and the Joule-Thomson coefficient, in both single-phase states and along the liquid-vapour saturation boundary

**3.9
thermophysical properties**

all of the thermodynamic, transport, and other miscellaneous properties

**3.10
triple point**

state at which solid, liquid, and vapour phases of a substance are in thermodynamic equilibrium

4 Calculation of refrigerant properties

4.1 General

This International Standard specifies properties for the refrigerants listed in [Clause 1](#). These properties are derived from experimental measurements. It is not practical, however, to directly reference the experimental data; they may not be available at all conditions of interest and some properties, such as entropy, cannot be measured directly. Furthermore, a simple tabulation, even for properties (such as vapour pressure) that are directly measurable, is not convenient for modern engineering use. Thus, some means to correlate the data is required to allow calculation of the properties at a desired thermodynamic state.

The properties enumerated in this International Standard are calculated from specified equations of state, although alternative algorithms are allowed. The properties themselves constitute this International Standard. The equations of state serve as a convenient means to represent and reproduce the properties. The properties enumerated in the tables in this International Standard thus represent only a subset of the properties specified by this International Standard; the full range of conditions is given for each fluid in [Clause 5](#). An equation of state is a mathematical equation that is a complete

and thermodynamically consistent representation of the thermodynamic properties of a fluid. These equations have been selected based on the following criteria:

- accuracy in reproducing the available experimental data;
- applicability over wide ranges of temperature, pressure, and density;
- proper behavior on extrapolation beyond the available experimental data; and
- preference has been given to fully documented and published formulations.

4.2 Pure-fluid equations of state

An equation of state for a pure fluid may express the reduced molar Helmholtz energy, A , as a function of temperature and density. The equation is composed of separate terms arising from ideal-gas behaviour (subscript “id”) and a “residual” or “real-fluid” (subscript “r”) contribution as given in [Equation \(1\)](#):

$$\phi = \frac{A}{RT} = \phi_{\text{id}} + \phi_{\text{r}} \quad (1)$$

where

R is the gas constant.

Equations of this form may be written on either a molar basis or a mass basis. For a consistent representation in this International Standard, the equations of state originally published on a mass basis have been converted to a molar basis. The “residual” or “real-fluid” contribution is given by [Equation \(2\)](#):

$$\phi_{\text{r}} = \sum_k N_k \tau^{t_k} \delta^{d_k} \exp\left[-\alpha_k (\delta - \varepsilon_k)^{l_k}\right] \exp\left[-\beta_k (\tau \gamma_k)^{m_k}\right] \quad (2)$$

where

- τ is the dimensionless temperature variable T^*/T ;
- T^* is the reducing parameter that is often equal to the critical temperature;
- δ is the dimensionless density variable ρ/ρ^* ;
- ρ^* is the reducing parameter that is often equal to the critical density;
- N_k are numerical coefficients fitted to experimental data;
- $\alpha_k, \beta_k, \varepsilon_k$ and γ_k are parameters optimized for a particular fluid or group of fluids by a selection algorithm starting with a large bank of terms or by use of a non-linear fitting process;
- t_k, d_k, l_k and m_k are exponents optimized for a particular fluid or group of fluids by a selection algorithm starting with a large bank of terms or by use of a non-linear fitting process.

The ideal-gas contribution can be represented in one of several ways. One representation is in terms of the heat capacity of the ideal-gas state, as given in [Equation \(3\)](#):

$$\phi_{\text{id}} = \frac{h_{\text{ref}}}{RT} - \frac{s_{\text{ref}}}{R} - 1 + \ln\left(\frac{RT\rho}{p_{\text{ref}}}\right) + \frac{1}{RT} \int_{T_{\text{ref}}}^T C_{p,\text{id}} dT - \frac{1}{R} \int_{T_{\text{ref}}}^T \frac{C_{p,\text{id}}}{T} dT \quad (3)$$

where

h_{ref} is the arbitrary reference enthalpy for the ideal gas at the reference state specified by T_{ref} ;

s_{ref} is the arbitrary reference entropy for the ideal gas at the reference state specified by T_{ref} and p_{ref} .

In this International Standard, the h_{ref} and s_{ref} are chosen to yield a reference state for enthalpy of 200 kJ/kg and for entropy of 1 kJ/(kg·K), both for the saturated liquid at 0 °C. Such values of h_{ref} and s_{ref} are informative only; different values, corresponding to different reference state conventions, are acceptable.

The heat capacity of the ideal gas state, $C_{p,\text{id}}$ may be represented as a function of temperature by the general form consisting of separate summations of polynomial (empirical) and exponential (theoretical) terms, as given in [Equation \(4\)](#):

$$\frac{C_{p,\text{id}}}{R} = c_0 + \sum_k c_k T^{t_k} + \sum_k a_k \frac{u_k^2 \exp(u_k)}{[\exp(u_k) - 1]^2} \quad (4)$$

where

$$u_k = \frac{b_k}{T}; \quad (5)$$

c_k , a_k , b_k and t_k are numerical coefficients and exponents fitted to data or derived from theoretical calculations.

STANDARD PREVIEW

A second representation of the ideal-gas contribution is given directly in terms of the Helmholtz free energy, as shown in [Equation \(6\)](#):

$$\phi_{\text{id}} = d_1 + d_2 \tau + \ln \delta + d_3 \ln \tau + \sum_k d_k \tau^{t_k} + \sum_k a_k \ln [1 - \exp(-\tau \lambda_k)] \quad (6)$$

where

d_1 and d_2 are adjusted to yield the desired reference state values for the enthalpy and entropy;

d_3 , d_k , a_k , λ_k and t_k are either empirical or theoretical parameters.

[Equation \(6\)](#) is functionally equivalent to [Equations \(3\) to \(5\)](#), and an ideal-gas contribution in the form of [Equation \(6\)](#) may be converted to the heat capacity form as given by [Equation \(7\)](#):

$$\frac{C_{p,\text{id}}}{R} = d_3 + 1 - \sum_k d_k t_k (t_k - 1) \left(\frac{T^*}{T} \right)^{t_k} + \sum_k a_k \frac{u_k^2 \exp(u_k)}{[\exp(u_k) - 1]^2} \quad (7)$$

where

$$u_k = \frac{\lambda_k T^*}{T} \quad (8)$$

The equations of state for certain fluids may also include special terms to represent the behaviour very close to the critical point. These are of the form of [Equation \(9\)](#):

$$\phi_{\text{crit}} = \sum_k N_k \delta \Delta^{b_k} \Psi \quad (9)$$

where

$$\Delta = \theta^2 + B_k \left[(\delta - 1)^2 \right]^{a_k} \quad (10)$$

$$\theta = (1 - \tau) + A_k \left[(\delta - 1)^2 \right]^{1/(2\beta_k)} \quad (11)$$

$$\Psi = \exp \left[-C_k (\delta - 1)^2 - D_k (\tau - 1)^2 \right] \quad (12)$$

[Equation \(9\)](#) is added to the normal terms in [Equation \(1\)](#). The $N_k, A_k, B_k, C_k, D_k, \alpha_k$ and β_k are adjustable parameters fitted to data. Among the fluids in this International Standard, only the equation of state for R744 (carbon dioxide) includes these critical region terms.

Alternately, an equation of state may express pressure as an explicit function of temperature and molar density. One form is that of a modified Benedict-Webb-Rubin (MBWR) equation of state, as given in [Equation \(13\)](#):

$$p = \sum_{k=1}^9 a_k \rho^k + \exp(-\rho^2 / \rho_{\text{crit}}^2) \sum_{k=10}^{15} a_k \rho^{2k-17} \quad (13)$$

where the a_k are functions of temperature resulting in a total of 32 adjustable parameters that are fitted to the experimental data. For a complete description of the thermodynamic properties, the MBWR equation is combined with an expression for the ideal-gas heat capacity, such as [Equation \(4\)](#) or [\(5\)](#).

In this International Standard, [pressure-explicit equations of state](#) [such as [Equation \(13\)](#)] are transformed into the Helmholtz-energy form to maintain a consistent representation. The pressure is related to the Helmholtz energy using the thermodynamic identity shown in [Equation \(14\)](#):

$$p = - \left(\frac{\partial A}{\partial V} \right)_T \quad (14)$$

ISO/DIS 17584
https://standards.iteh.ai/catalog/standards/sist/0c40f5ad-3bd6-4349-917b-2d5fbbe927ce/iso-dis-17584

Thus, the Helmholtz energy can be evaluated from the pressure by an integration over volume, using [Equation \(15\)](#):

$$\frac{A_r(T, \rho)}{RT} = \phi_r = - \int_V^\infty \left(\frac{p}{RT} - \rho \right) dV \quad (15)$$

[Equation \(15\)](#) is then combined with an ideal-gas contribution given by [Equations \(3\)](#) to [\(5\)](#) to yield a complete description of the thermodynamic properties. Among the fluids in this International Standard, the equations of state for R123 and R152a have been transformed in this manner.

An equation of state or the ideal-gas heat capacity may also be expressed in other forms, but the forms represented by [Equations \(1\)](#) through [\(15\)](#) encompass all those specified in this International Standard.

Methods for computing pure-fluid thermodynamic properties from an equation of state are given in [Annex B](#).

4.3 Mixture equation of state

Thermodynamic properties of mixtures are calculated by applying mixing rules to the Helmholtz energy of the mixture components together with a separate mixture function. The reduced Helmholtz energy of the mixture is a sum of ideal-gas and residual contributions as given by [Equation \(16\)](#):

$$\phi_{\text{mix}} = \frac{A}{RT} = \phi_{\text{mix,id}} + \phi_{\text{mix,r}} \quad (16)$$

The ideal gas part is given by [Equation \(17\)](#):

$$\phi_{\text{mix,id}} = \sum_{i=1}^n [x_i \phi_{i,\text{id}} + x_i \ln x_i] + f_3 + f_4 / T \quad (17)$$

where

x_i is the mole fraction of component i in the n -component mixture;

$x_i \ln x_i$ are terms arising from the entropy of mixing of ideal gases.

The parameters f_3 and f_4 are used to shift the thermodynamic surface such that the reference state for enthalpy is 200 kJ/kg and entropy is 1 kJ/(kg·K) at the saturated liquid at 0 °C, similar to that done for the pure fluids. Setting the parameters f_3 and f_4 to zero corresponds to a reference state based solely on the constituents of the mixture.

The residual part is given by [Equation \(18\)](#):

$$\phi_{\text{mix,r}} = \sum_{i=1}^n x_i \phi_{i,r} + \sum_{i=1}^{n-1} \sum_{j=i+1}^n x_i x_j \phi_{ij,\text{excess}} \quad (18)$$

The first summation in this equation represents the ideal solution; it consists of the real fluid terms for each of the pure fluids multiplied by their respective compositions. The double summation accounts for the “excess” Helmholtz energy or “departure” from ideal solution. The $\phi_{i,r}$ and $\phi_{ij,\text{excess}}$ functions in [Equation \(18\)](#) are not evaluated at the temperature, T_{mix} , and density, ρ_{mix} , of the mixture, but, rather, at a reduced temperature, τ , and density, δ . The mixing rules for the reducing parameters are given by [Equations \(19\)](#) and [\(20\)](#):

$$\tau = \frac{T^*}{T_{\text{mix}}} \quad (19)$$

where

$$T^* = \sum_{i=1}^n x_i T_i^* + \sum_{i=1}^{n-1} \sum_{j=i+1}^n x_i x_j \zeta_{ij}$$

and

$$\delta = \frac{\rho_{\text{mix}}}{\rho^*} \quad (20)$$

where

$$\frac{1}{\rho^*} = \sum_{i=1}^n \frac{x_i}{\rho_i^*} + \sum_{i=1}^{n-1} \sum_{j=i+1}^n x_i x_j \xi_{ij}$$

where

ζ_{ij} and ξ_{ij} are “interaction parameters”;

T_i^* and ρ_i^* are the reducing parameters of the pure fluids.

The $\phi_{ij,\text{excess}}$ function is of the general form of [Equation \(21\)](#):

$$\phi_{ij,\text{excess}} = F_{ij} \sum_k N_k \delta^{d_k} \tau^{t_k} \exp(-\delta^{l_k}) \quad (21)$$

The $\phi_{ij,\text{excess}}$ function will, in general, vary from mixture to mixture, and the coefficients and exponents are tabulated in [Clause 5](#) for the refrigerant blends included in this International Standard. In all cases, the pure-component contributions are those defined in [Clause 5](#) of this International Standard.

Methods for computing thermodynamic properties from a mixture equation of state are given in [Annex C](#).

4.4 Implementation

An algorithm is conforming to this International Standard if it directly implements one or more of the equations of state specified in [Clause 5](#) together with the methods of calculating the thermodynamic properties given in [Annex B](#) and is also demonstrated to reproduce, for the fluids implemented, the “verification values” given in [Annex D](#).

4.5 Alternative implementation

An algorithm is conforming to this International Standard if, by any method, it reproduces the values of thermodynamic properties specified in this International Standard for the fluids implemented. An algorithm claiming compliance under this section can be applicable to the full range of temperature, pressure, and density and to the full set of properties or to any subrange of conditions and/or subset of properties. Any algorithm must state the fluids for which it is applicable and the applicable property(ies) and range(s). The allowable variations (tolerances) between the property values specified in this International Standard and those of an alternative implementation vary from property to property and are defined in [Annex A](#).

4.6 Certification of conformance

Any computer program or other implementation of this International Standard must satisfy the requirements specified in [Annex A](#) before it can claim compliance with this International Standard. These requirements shall be carried out by the developer of the particular implementation.

5 Specifications for individual refrigerants

5.1 General

The following sections specify the equations of state used to calculate the properties of each of the refrigerants covered by this International Standard and also tabulate the properties along the liquid-vapour saturation boundary. In the tabulations of coefficients and exponents, any terms not listed are zero.

5.2 R744 — Carbon dioxide

5.2.1 Range of validity

The coefficients are valid within the following ranges:

$$T_{\min} = 216,592 \text{ K}, T_{\max} = 1\,100 \text{ K}; p_{\max} = 800 \text{ MPa}; \rho_{\max} = 37,24 \text{ mol/l (1\,639 kg/m}^3\text{)}$$