



SLOVENSKI STANDARD
oSIST prEN 17966:2023
01-julij-2023

Oprema za požarno zaščito - Gasilni sistemi z ogljikovim dioksidom za uporabo v prostorih - Načrtovanje in vgradnja (ISO 6183:2022, spremenjen)

Fire protection equipment - Carbon dioxide extinguishing systems for use on premises - Design and installation (ISO 6183:2022, modified)

Brandschutzeinrichtungen - Kohlenstoffdioxid-Löschanlagen für den Einsatz in Gebäuden - Planung und Einbau (ISO 6183:2022, modifiziert)

Équipement de protection contre l'incendie - Installations d'extinction par dioxyde de carbone utilisées dans les bâtiments - Conception et installation (ISO 6183:2022, modifiée)

Ta slovenski standard je istoveten z: prEN 17966

ICS:

13.220.20 Požarna zaščita Fire protection

oSIST prEN 17966:2023 **en,fr,de**

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
prEN 17966

May 2023

ICS 13.220.20

English Version

Fire protection equipment - Carbon dioxide extinguishing systems for use on premises - Design and installation (ISO 6183:2022, modified)

Équipement de protection contre l'incendie -
Installations fixes d'extinction par dioxyde de carbone
utilisées dans les bâtiments - Conception et installation
(ISO 6183:2022, modifiée)

Brandschutzeinrichtungen - Kohlenstoffdioxid-
Löschanlagen für den Einsatz in Gebäuden - Planung
und Einbau (ISO 6183:2022, modifiziert)

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 191.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	5
Introduction	6
1 Scope.....	7
2 Normative references.....	7
3 Terms and definitions.....	7
4 Use and limitations.....	11
4.1 General.....	11
4.2 Uses for carbon dioxide systems.....	11
4.3 Limitations for carbon dioxide systems	11
4.4 Temperature limitations.....	11
5 Safety	12
5.1 Hazard to personnel	12
5.2 Safety precautions	12
5.2.1 Normally occupied and normally unoccupied areas	12
5.2.2 Warning notices for occupiable areas	13
5.2.3 Warning notices for unoccupiable areas.....	16
5.3 Electrical hazards	17
5.4 Electrical earthing	18
5.5 Electrostatic discharge.....	18
6 System design.....	18
6.1 General.....	18
6.1.1 Introduction.....	18
6.1.2 Specifications	19
6.1.3 Working documents.....	19
6.2 Carbon dioxide supply	19
6.2.1 Quality.....	19
6.2.2 Quantity.....	19
6.2.3 Container arrangement	20
6.2.4 Storage containers.....	21
6.3 Distribution.....	23
6.3.1 General.....	23
6.3.2 Piping	24
6.3.3 Fittings	24
6.3.4 Pipe and valve support	24
6.3.5 Valves	25
6.3.6 Nozzles	26
6.4 Enclosures (total flooding).....	27
6.4.1 Structural strength.....	27
6.4.2 Loss through openings.....	27
6.4.3 Ventilation systems.....	28
6.5 Detection, actuation and control systems.....	28
6.5.1 General.....	28
6.5.2 Shut-down of plant and equipment.....	28
6.5.3 Automatic detection.....	28

6.5.4	Operating devices.....	28
6.5.5	Control equipment.....	29
6.5.6	Audible alarms and visual indicators.....	30
6.6	Local control (LC) and local control stations (LCS).....	31
7	Carbon dioxide flow and concentration calculations.....	32
7.1	General.....	32
7.2	System flow calculations.....	32
7.2.1	General.....	32
7.2.2	Friction losses.....	32
7.2.3	Pressure drop.....	32
7.2.4	Valves and fittings.....	33
7.2.5	As-installed calculations.....	33
7.2.6	Specific requirements.....	33
7.3	Carbon dioxide concentration requirements.....	33
7.3.1	Flame extinguishment.....	33
7.3.2	Inerting.....	34
7.4	Total flooding quantity.....	34
7.4.1	General.....	34
7.4.2	Design quantity.....	34
7.4.3	K_B factor.....	35
7.5	Design of local application systems.....	38
7.5.1	General.....	38
7.5.2	Carbon dioxide requirements.....	38
7.5.3	Rate by area method.....	39
7.5.4	Rate by volume method.....	40
7.6	Duration of protection — total flooding systems.....	42
7.7	System performance.....	42
7.7.1	Discharge time.....	42
7.7.2	Extended discharge.....	43
8	Commissioning and acceptance.....	43
8.1	General.....	43
8.2	Tests.....	43
8.2.1	General.....	43
8.2.2	Enclosure check.....	43
8.2.3	Review of mechanical components.....	43
8.2.4	Review of enclosure integrity.....	44
8.2.5	Review of electrical components.....	45
8.2.6	Preliminary functional tests.....	45
8.2.7	System functional operational test.....	46
8.2.8	Remote monitoring operations (if applicable).....	46
8.2.9	Control panel primary power source.....	46
8.2.10	Completion of functional tests.....	47
8.3	Completion certificate and documentation.....	47
9	Inspection, maintenance, testing and training.....	47
9.1	General.....	47
9.2	Inspection.....	47
9.2.1	General.....	47
9.2.2	Container.....	47
9.2.3	Hose.....	47
9.2.4	Enclosures.....	47
9.3	Maintenance.....	48
9.3.1	General.....	48

prEN 17966:2023 (E)

9.3.2	User's programme of inspection	48
9.3.3	Service schedule.....	48
9.4	Training.....	48
Annex A (normative) Working documents		49
A.1	General.....	49
A.2	Working documents.....	49
A.3	Specific details	50
A.4	Completion certificate and documentation.....	50
Annex B (normative) Carbon dioxide system pipe and orifice size determination.....		56
Annex C (informative) System performance verification.....		66
Annex D (informative) General information on carbon dioxide.....		67
D.1	General.....	67
D.2	Free efflux.....	68
D.3	Hazards to personnel	70
Annex E (informative) Examples of calculations.....		72
E.1	Rate by volume method — Example 1.....	72
E.2	Rate by volume method — Example 2.....	73
E.3	Rate by area method.....	74
E.4	Total flooding system	74

oSIST prEN 17966:2023

<https://standards.iteh.ai/catalog/standards/sist/02513885-ed62-4812-a1c9-530353b3c969/osist-pren-17966-2023>

European foreword

This document (prEN 17966:2023) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This document is currently submitted to the CEN Enquiry.

The text of ISO 6183:2022 has been prepared by Technical Committee ISO/TC 21 “Equipment for fire protection and fire fighting” of the International Organization for Standardization (ISO) and has been taken over as prEN 17966:2023 by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI, with common modifications which are indicated by a straight line in the margin of the text.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN 17966:2023](https://standards.iteh.ai/catalog/standards/sist/02513885-ed62-4812-a1c9-530353b3c969/osist-pren-17966-2023)

<https://standards.iteh.ai/catalog/standards/sist/02513885-ed62-4812-a1c9-530353b3c969/osist-pren-17966-2023>

Introduction

This document is intended for use by those concerned with purchasing, designing, installing, testing, inspecting, approving, operating and maintaining carbon dioxide (CO₂) extinguishing systems.

This document applies only to carbon dioxide fixed fire-extinguishing systems in buildings and other premises on land. Although the general principles can apply to other uses (e.g. maritime use), for these other uses, it is likely that additional considerations will have to be taken into account and the application of the requirements given in this document is therefore unlikely to be fully satisfactory. General information about carbon dioxide as an extinguishing medium is given in Annex D. This can be useful background information for those unfamiliar with the characteristics of this medium.

It has been assumed in the preparation of this document that the execution of its provisions will be entrusted to those persons appropriately qualified and experienced in the specification, design, installation, testing, approval, inspection, operation and maintenance of systems and equipment, for whose guidance it has been prepared, and who can be expected to exercise a duty of care to avoid the unnecessary release of carbon dioxide. New requirements to minimize the need to release carbon dioxide during testing and commissioning procedures are included in this third edition. These are linked to the inclusion of enclosure integrity testing.

Carbon dioxide has for many years been a recognized effective medium for the extinction of flammable liquid fires as well as fires in the presence of electrical and ordinary Class A hazards. Nevertheless, in the planning of comprehensive schemes, it should be remembered that there can be hazards for which this media is not suitable, and that in certain circumstances or situations there can be dangers in its use requiring special precautions.

The use of carbon dioxide is no longer recommended for total flooding of occupied areas if more appropriate extinguishing agents are available. EN 15004 provides requirements for other extinguishing agents that can be more appropriately used in these areas.

It is important that the fire protection of a building or plant be considered as a whole. Carbon dioxide systems form only a part, albeit an important part, of the available facilities. It cannot be assumed that their adoption necessarily removes the need to consider supplementary measures, such as the provision of portable fire extinguishers or other mobile appliances for first aid or emergency use, or to deal with special hazards.

Advice on these matters can be obtained from the appropriate manufacturer of the carbon dioxide or the extinguishing system. Information can also be sought from the appropriate fire authority, the health and safety authorities, and insurers. In addition, reference needs to be made, as appropriate, to the other national standards and statutory regulations of a given country.

It is essential that firefighting equipment be carefully maintained to ensure instant readiness when required. Routine maintenance is liable to be overlooked or given insufficient attention by the owner of the system. It is, however, neglected at the peril of the lives of occupants of the premises and at the risk of crippling financial loss. The importance of maintenance cannot be too highly emphasized. Inspection, preferably by a third party, should include an evaluation concluding that the extinguishing system continues to provide adequate protection for the risk (protected zones as well as state-of-the-art can change over time).

1 Scope

This document specifies requirements and gives recommendations for the design, installation, testing, maintenance and safety of fixed carbon dioxide firefighting systems in buildings, plants or other structures. It is not applicable to extinguishing systems on ships, in aircraft, on vehicles or on mobile fire appliances, or to below ground systems in the mining industry; nor does it apply to carbon dioxide pre-inerting systems.

Design of systems where unclosable opening(s) exceed a specified area and where the opening(s) can be subject to the effect of wind is not specified, although general guidance on the procedure to be followed in such cases is given (see 7.4.3.2).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 7731, *Ergonomics — Danger signals for public and work areas — Auditory danger signals (ISO 7731)*

EN 15004:2019¹, *Fixed firefighting systems — Gas extinguishing systems — Part 1: Design, installation and maintenance (ISO 14520-1:2015 modified)*

EN 12094 (all parts), *Fixed firefighting systems — Components for gas extinguishing systems*

EN 54 (all parts), *Fire detection and fire alarm systems*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1

approved

acceptable to a relevant authority (3.2)

Note 1 to entry: In determining the acceptability of installations or procedures, equipment or materials, the authority can base acceptance on compliance with the appropriate standards.

3.2

authority

organization, office or individual responsible for approving equipment, installations or procedures

¹ Under revision.

prEN 17966:2023 (E)**3.3****automatic/manual switch**

means of converting the system from automatic to manual actuation

Note 1 to entry: This can be in the form of a manual switch on the control panel or other units, or a personnel door interlock. In all cases, this changes the actuation mode of the system from automatic and manual to manual only or vice versa.

3.4**clearance**

air gap between equipment, including piping and nozzles and unenclosed or uninsulated live electrical components at other than ground potential

3.5**deep-seated fire**

fire involving solids subject to smouldering

Note 1 to entry: Examples of a deep-seated fire include baled, stacked or piled materials such as paper, wool and grain.

3.6**design concentration**

concentration of carbon dioxide, including a safety factor (3.24), required for system design purposes

3.7**engineered system**

system in which the supply of carbon dioxide is discharged through a system of pipes and nozzles in which the size of each section of pipe and nozzle orifice has been calculated in accordance with the requirements of this document

3.8**extinguishing concentration**

minimum concentration of carbon dioxide required to extinguish a fire involving a particular fuel under defined experimental conditions excluding any safety factor (3.24)

3.9**fill density**

mass of carbon dioxide per unit volume (3.11) of container

3.10**design quantity**

mass of carbon dioxide required to achieve the design concentration (3.6) within the protected volume (3.11)

3.11**volume**

protected space enclosed by the building elements

3.12**high pressure storage**

storage of carbon dioxide in pressurized containers at ambient temperatures

3.13**hold time**

period of time during which a concentration of carbon dioxide greater than the fire extinguishing concentration (3.8) is maintained

Note 1 to entry: See 7.6.2.

3.14**inspection**

visual check to give reasonable assurance that the extinguishing system is fully charged and operable

Note 1 to entry: This is done by seeing that the system is in place, that it has not been activated or tampered with, and that there is no obvious physical damage or condition to prevent operation.

3.15**liquid discharge time**

time during which predominantly liquid carbon dioxide is present at the nozzle

3.16**lock-off device**

manually operated shut-off valve installed in the discharge piping downstream of the carbon dioxide containers, or other type of device that mechanically prevents agent container actuation

Note 1 to entry: The actuation of this device provides an indication of system isolation.

Note 2 to entry: The intent is to prevent the discharge of carbon dioxide into the hazard area when the lock-off device is activated.

3.17**local application system**

automatic or manual fire extinguishing system in which a fixed supply of carbon dioxide is permanently connected to fixed piping with nozzles arranged to discharge the carbon dioxide directly to a fire occurring in a defined area that has no enclosure surrounding it, or is only partially enclosed, and that does not produce an extinguishing concentration (3.8) throughout the entire volume (3.11) containing the protected hazard

3.18**low pressure storage**

storage of carbon dioxide in pressurized containers at a controlled low temperature, normally -18 °C to -20 °C

Note 1 to entry: The pressure in this type of storage is approximately 21 bar².

3.19**maintenance**

thorough check to verify that the extinguishing system will operate as intended

Note 1 to entry: It includes a thorough examination and any necessary repair or replacement of system components.

² 1 bar = 0,1 MPa = 10^5 Pa; 1 MPa = 1 N/mm².

prEN 17966:2023 (E)**3.20****maximum working pressure**

equilibrium pressure within a container at the maximum working temperature

Note 1 to entry: For high pressure storage (3.12), at the maximum fill density (3.9). For a container in transit, the equilibrium pressure can differ from that in storage within a building.

Note 2 to entry: For low pressure storage (3.18), the pressure corresponding to the maximum controlled temperature of $-18\text{ }^{\circ}\text{C}$.

3.21 Terms related to occupied and unoccupiable areas**3.21.1****normally occupied area**

area intended for occupancy

3.21.2**normally unoccupied area**

area not normally occupied by people, but which may be entered occasionally for brief periods

3.21.3**unoccupiable area**

area which cannot be occupied by people due to dimensional or other physical constraints

EXAMPLE Shallow voids and cabinets.

3.22**pre-engineered system**

system consisting of a supply of extinguishant of specified capacity coupled to pre-calculated pipework and nozzle arrangement up to maximum permitted limits

Note 1 to entry: No deviation is permitted from the limits specified by the manufacturer or authority (3.2).

3.23**pre-liquid vapour flow time**

time from the opening of the container or selector valve (3.25) to the start of predominantly liquid flow at the most unfavourable nozzle

3.24**safety factor**

multiplier of the carbon dioxide extinguishing concentration (3.8), used to determine minimum design concentration (3.6)

3.25**selector valve**

valve installed in the discharge piping downstream of the storage containers, used to direct the carbon dioxide to the appropriate hazard

Note 1 to entry: It is used where one or more storage containers are arranged to selectively discharge carbon dioxide to any of several separate hazards.

3.26**surface fire**

fire involving combustible or flammable liquids, gases and solids not subject to smouldering

3.27

total flooding system

system arranged to discharge carbon dioxide into an enclosed space to achieve the appropriate design concentration (3.6)

4 Use and limitations

4.1 General

The design, installation, service and maintenance of carbon dioxide fire-extinguishing systems shall be performed by those competent in fire extinguishing system technology. Maintenance and installation shall only be performed by qualified personnel and companies.

4.2 Uses for carbon dioxide systems

Carbon dioxide, local application and total flooding are useful within the limits of this document in extinguishing fires involving specific hazards or equipment.

The following are typical of such hazards, but the list is not exhaustive:

- a) combustible or flammable liquid and gases;
- b) electrical hazards such as transformers, switches, circuit breakers, rotating equipment and electronic equipment;
- c) engines utilizing gasoline and other flammable liquid fuels;
- d) ordinary combustibles such as paper, wood, and textiles.

4.3 Limitations for carbon dioxide systems

Carbon dioxide cannot extinguish fires involving certain types of materials such as:

- a) chemicals containing their own supply of oxygen, such as cellulose nitrate; or
- b) metals and chemicals which react with carbon dioxide, e.g. alkali metals and metal hydrides.

While carbon dioxide does not extinguish certain fuels containing their own oxygen of combustion, it does not react dangerously with these materials or increase their burning rate. Carbon dioxide, if used in this situation in a total flooding system, provides protection for adjacent combustibles or can be successfully used if the reactive metals or hydride are first covered by another material. Examples of the latter condition are sodium stored or used under kerosene, cellulose nitrate in a solution of lacquer thinner, and magnesium chips covered with heavy oil.

4.4 Temperature limitations

All devices shall be designed for the service they will encounter and shall not be readily rendered inoperative or susceptible to accidental operation. Devices shall normally be designed to function properly from -20 °C to $+50\text{ °C}$, or marked to indicate temperature limitations, or in accordance with the manufacturer's specifications, which shall be marked on the name-plate, or (where there is no name-plate) in the manufacturer's instruction manual.

5 Safety

5.1 Hazard to personnel

The discharge of carbon dioxide in fire-extinguishing concentration creates serious hazards to personnel, such as suffocation and reduced visibility during and after the discharge period. Hazards to personnel created by the discharge of carbon dioxide shall be considered in the design of the system.

Carbon dioxide gas is heavier than air and will collect in pits, wells, shaft bottoms or other low-lying areas, and can migrate into adjacent places outside the protected space. Consideration shall also be given to places to which the carbon dioxide can migrate or collect in the event of a discharge from a safety relief device of a storage container.

Conformance with this document does not affect the user's statutory responsibility to conform to the appropriate safety regulations.

NOTE The safety precautions required by this document do not address toxicological or physiological effects associated with the products of combustion caused by fire.

5.2 Safety precautions

5.2.1 Normally occupied and normally unoccupied areas

The use of carbon dioxide is not recommended for total flooding of normally occupied and normally unoccupied areas as long as comparable alternative firefighting methods are available. However, where carbon dioxide systems are used to protect these areas, they shall be provided with the following:

- a) A non-electrical time delay device and an electrical and pneumatic pre-discharge alarm that is distinct from all other alarm signals or other approved combination of devices providing equivalent level of safety and reliability.

The pre-discharge alarm shall be audible in all areas within the protected space and, where used, carbon dioxide powered alarms shall not result in the development of an unsafe atmosphere.

Non-electrical delay devices shall be approved in accordance with EN 12094-2. Electrical pre discharge alarms shall be approved in accordance with EN 54-3. Pneumatic pre discharge alarms shall be approved in accordance with EN 12094-12.

- b) An automatic/manual switch, with associated status indication.
- c) A lock-off device supervised to indicate a system fault if the valve is more than one eighth closed.

Lock-off devices shall be approved in accordance with EN 12094-6.

NOTE The purpose of the lock-off device is to physically prevent discharge of carbon dioxide into the protected space, for example, during maintenance or if safe evacuation is not possible during the pre-warning time.

- d) Emergency lighting and adequate direction signs for exit routes: continuous visual and audible alarms at entrances and designated exits inside the protected area and continuous visual alarms outside the protected area that operate until the protected area has been declared safe.
- e) Designated exit doors that are outward swinging, self-closing and able to be opened from the inside, even when locked from the outside.
- f) Appropriate warning and instruction signs (see 5.2.2).

- g) Means for prompt natural or forced-draft ventilation of such areas after any discharge of carbon dioxide. Forced-draft ventilation will often be necessary. Care shall be taken to completely dissipate hazardous atmospheres, and not just move them to other locations, as carbon dioxide is heavier than air.

Where it is possible for carbon dioxide gas to collect in pits, wells, shaft bottoms or other low-lying areas, consideration shall be given to adding an odoriferous substance to the carbon dioxide.

Instructions to, and drills of, all personnel within or in the vicinity of protected areas, including maintenance or construction personnel who could be brought into the area, shall be given to ensure their correct actions when the system operates. Following discharge of the system, personnel should not enter the enclosure until it has been declared as being safe to do so. Additional safety aspects such as breathing apparatus should be considered.

The need to comply with national regulations or standards requiring other precautions shall be considered.

5.2.2 Warning notices for occupiable areas

Notices shall be provided at the following locations:

- a) at all entrances to the protected enclosure (see Figure 1 and Figure 2);
- b) at each emergency manual release point (see Figure 3);
- c) at each lock-off valve (see Figure 4).

For carbon dioxide systems protecting occupiable areas, appropriate warning and instruction signs shall be provided adjacent to access points to the protected space or as specified by national requirements. Examples of a typical notices are shown in Figure 1 to Figure 5.

[oSIST prEN 17966:2023](https://standards.iteh.ai/catalog/standards/sist/02513885-ed62-4812-a1c9-530353b3e969/osist-pren-17966-2023)

<https://standards.iteh.ai/catalog/standards/sist/02513885-ed62-4812-a1c9-530353b3e969/osist-pren-17966-2023>