
**Implants for surgery — Wear of
total intervertebral spinal disc
prostheses —**

**Part 1:
Loading and displacement parameters
for wear testing and corresponding
environmental conditions for test**
AMENDMENT 1

ISO 18192-1:2011/Amd 1:2018

<https://standards.iteh.ai/standards/ISO/18192-1:2011/Amd.1:2018>
**Implants chirurgicaux — Usure des prothèses totales de
remplacement des disques intervertébraux lombaires —**

*Partie 1: Paramètres de charge et de déplacement pour essais d'usure
et conditions environnementales correspondantes*

AMENDEMENT 1



iTeh STANDARD PREVIEW
(standards.iteh.ai)

<https://standards.iteh.ai/catalog/standards/sist/5194b83a-1643-4bbf-88dc-997892023734/iso-18192-1-2011-amd-1-2018>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2018

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO TC 150, *Implants for surgery*, Subcommittee SC 5, *Osteosynthesis and spinal devices*.

A list of all parts in the ISO 19218 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO 18192-1:2011/Amd 1:2018](https://standards.iteh.ai/catalog/standards/sist/5194b83a-1643-4bbf-88dc-997892023734/iso-18192-1-2011-amd-1-2018)

<https://standards.iteh.ai/catalog/standards/sist/5194b83a-1643-4bbf-88dc-997892023734/iso-18192-1-2011-amd-1-2018>

Implants for surgery — Wear of total intervertebral spinal disc prostheses —

Part 1:

Loading and displacement parameters for wear testing and corresponding environmental conditions for test

AMENDMENT 1

6.4

Replace 6.4 with the following:

6.4 Motion control system, capable of generating the angular movements of the superior or inferior component as given in Figures 2 and 3 with an accuracy of $\pm 0,5^\circ$ at the maxima and minima of the motion and $\pm 2\%$ of the full cycle time for phasing. For multi-station test systems, capabilities should be assessed with all stations active.

ITC STANDARD PREVIEW
(standards.iteh.ai)

<https://standards.iteh.ai/catalog/standards/sist/5194b83a-1643-4bbf-88dc-997892023734/iso-18192-1-2011-amd-1-2018>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO 18192-1:2011/Amd 1:2018](https://standards.iteh.ai/catalog/standards/sist/5194b83a-1643-4bbf-88dc-997892023734/iso-18192-1-2011-amd-1-2018)
<https://standards.iteh.ai/catalog/standards/sist/5194b83a-1643-4bbf-88dc-997892023734/iso-18192-1-2011-amd-1-2018>