



SLOVENSKI STANDARD

oSIST prEN 1751:2023

01-marec-2023

Nadomešča:
SIST EN 1751:2014

Prezračevanje stavb - Naprave za dovod in odvod zraka - Aerodinamično preskušanje dušilnikov in loput

Ventilation for buildings - Air terminal devices - Aerodynamic testing of damper and valves

Lüftung von Gebäuden - Geräte des Luftverteilungssystems - Aerodynamische Prüfungen von Drossel- und Absperrerelementen

Ventilation des bâtiments - Bouches d'air - Essais aérodynamiques des registres et clapets

Ta slovenski standard je istoveten z: prEN 1751

ICS:

91.140.30	Prezračevalni in klimatski sistemi	Ventilation and air-conditioning systems
-----------	------------------------------------	--

oSIST prEN 1751:2023

en,fr,de

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
prEN 1751

January 2023

ICS 91.140.30

Will supersede EN 1751:2014

English Version

Ventilation for buildings - Air terminal devices - Aerodynamic testing of damper and valves

Ventilation des bâtiments - Bouches d'air - Essais
aérodynamiques des registres et clapets

Lüftung von Gebäuden - Geräte des
Luftverteilungssystems - Aerodynamische Prüfungen
von Drossel- und Absperrelementen

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 156.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	4
1 Scope	5
2 Normative references	5
3 Terms, definitions, symbols and suffixes	6
3.1 Terms and definitions	6
3.2 Symbols	6
3.3 Suffixes	7
4 Instrumentation	7
4.1 Air flow rate measurement	7
4.2 Pressure measurement	8
4.3 Temperature measurement	9
5 Leakage tests	9
5.1 General	9
5.2 Damper and valve leakage	9
5.3 Casing leakage	9
6 Flow rate and pressure tests	10
6.1 Ducted method	10
6.2 Chamber method	11
6.2.1 General	11
6.2.2 Size relationship	11
6.2.3 Tests	12
6.3 Calculations and report	12
Annex A (informative) Mechanical testing of dampers and valves	20
A.1 Scope	20
A.2 Instrumentation: Torque measurement	20
A.3 Pressure test to determine limiting value for structural stability	20
A.4 Torque tests to determine the torque required to operate the damper or valve and the limiting value to avoid structural damage	21
A.4.1 Torque required to operate damper	21
A.4.2 Maximum permitted torque	21
Annex B (informative) Thermal transmittance through dampers and valves	24
B.1 Introduction	24
B.2 Scope	24
B.3 Thermal loss test using a substitution method	24
Annex C (normative) Classification of a damper or valve leakage	27
C.1 Scope	27
C.2 Leakage through closed blade(s)	27
C.3 Casing leakage	28
Annex D (informative) Effect of duct configuration on pressure loss coefficient	31
D.1 General	31

D.2	Application of correction factor	32
Annex E (informative)	Correction of air flow rate according to ambient conditions	33
E.1	Calculation on airflow correction under reference conditions – examples	33
Bibliography	35

iTeh STANDARD PREVIEW (standards.iteh.ai)

[oSIST prEN 1751:2023](https://standards.iteh.ai/catalog/standards/sist/6e7046d5-41a3-4804-bb71-6c5da5212500/osist-pren-1751-2023)

<https://standards.iteh.ai/catalog/standards/sist/6e7046d5-41a3-4804-bb71-6c5da5212500/osist-pren-1751-2023>

prEN 1751:2023 (E)**European foreword**

This document (prEN 1751:2023) has been prepared by Technical Committee CEN/TC 156 “Air terminal devices”, the secretariat of which is held by BSI.

This document is currently submitted to the CEN Enquiry.

This document supersedes EN 1751:2014.

In comparison with the previous edition EN 1751:2014, the following technical modifications have been made:

- Annex C Classification of a damper or valve leakage;
- Closed blade leakage now has the addition of equations for the calculation of classification levels and an improved graph;
- Case leakage now has equations for classification which are based on ductwork leakage classes in EN 16798-3:2017, Table 19 taking a reference case length of 1 m and also an improved graph.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN 1751:2023](https://standards.iteh.ai/catalog/standards/sist/6e7046d5-41a3-4804-bb71-6c5da5212500/osist-pren-1751-2023)

<https://standards.iteh.ai/catalog/standards/sist/6e7046d5-41a3-4804-bb71-6c5da5212500/osist-pren-1751-2023>

1 Scope

This document specifies methods for the testing and rating of dampers and valves used in air distribution systems with pressure differences up to 2 000 Pa.

The tests incorporated in this document will address:

- leakage past a closed damper or valve (for classification see Annex C);
- casing leakage (for classification see Annex C);
- flow rate/pressure requirement characteristics;
- torque: (see Annex A);
- thermal transmittance: (see Annex B).

The acoustic testing of dampers and valves is not included in this document. The tests specified above apply to the following:

- measurement of leakage past a closed damper or valve;
- measurement of casing leakage;
- determination of flow rate and pressure requirements;
- measurement of torque characteristics (see Annex A);
- measurement of thermal transfer characteristics to determine insulation properties (see Annex B).

NOTE Certain aspects of the dynamic performance of dampers and/or valves are dependent upon the air distribution system to which they are connected and are, therefore, difficult to measure in isolation. Such considerations have led to the omission of these aspects of the dynamic performance measurements from this document. Also, in common with other air distribution components, the results from tests carried out in accordance with this document may not be directly applicable if the damper or valve is situated in an area of non-uniform flow.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

CEN/TS 17153, *Ventilation for buildings — Correction of air flow rate according to ambient conditions*

EN 12792, *Ventilation for buildings — Symbols, terminology and graphical symbols*

EN 16798-3:2017, *Energy performance of buildings — Ventilation for buildings — Part 3: For non-residential buildings — Performance requirements for ventilation and room-conditioning systems (Modules M5-1, M5-4)*

EN ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 1: General principles and requirements (ISO 5167-1)*

EN ISO 5167-2, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 2: Orifice plates (ISO 5167-2)*

prEN 1751:2023 (E)

EN ISO 5167-3, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 3: Nozzles and Venturi nozzles (ISO 5167-3)*

EN ISO 5167-4, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 4: Venturi tubes (ISO 5167-4)*

3 Terms, definitions, symbols and suffixes

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 12792 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp/ui>

3.2 Symbols

The symbols used in this document are given in Table 1.

Table 1 — Symbols

Symbol	Quantity	Unit
A	Internal cross-sectional area of duct	m^2
C_D	Coefficient of discharge	-
D_e	Equivalent hydraulic diameter Circular ducts: $\sqrt{\frac{4A}{\pi}}$ Square/Rectangular ducts: $\frac{2ab}{a+b}$	m
p	Absolute pressure	Pa
p_a	Atmospheric pressure	Pa
p_d	Velocity pressure $1/2 \rho v^2$	Pa
p_t	Stagnation or absolute total pressure	Pa
p_s	Static gauge pressure ($p - p_a$)	Pa
Δp_s	Pressure difference across the damper or valve under test	Pa
Δp	Flow meter differential pressure	Pa
Δp_t	Conventional total pressure difference for an air density of $1,2 \text{ kg}\cdot\text{m}^{-3}$ at the inlet to the damper or valve under test	Pa
q_v	Volume rate of air flow at the flow meter	$\text{l}\cdot\text{s}^{-1}$
q_{vL}	Leakage volume rate of air flow	$\text{l}\cdot\text{s}^{-1}$

Symbol	Quantity	Unit
q_{vLBA}	Closed blade air leakage factor, volume rate of air flow per unit duct cross-sectional area	$l \cdot s^{-1} \cdot m^{-2}$
q_{vLCA}	Case air leakage factor, volume rate of air flow per reference casing area (which is taken as a perimeter of the damper multiplied by an equivalent length of 1 m)	$l \cdot s^{-1} \cdot m^{-2}$
v	Velocity	$m \cdot s^{-1}$
s	Position of damper setting	%, α or m
T	Torque	N·m
U	Thermal transmittance coefficient	$W \cdot K^{-1} \cdot m^{-2}$
q	Temperature	°C
ρ	Air density	$kg \cdot m^{-3}$
ξ	Pressure loss coefficient	-

3.3 Suffixes

The following suffixes shall be used with the symbols given in Table 1.

- 1 is the inlet of the damper or valve under test;
- 2 is the outlet of the damper or valve under test;
- u is the measuring point upstream of the flow meter;
- n is the value at a selected point of the flow rate/static pressure curve.

4 Instrumentation

4.1 Air flow rate measurement

4.1.1 The air flow rate shall be measured using instruments in accordance with EN ISO 5167-1, EN ISO 5167-2, EN ISO 5167-3 and EN ISO 5167-4, or other instruments which have equivalent calibrated performance.

4.1.2 Air flow meters shall have a minimum calibration accuracy of $\pm 2,5$ % over the whole range.

NOTE If necessary, flow meters can be calibrated *in situ* by means of the Pitot static tube traverse technique described in ISO 3966.

4.1.3 Flow meters shall be checked at intervals as appropriate but not exceeding 12 months. This check can take the form of one of the following:

- a dimensional check for all flow meters not requiring calibration;
- a calibration over their full range using the original method employed for the initial calibration of meters calibrated *in situ*;

prEN 1751:2023 (E)

— a check against a flow meter which is compliant with flow meter specifications according to EN ISO 5167-1, EN ISO 5167-2, EN ISO 5167-3 or EN ISO 5167-4 as appropriate.

4.1.4 Leakage air flow meters shall have a minimum indicated accuracy according to the ranges in Table 2.

Table 2 — Accuracy of leakage air flow meters

Range $l \cdot s^{-1}$	Accuracy of measurement
Up to and including 0,018	$\pm 0,0009 l \cdot s^{-1}$
More than 0,018	$\pm 5 \%$

NOTE Alternatively, other devices such as variable area, flow-rate meters or integrating air flow meters of the positive displacement type can be used if calibrated in accordance with 4.1.3 c).

4.2 Pressure measurement

4.2.1 Pressure in the duct shall be measured by means of a liquid-filled calibrated manometer or any other device conforming to 4.2.2.

4.2.2 The resolution shall not be greater than the characteristics listed for the accompanying range of manometers, given in Table 3.

Table 3 — Resolution for the ranges of manometers

Range Pa	Resolution Pa
Up to and including 50	0,1
From 50 to 250	1
From 250 to 500	5,0
Above 500	25,0

4.2.3 The measured value of differential pressure should be greater than 10 % of the range of the measurement device used.

EXAMPLE With a micromanometer with a range from 0 to 1000 Pa the minimum differential pressure to be measured is 100 Pa.

4.2.4 The uncertainty of calibration standards shall be:

- for instruments with a measuring range up to 100 Pa, equal or better than $\pm 0,5$ Pa; and
- for instruments with a measuring range over 100 Pa, equal or better than $\pm 0,5 \%$ of reading.

4.3 Temperature measurement

Measurement of temperatures shall be conducted, for example, by means of mercury-in-glass thermometers, resistance thermometers or thermo-couples. Instruments shall have a resolution better than 0,5 K and be calibrated to an accuracy of $\pm 0,25$ K.

5 Leakage tests

5.1 General

Damper leakage performance could vary depending on whether the damper is subjected to positive or negative pressure. The manufacturer shall specify the pressure conditions for test.

5.2 Damper and valve leakage

5.2.1 Measurements of damper and/or valve leakage in the shut-off position shall be made under conditions of actual operation with the damper or valve closed against the maximum recommended static pressure conditions. Since small flow rates still exist during the closing of the damper and valve condition, the method used to measure these small flow rates will introduce a high-pressure loss when the damper or valve is open. This precludes a high-pressure difference in the inlet duct until the damper or valve approaches the closed position.

As the valve is closed and the flow rate decreases, the inlet static pressure difference will increase to approximately the recommended inlet pressure.

5.2.2 The damper or valve shall be cycled 10 times between the fully open and fully closed positions of the actuator at the start of each test (before starting the fan of the air supply system) concluding with the damper or valve in the fully closed position.

NOTE In all cases in the closed position, the damper drive is subject to a torque rating recommended by the manufacturer.

5.2.3 The damper or valve under test shall be connected to a test installation similar to that shown in Figure 1a) or Figure 1b). A suitable air supply shall be connected to the duct. In both cases, care shall be taken to ensure that duct joints are sealed to manufacturer's instructions.

5.2.4 The supply air pressure shall be increased to the maximum recommended inlet pressure difference in accordance with the appropriate classification from Figure C.1 and Figure C.2. The damper or valve is then modulated to the open position, without any additional adjustment of the supply air system flow rate, and then returned to the closed position either manually or by the means provided by the manufacturer. The supply air pressure shall be adjusted as the damper or valve nears closure, to maintain the recommended inlet static gauge pressure difference within ± 5 %. The above process is to ensure that the closed condition is as representative as possible of typical operation with airflow present.

NOTE The air flow measuring device for leakage measurement may have to be disconnected in the above process to avoid any potential damage to the device for measuring low air rates.

5.2.5 Report the damper or valve air leakage factor as a function of test pressure difference in the closed position. Also include classification (see Annex C).

5.3 Casing leakage

5.3.1 The test installation shall be similar to that shown in Figure 2 a) or Figure 2 b). The damper or valve casing outlet shall be sealed according to the instructions of the manufacturer. The damper or valve shall be set to the open position.

prEN 1751:2023 (E)

5.3.2 The test of the casing shall be carried out by subjecting the casing to its maximum recommended pressure in accordance with 5.2.4. The pressure shall be maintained for 60 s before the measurement of leakage commences.

5.3.3 Report the test results as casing air leakage factor as a function of test pressure. Also include classification (see Annex C).

6 Flow rate and pressure tests**6.1 Ducted method**

6.1.1 This method applies for dampers or valves mounted within a duct.

6.1.2 The damper or valve under test shall be mounted in a system comprising of a fan, a means of controlling air flow rate, a flow rate measuring system and test ducts (see Figure 3).

6.1.3 The test ducts shall have cross-sectional dimensions equal to the nominal size of the unit under test or to the manufacturer's instructions. The upstream test duct shall be straight for a minimum length of $5D_{e1}$. The downstream test duct shall be straight for a minimum length of $5D_{e2}$ or 2 m, whichever is the greatest.

6.1.4 Flow straighteners shall be fitted in the upstream test duct at a position $3D_{e1}$ from the connection to the damper or valve under test or, alternatively a straight duct shall be used without a flow straightener.

6.1.5 The velocity profile near the upstream connection to the damper or valve under test shall be uniform to 10 % of the mean value over the test duct cross-section, excluding the area within 15 mm of the duct walls. Carry out a velocity survey at ten equally spaced intervals along a pair of mutually perpendicular axis to confirm that the velocity profile is within these limits. Wire mesh screens located no closer than $2,5D_{e1}$ to the upstream connection to the damper or valve under test can, if necessary, be incorporated to achieve a suitably uniform velocity profile.

6.1.6 The upstream duct static gauge pressure (p_{s1}) shall be measured by means of four static pressure tappings $1,5D_{e1}$ from the upstream connection to the damper or valve under test. For a rectangular duct, these pressure taps shall be at the centre of each side and, for a circular duct, equally spaced around the circumference. Connect the pressure taps to form a piezometric ring. Alternatively, use a single Pitot static probe.

6.1.7 The air temperature shall be measured at the flow meter and at a position $2,5D_{e1}$ upstream of the damper or valve under test, and, during the test the temperature variation at the same station shall not be greater than 3 K.

6.1.8 The damper or valve shall be set in its fully open position and tests shall be carried out as follows:

- use a minimum of five air flow rates distributed evenly throughout the total flow range, and choose the lowest air flow rate so that the test duct static pressure is not less than 10 Pa;
- remove the damper or valve from the test installation and connect the upstream test duct directly to the downstream test duct. Repeat the procedure in 6.1.8 at five air flow rates covering the same flow rate range used in 6.1.8.