



~~Designation: C615/C615M-10~~ Designation: C615/C615M – 11

Standard Specification for Granite Dimension Stone¹

This standard is issued under the fixed designation C615/C615M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

1. Scope

~~1.1 This specification covers the material characteristics, physical requirements, and sampling appropriate to the selection of granite for general building and structural purposes.~~

1.1 This specification covers the material characteristics, physical requirements, and sampling appropriate to the selection of granite for general building and structural purposes. Refer to Guides C1242 and C1528 for the appropriate selection and use of granite dimension stone.

1.2 Granite dimension stone shall include stone that is sawed, cut, split, or otherwise finished or shaped, and shall specifically exclude molded, cast, or otherwise artificially aggregated units composed of fragments, crushed and broken stone.

1.3 The values stated in either SI units or inch-pound units are to be regarded separately as standard. The values stated in each system may not be exact equivalents; therefore, each system shall be used independently of the other. Combining values from the two systems may result in non-conformance with the standard.

2. Referenced Documents

2.1 *ASTM Standards:*²

C97/C97M [Test Methods for Absorption and Bulk Specific Gravity of Dimension Stone](#)

C99/C99M [Test Method for Modulus of Rupture of Dimension Stone](#)

C119 [Terminology Relating to Dimension Stone](#)

C170/C170M [Test Method for Compressive Strength of Dimension Stone](#)

C241/C241M [Test Method for Abrasion Resistance of Stone Subjected to Foot Traffic](#)

C1242 [Guide for Selection, Design, and Installation of Dimension Stone Attachment Systems](#)

C880/C880M [Test Method for Flexural Strength of Dimension Stone](#)

~~C1353 [Test Method for Abrasion Resistance of Dimension Stone Subjected to Foot Traffic Using a Rotary Platform, Double-Head Abraser](#)~~
C1353 [Test Method for Abrasion Resistance of Dimension Stone Subjected to Foot Traffic Using a Rotary Platform, Double-Head Abraser](#)

C1528 [Guide for Selection of Dimension Stone](#)

3. Terminology

3.1 *Definitions*—All definitions are in accordance with Terminology C119.

4. Classification

4.1 Granite dimension stone under this specification shall be granite used for:

4.1.1 Exterior and interior cladding of buildings and structures;

4.1.2 Curbstone, paving, and landscape features;

4.1.3 Structural components having established dimensions;

4.1.4 Grade separations and retaining walls; and

4.1.5 Monuments.

¹ This specification is under the jurisdiction of ASTM Committee C18 on Dimension Stone and is the direct responsibility of Subcommittee C18.03 on Material Specifications.

~~Current edition approved Sept. 1, 2010. Published October 2010. Originally approved in 1968. Last previous edition approved in 2003 as C 615-03. DOI:10.1520/C615-C615M-10.~~

Current edition approved Jan. 1, 2011. Published January 2011. Originally approved in 1968. Last previous edition approved in 2010 as C 615/C 615M-10. DOI:10.1520/C615_C615M-11.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.