



Designation: E 839 – 96

Standard Test Methods for Sheathed Thermocouples and Sheathed Thermocouple Material¹

This standard is issued under the fixed designation E 839; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

INTRODUCTION

Thermocouples are widely used in industry and they provide reliable service. However, if thermocouples fail in service, the results can range from negligible to life threatening. Often a loss of equipment, product, or operating time will result. The user should weigh the potential consequences of thermocouple failure when considering what tests should be performed. No tests are required by this document except those specifically ordered by the user. This document lists methods for testing sheathed thermocouples and thermocouple material but does not state criteria for acceptance. The acceptance criteria for the particular thermocouple, when subjected to the tests, are given in other ASTM standard specifications for that thermocouple. Examples from ASTM thermocouple specifications for acceptance criteria are given for many of the tests. These tabulated values are *not* necessarily those that would be required to meet these tests, but are given here as examples only.

1. Scope

1.1 These are test methods for sheathed thermocouple material and assemblies.

1.2 The tests are intended to ensure quality control and to evaluate the suitability of sheathed thermocouple material or assemblies for specific applications. Some alternative test methods to obtain the same information are given, since in a given situation an alternative test method may be more practical. Service conditions are widely variable and so it is unlikely that all the tests described will be appropriate for a given thermocouple application. A brief statement is made following each test description to indicate when it might be used.

1.3 The tests described herein include test methods to measure the following properties of sheathed thermocouple material and assemblies.

1.3.1 *Insulation Properties:*

1.3.1.1 Compaction

absorption method and tension method,

1.3.1.2 Thickness, and

1.3.1.3 Resistance—room temperature and elevated temperature.

1.3.2 *Sheath Properties:*

1.3.2.1 Integrity

water test (two test methods) and mass spectrometer,

1.3.2.2 Dimensions—length, diameter, and roundness,

1.3.2.3 Wall thickness,

1.3.2.4 Surface—gross visual, finish, defect detection by dye penetrant, and cold-lap detection by tension test,

1.3.2.5 Metallurgical structure, and

1.3.2.6 Ductility—bend test and tension test.

1.3.3 *Thermoelement Properties:*

1.3.3.1 Calibration,

1.3.3.2 Homogeneity,

1.3.3.3 Drift,

1.3.3.4 Thermoelement diameter, roundness, and surface appearance,

1.3.3.5 Thermoelement spacing,

1.3.3.6 Thermoelement ductility, and

1.3.3.7 Metallurgical structure.

1.3.4 *Thermocouple Assembly Properties:*

1.3.4.1 Dimensions

length, diameter, and roundness,

1.3.4.2 Surface—gross visual, finish, reference end seal, and defect detection by dye penetrant,

1.3.4.3 Electrical—continuity, loop resistance, and connector polarity,

1.3.4.4 Insulation resistance—room temperature, and elevated temperature,

1.3.4.5 Radiographic inspection,

1.3.4.6 Thermoelement diameter,

1.3.4.7 Thermal response time, and

¹ These test methods are under the jurisdiction of Committee E-20 on Temperature Measurement and are the direct responsibility of Subcommittee E20.04 on Thermocouples.

Current edition approved June 10, 1996. Published August 1996. Originally published as E 839 – 89. Last previous edition E 839 – 89.

1.3.4.8 Thermal cycle.

2. Referenced Documents

2.1 ASTM Standards:

- D 2771 Test Methods for Compaction Density of Electrical Grade Magnesium Oxide²
- E 3 Methods of Preparation of Metallographic Specimens³
- E 94 Guide for Radiographic Testing⁴
- E 112 Test Methods for Determining the Average Grain Size³
- E 142 Method for Controlling Quality of Radiographic Testing⁴
- E 165 Practice for Liquid Penetrant Examination⁴
- E 207 Method of Thermal EMF Test of Single Thermoelement Materials by Comparison with a Secondary Standard of Similar EMF-Temperature Properties⁵
- E 220 Method for Calibration of Thermocouples by Comparison Techniques⁶
- E 230 Specification for Temperature-Electromotive Force (EMF) Tables for Standardized Thermocouples⁵
- E 235 Specification for Thermocouples, Sheathed, Type K, for Nuclear or for Other High-Reliability Applications⁵
- E 344 Terminology Relating to Thermometry and Hydrometry⁵
- E 585 Specification for Sheathed Base-Metal Thermocouple Materials⁵
- E 608 Specification for Metal-Sheathed Base-Metal Thermocouples⁵
- E 780 Test Method for Measuring the Insulation Resistance of Sheathed Thermocouple Material at Room Temperature⁵
- E 988 Temperature-Electromotive Force (EMF) Tables for Tungsten-Rhenium Thermocouples⁵
- E 1129/E 1129M Specification for Thermocouple Connectors⁵

2.2 ANSI Standard

- B 46.1 Surface Texture⁷

3. Terminology

3.1 *Definitions*—The definitions given in Terminology E 344 shall apply to these test methods.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *bulk material length (BML), n*—a single length of thermocouple material (produced from the same raw material lot) after completion of fabrication resulting in sheathed thermocouple material.

3.2.2 *cold-laps, n*—sheath surface defects where the sheath surface has been galled and torn by a drawing die and the torn surfaces smoothed by a subsequent diameter reduction.

3.2.3 *insulation compaction density, n*—the density of a compacted powder is the combined density of the powder particles and of the voids remaining after the powder compac-

tion. Sometimes the insulation compaction density is divided by the theoretical density of the powder particles to obtain a dimensionless fraction of theoretical density as a convenient method to express the relative compaction.

3.2.4 *production run, n*—the quantity of BMLs (produced at one time and from the same material lot) that travel together continuously through the same processing steps, that is, assembly, size reduction, annealing, etc.

3.2.5 *raw material, n*—material components (tubing, insulators, and thermoelements) as received, prior to any manufacturing procedures.

3.2.6 *short range ordering, n*—the reversible short-ranged, order-disorder transformation in which the nickel and chromium atoms occupy specific (ordered) localized sites in the Type EP or Type KP thermoelement alloy crystal structure.

3.2.7 *thermocouple assembly, n*—the cut-to-length, finished assembly consisting of thermocouple material with thermoelements having one end joined in a measuring junction. The assembly has the sheath closed at the measuring end and has a moisture seal at the reference junction end of the sheath. The assembly does not include a reference junction but may include a thermocouple connector, thermocouple extension, or compensating wire.

4. Summary of Test Methods

4.1 Insulation Properties:

4.1.1 *Compaction*—These tests ensure the insulation is compacted enough (1) to prevent the insulation from shifting during use with the possibility of the thermoelements shorting to each other or to the sheath and (2) to have good heat transfer between the sheath and the thermoelements.

4.1.2 *Resistance*—The insulation must be free of moisture and contaminants that would compromise the voltage-temperature relation or shorten the useful life of the sheathed thermocouple. Measurement of insulation resistance is a useful way to detect the presence of unacceptable levels of impurities in the insulation.

4.2 Sheath Properties:

4.2.1 *Integrity*—These tests ensure (1) the sheath will be impervious to moisture and gases so the insulation and thermoelements will be protected, (2) surface flaws and cracks that might develop into sheath leaks are detected, and (3) the sheath walls are as thick as specified.

4.2.2 *Dimensions*—If the sheath must fit in a fixed space the dimensions of length, diameter, and sheath roundness must be determined.

4.2.3 *Ductility*—If the sheath must be bent during installation or service, then the sheath must be ductile enough to bend the required amount without breaking or cracking.

4.3 Thermoelement Properties Service Life:

4.3.1 *Calibration*—These tests ensure the temperature (emf) relation corresponds to the standard values both initially and after a short time of heating to service temperatures.

4.3.2 *Size*—The thermocouple sheath and thermoelement sizes are related to service life, and the thermoelement spacing is related to possible low insulation resistance or shorting.

4.3.3 *Ductility*—Thermoelement ductility is necessary if the thermocouple assembly must be bent during installation or service.

² Annual Book of ASTM Standards, Vol 10.01.

³ Annual Book of ASTM Standards, Vol 03.01.

⁴ Annual Book of ASTM Standards, Vol 03.03.

⁵ Annual Book of ASTM Standards, Vol 14.03.

⁶ Discontinued. See 1994 Annual Book of ASTM Standards, Vol 14.03.

⁷ Available from American National Standards Institute, 11 W. 42nd St., 13th Floor, New York, NY 10036.

4.4 *Thermocouple Assembly Properties*—The criteria listed above must apply to both thermocouple assemblies and to bulk sheathed material, and in addition the following tests are important for thermocouple assemblies.

4.4.1 *Continuity*—The loop continuity test assures that the thermocouple assembly has, at least, a completed circuit.

4.4.2 *Resistance*—The loop resistance test can detect shorted or damaged thermoelements.

4.4.3 *Polarity*—The connector polarity test indicates whether the connector is correctly installed.

4.4.4 *End Seal*—The reference end seal, if faulty, may allow the contamination of the insulation with moisture or gases.

4.4.5 *Radiography*—Radiographic examination of the junction and sheath closure weld can indicate faulty junctions and sheath closures that will lead to early failure. The internal dimensions can also be measured from the radiograph.

4.4.6 *Response Time*—The thermal response time gives an indication of the quickness with which an installed thermocouple will signal a changing temperature under the test conditions.

4.4.7 *Thermal Cycle*—The thermal cycle test will offer assurance that the thermocouple will not have early failure because of strains imposed from temperature transients.

5. Significance and Use

5.1 These tests provide a description of test methods for use in ASTM specifications that establish certain acceptable limits for characteristics of thermocouple assemblies and thermocouple materials.

5.2 The intended use of these test methods is to define the methods by which the characteristics shall be determined.

5.3 The usefulness and purpose of the included tests are given for the category of tests.

6. General Requirements

6.1 All the inspection operations are to be performed under clean conditions (that is, conditions that will not degrade the insulation, sheath, or thermoelements), including the use of suitable gloves when appropriate.

6.2 During all process steps in which insulation is exposed to ambient atmosphere, the air must be clean, with less than 50 % relative humidity, and at a temperature between 20 and 26°C (68 and 79°F).

6.3 All samples which are tested shall be identified by material code, and shall be traceable to a production run.

7. Insulation Properties

7.1 *Insulation Compaction Density*—The thermal conductivity of the insulation, as well as the ability of the insulation to lock the thermoelements into place, will be affected by the insulation compaction density.

7.1.1 Test Methods D 2771 is a test on representative samples to measure the compaction density of electrical grade magnesium oxide. Two methods are used to find the density: Test Method A for water displacement and Test Method B for oil absorption. Both Test Methods A and B require precision weighing and careful procedure.

7.1.2 A direct measurement test of insulation compaction density is applicable if a representative sample can be sec-

tioned so the sample ends are perpendicular to the sample length and the sheath, thermoelements, and insulation form a smooth surface free of burrs. The test procedure is to:

7.1.2.1 Weigh the sample section,

7.1.2.2 Measure the sheath diameter and length with a micrometer,

7.1.2.3 Separate wires, sheath, and insulation by use of an air abrasive tool (air-driven abrasive particles) to remove the insulation from the sample,

7.1.2.4 Weigh the thermoelements and sheath, and

7.1.2.5 Determine the sheath and thermoelements densities either by experiment or from references.

7.1.3 The fraction of the maximum theoretical insulation density is determined as follows:

$$(A - B)/\{[0.785 C^2 D - (E/F + G/H)]J\} \tag{1}$$

where:

A = total specimen mass, g or lb,

B = sheath and wires mass, g or lb,

C = sheath diameter, mm or in.,

D = specimen length, mm or in.,

E = sheath mass, g or lb,

F = sheath density, kg/m³ or lb/in.³,

G = wires mass, g or lb,

H = wires density (averaged density if applicable), kg/m³ or lb/in.³, and

J = maximum theoretical density of the insulation, kg/m³ or lb/in.³.

7.2 *Insulation Compaction, Tension Test Method*—This is a destructive test on representative samples that determines if the thermoelements are locked together with the sheath by the compacted insulation, but the test does not measure the compaction density per se. This tension test is the complement of the tests of 7.1 that measure the insulation compaction density but does not establish that the thermoelements are locked to the sheath (since there is no established minimum compaction density where locking begins). This test can be performed concurrently with the sheath ductility test (8.5.3).

7.2.1 Cut a test sample about 0.5 m (20 in.) long from one end of a bulk material length and strip both ends of the sample to expose a minimum of 10 mm (0.4 in.) of the thermoelements.

7.2.2 Without sealing the exposed insulation, clean the thermoelements (wires) of insulation to provide good electrical contact and twist the wires together on one end to form a thermocouple loop (Fig. 1).




FIG. 1 Specimen of Sheathed Thermocouple Material Prepared for Tension Testing

7.2.3 Measure the electrical resistance of the thermocouple loop to $\pm 0.01 \Omega$ and measure the length of the thermocouple loop to establish the electrical resistance per unit length.

7.2.4 Place the test sample in the tension testing machine so that (1) the grips clamp only on the sample sheath, (2) the force will be applied longitudinally on the sheath, and (3) there is at least a 0.25-m (10-in.) distance between the grips where the force will be applied (Fig. 2).

7.2.5 Attach an ohmmeter capable of measuring $\pm 0.01 \Omega$ to the exposed thermoelements and measure the resistance with no tension force applied; also measure the distance between the tension tester grips to establish the initial length, L_0 , of the test sample that will be elongated.

7.2.6 Calculate the initial resistance, R_0 , of the test sample section that will be elongated, using the unit length electrical resistance obtained in 7.2.3.

7.2.7 Make a simultaneous record of the electrical resistance and the elongation of the sheath while stretching the test sample until the thermoelements break.

7.2.8 Examine the exposed ends of the thermoelements to see whether they have been drawn into the insulation during the elongation; any shortening of the exposed ends indicates low compaction of the insulation.

7.2.9 Plot the fractional change of resistance ($\Delta R/R_0$) versus the fractional change of length ($\Delta L/L_0$). The slope of the plot reveals if the thermoelements were locked to the sheath throughout the plastic deformation of the sheath and, if not, where the thermoelements began to elongate in a different manner than the sheath. Examples of criteria to evaluate the insulation locking are given in X1.9

7.3 *Insulation Thickness Measurement*—Determine the dimension C of Fig. 3 from a metallographic mount (prepared by Methods E 3) of a polished cross section of the thermocouple using a microscope having at least a $60\times$ magnification and a 2.5-mm (0.1-in.) reticle graduated in at least 0.03-mm (0.001-in.) increments. Sampling frequency, measurement tolerance, and insulation thickness shall be as stated in the standard specification relevant to the subject thermocouple. Examples of specifications for the insulation thickness are given in the Measuring Junction Configuration section of Specification E 608 for the junction area, in Table 1 of Specification E 585 for base-metal thermocouples, and Tables X1.1 and X1.2.

7.4 *Insulation Resistance, Room Temperature*—Measure the insulation resistance of sheathed thermocouple material at room temperature using Test Method E 780. Sampling frequency and insulation resistance shall be as agreed upon between the purchaser and the producer. See Table X1.3.






FIG. 2 The Thermocouple Positioned In The Tension Tester



(a) Class 1 Grounded Thermocouple Junction



(b) Class 2 Insulated Thermocouple Junction

FIG. 3 Sheathed Thermocouple Assembly

7.5 *Insulation Resistance, Elevated Temperatures*—The purpose of this test is to determine if the thermocouple insulation will be adequate for high temperature use of the thermocouple (**Caution**—See Note 1). Sampling frequency shall be as stated in the standard specification relevant to the subject thermocouple.

NOTE 1—**Caution:** Some thermocouples, such as Type E or K, may have changes in thermoelectric homogeneity produced by exposure to elevated temperatures; therefore, this test should be regarded as possibly destructive.

7.5.1 *Thermocouple Assembly*—Measure the electrical resistance between the thermoelements and the sheath for a Class 2 (insulated junction) finished thermocouple assembly (Fig. 3) using the technique of Test Method E 780 (Resistance Measurement). Insert the finished thermocouple assembly, measuring the junction end first, into a furnace or constant temperature bath to a depth that will yield maximum temperature stability (example: 20 sheath diameters). Then, the thermocouple can be heated to the maximum temperature of intended use.

7.5.1.1 The minimum acceptable insulation resistance between the thermoelements and the sheath, while the test specimen is at the specified elevated temperature, shall be as stated in the standard specification relevant to the subject thermocouple assembly.

7.5.2 *Bulk Material*—Insulation resistance tests on sheathed thermocouple material at elevated temperatures have the purpose of determining (1) if excess moisture is in the insulation of the bulk material or (2) if the insulation contains excess impurities other than moisture, which will affect the insulation resistance at high temperatures.

7.5.2.1 *Elevated Temperature, Moisture and Impurities Combined*—The steps listed for this test are intended to evaluate the combined effects of insulation impurities on the elevated temperature resistance of Type K or N bulk material.

NOTE 2—**Caution:** Improper technique in constructing thermocouple

assemblies can introduce additional insulation impurities.

(1) Cut a sample of approximately 1.2 m (4 ft) in length from the end of the bulk material. Strip both ends of the sample about 25 mm (1 in.) to expose the thermoelements and at once seal the ends with an insulating sealant such as epoxy to prevent further moisture adsorption. Wind the center section of the sample around a 25-mm (1-in.) mandrel to form three coils, as shown in Fig. 4. The coils use about 0.3 m (1 ft) of the sample.

(2) Install a suitable connector on one end of the coil and test the room temperature insulation resistance as described in 7.4.

(3) Insert the sample coil into a furnace and bring the coil temperature to $1000 \pm 10^\circ\text{C}$. The sealed ends of the sample should be at about room temperature. Allow the sample to stabilize at 1000°C for at least 15 min, as measured by the furnace monitor thermocouple.

(4) Measure the insulation resistance at the voltage and range appropriate for readability and the thermocouple sheath size. The charge time of the megohm tester should be 1 min before the measurement is recorded.


(5) Record the insulation resistance between each thermoelement, and from each thermoelement to the sheath.

7.5.2.2 *Elevated Temperature, Contaminants Other than Moisture*—The steps listed for this test evaluate the effects of impurities in the insulation (other than moisture) on the insulation resistance of the bulk material at elevated temperatures.

NOTE 3—**Caution:** Improper practice in forming the junction and sheath closure may change the insulation resistance of the thermocouple assembly.

(1) Cut a sample about 0.6 m (2 ft) long from the end of the bulk material to be tested. Strip both ends about 25 mm (1 in.) to expose the thermoelements.

(2) Weld extension wires to each of the thermoelements and to the sheath, as shown in Fig. 5. The extension wires need not be the same composition as the thermoelements, but the extension wire must withstand the temperature of the test and



NOTE 1—The ends of the test specimen are not sealed, allowing water vapor to escape before measuring the insulation resistance

FIG. 5 High Temperature Insulation Resistance Test, Insulation Contamination Other Than Moisture

the same composition extension wire should be used for all connections to the sample.

(3) Wind the center section of the sample around a 25-mm (1-in.) mandrel to form three coils, as shown in Fig. 5. The coils use about 0.3 m (1 ft) of the sample.

(4) Install a suitable terminal strip or connector to the extension wires, as shown in Fig. 5 and test the room temperature insulation resistance as described in 7.4.

(5) Insert the sample coil into a furnace so that the extension wires are in the same uniform temperature zone as the coil and bring the coil temperature to $1000 \pm 10^\circ\text{C}$. Allow the sample to stabilize at 1000°C for at least 15 min, as measured by the furnace monitor thermocouple.


(6) Measure the insulation resistance at the voltage appropriate for the thermocouple size. The charge time of the megohm tester should be 1 min before the measurement is recorded.

(7) Record the resistance between each thermoelement, and from each thermoelement to the sheath.

8. Sheath Properties

8.1 *Sheath Integrity*—Leakage of air or moisture through the sheath can be detrimental to the life and local homogeneity of the sheathed thermoelement. Penetrations of the sheath may be caused by holes left during the fabrication of the sheath tubing, cracks due to welding, holes because of incomplete closures at either of the measurement ends, or by other mechanical damage. Two major methods, water penetration and mass spectrometer measurements of helium penetration, are commonly used for assessing sheath integrity. The mass spectrometer method is the most sensitive and the only one that can be used with Class 1 (grounded junction) thermocouples. These sheath integrity test methods are given in order of increasing test sensitivity and difficulty.

8.1.1 *Fast Sheath Integrity Test Using Water*—This test is usually a test on bulk material using a less sensitive ohmmeter and a lower voltage test than the test used in 8.1.2; it is the fastest test, intended to detect the larger sheath penetrations.



NOTE 1—The ends of the test specimen are sealed with epoxy to prevent water vapor from being adsorbed or desorbed during the test.

FIG. 4 High Temperature Insulation Resistance Test Assembly to Test for Moisture Plus Impurities

8.1.1.1 Strip one end of the length to bare a 6 mm (0.25 in.) length of thermoelements.

8.1.1.2 Check the opposite end of the length for any evidence of shorting of thermoelements to the sheath.

8.1.1.3 Seal the open ends with an insulating sealant to prevent the absorption of water vapor.

8.1.1.4 Using a direct-current (dc) ohmmeter, reading to at least 20 M Ω , connect the ground lead to the cable sheath and the other test lead to either thermoelement.

8.1.1.5 Then immerse by using a rag saturated with cold tap water. Wipe along the length of the sheath from the end opposite the instrument connection slowly with a light pressure applied to the sheath.

8.1.1.6 As an alternative, immerse the entire length (in a coil if necessary) in tap water, except for 2 %, but not to exceed 0.3 m (1 ft), at each end.

8.1.1.7 With the ohmmeter range selection switch on the most sensitive readable range, interpret any noticeable reduction of insulation resistance as evidence of a leak in the sheath.

8.1.1.8 The leaking section may be cut from the length of material and this test repeated to determine acceptability of the remaining portion of the finished length.

8.1.2 *Basic Sheath Integrity Test Using Water.*

8.1.2.1 Strip one end of the sheathed material to expose a minimum of 6 mm (0.25 in.) of the thermoelements.

8.1.2.2 Check the opposite end of the length for any evidence of shorting of thermoelements to the sheath.

8.1.2.3 Seal the open ends with an insulating sealant to prevent the absorption of water vapor.

8.1.2.4 Using a megohmmeter on the most sensitive readable range with an applied voltage at a minimum of 10 V dc and at a maximum of 50 V dc, measure the insulation resistance between the sheath and thermoelements.

8.1.2.5 Then, using a clean rag saturated with unheated tap water (water dripping from the rag), wipe along the length of the sheath from the end opposite the instrument connection at a rate between 40 to 50 mm/s (7.9 to 9.8 ft/min) applying a light pressure to the rag circumferentially around the sheath thereby forcing the water into and through any fissure in the sheath wall. Set the material aside for 30 min after application of the water.

8.1.2.6 A more discriminating method to ensure detecting exceptionally small leaks is to immerse the entire length (coiled if necessary), including welded measuring junction end, in unheated tap water. Allow up to 2 %, but no more than 0.3 m (1 ft) of length on ends with insulating sealant to remain out of the water. Leave the material immersed in the water for a minimum of 16 h.

8.1.2.7 After the exposure to the water as required in 8.1.2.5 or 8.1.2.6, repeat the insulation resistance test of 8.1.2.4. Interpret a noticeable reduction in insulation resistance immediately upon exposure to the water, or after completion of either technique selected, as evidence of a leak in the sheath.

8.1.2.8 A technique to locate the leak (if a leak is found) is to leave the voltage applied while the sheathed material is exposed to the water. This will often pinpoint the location of a leak by emitted bubbles due to the electrolysis of water.

8.1.2.9 The leaking section of the length of material may be removed and this test repeated to determine acceptability of the remaining portion of the finished length.

8.1.3 *Sheath Integrity, Mass Spectrometer Method:*

8.1.3.1 Test the sheath and measuring end closures as follows: Weld shut the open ends of the sheath or otherwise hermetically seal. Wipe the test item clean with a solvent-saturated material. Recommended solvents are alcohol, methyl ethyl ketone, or methyl isobutyl ketone (see Note 4). Pressurize the sheath externally with helium to at least 7.0 Mpa (66 atm) for a period of 5 to 10 min. Wipe the test item again with a solvent-saturated tissue and insert within 2 h into a test chamber. Evacuate the interior of this chamber to a pressure of 7 kPa (50 mm Hg) or less, and test for the presence of helium using a mass spectrometer-type helium-leak detector. Monitor the test chamber for a time period of at least three times the *System Time Response* (8.1.3.3). Take an indication of helium leakage of 6×10^{-6} standard cubic centimeters per second as evidence of a leak.

NOTE 4—**Caution:** These solvents can be considered as hazardous and possibly toxic. Refer to applicable Material Safety Data Sheets.

8.1.3.2 Determine the sensitivity of the leak detector combined with the evacuated test chamber, hereafter called the system, using a standard leak or a calibrated leak of known leak rate before and after each test, or group of tests, on a given day. If the second sensitivity test shows a system sensitivity less than the minimum value specified below, repeat all intervening leak tests on the item being tested.

8.1.3.3 Introduce the standard or calibrated leak into the system at the point farthest from the leak detector. The mass spectrometer-type helium-leak detector shall demonstrate a minimum system sensitivity of 3×10^{-9} standard cubic centimeters of helium per second per smallest scale division on the leak detector meter. A leak rate of 6×10^{-9} standard cubic centimeter of helium per second shall produce an additional deflection on the leak-detector meter at least equal to the deflection produced by the combined background and noise signal from the leak detector itself. Perform the system sensitivity test as follows:

(1) With the standard, or calibrated leak at the location described above, introduce the standard leak into the system.

(2) Determine the time required for the leak detector to indicate a constant-leak rate (caused by the standard leak). The *System Time Response* is defined as the time required to obtain the constant leak-detector indication.

(3) Note the constant-leak rate, and use this value to determine the system sensitivity.

8.2 *Sheath Dimensions*—The sheath dimension tests will apply to either bulk material or completed thermocouple assemblies.

8.2.1 *Sheath Length*—Measure the thermocouple assembly length while the thermocouple assembly is laying straight on a level surface. Gentle axial tension may be applied to the thermocouple assembly to straighten sheath curvature during measurement. Make the measurements from the tip of the sheath closure to the start of the connector, the moisture seal,