
INTERNATIONAL STANDARD



Second edition 2019-05

Measurement of radioactivity in the environment — Air: Radon-222 —

Part 9:

Test methods for exhalation rate of building materials

Mesurage de la radioactivité dans l'environnement — Air: Radon 222 —

Partie 9: Méthode de détermination du flux d'exhalation des matériaux de construction

ISO 11665-9:2019

https://standards.iteh.ai/catalog/standards/iso/c37c7814-b04c-4c6c-ab4b-7056f35d9a54/iso-11665-9-2019



Reference number ISO 11665-9:2019(E)

iTeh Standards (https://standards.iteh.ai) Document Preview

ISO 11665-9:2019

https://standards.iteh.ai/catalog/standards/iso/c37c7814-b04c-4c6c-ab4b-7056f35d9a54/iso-11665-9-2019



COPYRIGHT PROTECTED DOCUMENT

© ISO 2019

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office CP 401 • Ch. de Blandonnet 8 CH-1214 Vernier, Geneva Phone: +41 22 749 01 11 Fax: +41 22 749 09 47 Email: copyright@iso.org Website: www.iso.org

Published in Switzerland

Contents

Page

Introduction 1 Scope 1 1 Scope 1 2 Normative references 1 3 Terms, definitions and symbols 1 3.1 Terms and definitions 1 3.2 Symbols 2 4 Principle 4 5 Reagents and equipment 4 5.2 Equipment for sample preparation 5 5.3 Equipment for sample preparation 5 5.4 Test bench 6 6 Building material test sample preparation 7 6.1 General 7 6.2 Indemssions 6 6.2.1 General 6 6.3.2 Fluid intermediate materials 1 6.3.1 End products 6 6.3.2 Fluid intermediate materials 1 7.1 General 5 7.2 Set up of test bench 5 7.3 General 5 7.4 Cheeral 5 7.5 Set up of test bench 5	Fore	word	iv
2 Normative references 1 3 Terms, definitions and symbols 1 3.1 Terms and definitions 1 3.2 Symbols 1 4 Principle 4 5 Reagents and equipment 4 5.1 Reagents 4 5.2 Equipment for sample preparation 4 5.3 Equipment for procedure 4 5.4 Test bench 6 6 Building material test sample preparation 6 6.1 General 6 6.2 Incernal 6 6.3 Conditioning 6 6.3.2 Fluid intermediate materials 6 6.3.2 Fluid intermediate materials 6 7 Measurement 6 7.1 General 6 7.2 Set up of test bench 7 7.3 Bearriantion of anount of adsorbent material 10 7.4 General 11 7.5 Set up of test bench 12 7.2.1 Choice of volume flow	Intro	duction	
3 Terms, definitions and symbols 3.1 3.1 Terms and definitions 3.2 3.2 Symbols 3.2 4 Principle 4 5 Reagents and equipment 4 5.2 Equipment for sample preparation 5 5.3 Equipment for procedure 5 6 Building material test sample preparation 5 6.1 General 6 6.2 Number and dimensions 6 6.2.1 General 6 6.2.2 End product 6 6.3 Conditioning 6 6.3 Fluid intermediate materials 6 7 Measurement Octament Provider 7.2 Set up of test bench 7 7.2 Set up of test bench 7 7.2.3 Determination of minimum desorption duration 11 7.2.3 Determination of adsorbent material 11 7.3 Measurement procedure 11 8 Expression of results 11 8.1 General 11	1	Scope	1
3.1 Terms and definitions 1 3.2 Symbols 1 3.2 Symbols 1 3.2 Symbols 1 3.2 Symbols 1 5 Reagents and equipment 1 5.1 Reagents 1 5.2 Equipment for procedure 1 5.3 Fauipment for procedure 1 6.4 Test bench 1 6.1 General 1 6.2 Number and dimensions 1 6.2.1 General 1 6.3.2 End product 1 6.3.3 Fluid intermediate materials 1 6.3.4 End products 1 6.3.2 Fluid intermediate materials 1 7 Measurement 1 7.1 General 1 7.2 Set up of test bench 1 7.2.3 Determination of mount of adsorbent material 1 7.2.4 LSC procedure 11 7.3 Determination of mount of adsorbent material 11	2 Normative references		
5 Reagents and equipment 4 5.1 Reagents 4 5.2 Equipment for sample preparation 5 5.3 Equipment for procedure 5 6 Building material test sample preparation 5 6.1 General 5 6.2 Number and dimensions 5 6.2.1 General 5 6.2.2 End product 5 6.3.3 Conditioning 5 6.3.4 Fluid intermediate materials 5 6.3.1 End products 5 6.3.2 Fluid intermediate materials 5 7 Measurement 5 7.2 Set up of test bench 5 7.2.3 Determination of amount of adsorbent material 11 7.2.3 Determination of minimum desorption duration 11 7.2.3 Determination of minimum desorption duration 11 7.3 Measurement procedure 11 8.4 General 12 8.5 Detection limit 12 8.4 Precision threshold	3	3.1 Terms and definitions	
5.1 Reagents 4 5.2 Equipment for sample preparation 5 5.4 Test bench 6 6 Building material test sample preparation 7 6.1 General 7 6.2 Number and dimensions 6 6.2.1 General 6 6.2.2 End product 6 6.3.3 Fluid intermediate materials 6 6.3.4 End products 6 6.3.2 Fluid intermediate materials 6 6.3.1 End products 6 6.3.2 Fluid intermediate materials 6 7.1 General 6 7.2 Set up of test bench 7 7.2.3 Determination of amount of adsorbent material 11 7.2.3 Determination of minimum desorption duration 11 7.2.4 LSC procedure 11 7.3 Measurement procedure 11 8 Expression of results 12 8.1 General 12 8.2 Free exhalation rate 12 <t< td=""><td>4</td><td>Principle</td><td>4</td></t<>	4	Principle	4
6.1 General 5 6.2 Number and dimensions 6 6.2.1 General 6 6.2.2 End product 6 6.3.3 Conditioning 6 6.3.4 End products 6 6.3.5 Fluid intermediate materials 6 6.3.1 End products 6 6.3.2 Fluid intermediate materials 6 7 Measurement 6 7.1 General 7 7.2 Set up of test bench 7 7.2.3 Determination of amount of adsorbent material 10 7.2.3 Determination of minimum desorption duration 10 7.3 Measurement procedure 11 8 Expression of results 12 8.1 General 12 8.2 Free exhalation rate 12 8.3 Standard uncertainty 12 8.4 Decision threshold 14 8.5 Detection limit 15 9 Test report 15 Annex A (informative) Method for	5	 5.1 Reagents. 5.2 Equipment for sample preparation. 5.3 Equipment for procedure. 	Z
6.3 Conditioning 6.3.1 End products 6.3.2 6.3.2 Fluid intermediate materials 6.3.2 Fluid intermediate materials 6.3.2 7 Measurement 6.3.2 6.3.2 6.3.2 6.3.2 7.1 General 6.3.2 6.3.2 6.3.2 6.3.2 7.1 General 6.3.2 6.3.2 6.3.2 6.3.2 7.2 Set up of test bench 6.3.2 6.3.2 6.3.2 6.3.2 7.2.1 Choice of volume flow rate 6.3.2 6.3.2 6.3.2 6.3.2 6.3.2 7.2.3 Determination of amount of adsorbent material 7.2.4 1.0.2 7.2.4 1.0.2 1.0.2 7.3 Measurement procedure 10.1.1 10.1.1 11.1 11.1 11.1 8 Expression of results 12.3 12.3 13.3 13.3 13.3 13.3 13.3 13.3 13.3 13.3 13.3 13.3 14.3 14.3 14.3 15.3 14.3 14.3 15.3 14.3 15.3 15.3 15.3 15.3 15.3 <td>6</td> <td> 6.1 General 6.2 Number and dimensions</td> <td>7 8 8 </td>	6	 6.1 General 6.2 Number and dimensions	7 8 8
7.1 General 2 7.2 Set up of test bench 2 7.2.1 Choice of volume flow rate 2 7.2.1 Choice of volume flow rate 2 7.2.1 Choice of volume flow rate 2 7.2.2 Determination of amount of adsorbent material 2 7.2.3 Determination of minimum desorption duration 10 7.2.4 LSC procedure 10 7.3 Measurement procedure 11 8 Expression of results 12 8.1 General 12 8.2 Free exhalation rate 12 8.3 Standard uncertainty 12 8.4 Decision threshold 14 8.5 Detection limit 15 9 Test report 15 Annex A (informative) Method for determination of free radon exhalation rate of mineral-based building materials — Total count determination using gamma-ray spectrometry 16 Annex B (informative) Method for determination of free radon exhalation rate of mineral-based building materials — Determination by nuclide-specific gamma-ray 26 Annex C (informative) Performance characteristics 36 <td></td> <td>6.3 Conditioning</td> <td></td>		6.3 Conditioning	
7.3 Measurement procedure 11 8 Expression of results 13 8.1 General 13 8.2 Free exhalation rate 13 8.3 Standard uncertainty 13 8.4 Decision threshold 14 8.5 Detection limit 15 9 Test report 15 Annex A (informative) Method for determination of free radon exhalation rate of mineral- based building materials — Total count determination using gamma-ray spectrometry 16 Annex B (informative) Method for determination of free radon exhalation rate of mineral- based building materials — Determination by nuclide-specific gamma-ray 26 Annex C (informative) Performance characteristics 38		7.1 General 7.2 Set up of test bench 7.2.1 Choice of volume flow rate 9.2.1 Choice of volume flow rate 9.2.1 Choice of adsorbent material 9.2.2 Determination of amount of adsorbent material 7.2.3 Determination of minimum desorption duration	50.20110 10
8 Expression of results 13 8.1 General 13 8.2 Free exhalation rate 13 8.3 Standard uncertainty 13 8.4 Decision threshold 14 8.5 Detection limit 15 9 Test report 15 Annex A (informative) Method for determination of free radon exhalation rate of mineral-based building materials — Total count determination using gamma-ray spectrometry 16 Annex B (informative) Method for determination of free radon exhalation rate of mineral-based building materials — Determination by nuclide-specific gamma-ray 26 Annex C (informative) Performance characteristics 38		1	
Annex A (informative) Method for determination of free radon exhalation rate of mineral- based building materials — Total count determination using gamma-ray spectrometry 16 Annex B (informative) Method for determination of free radon exhalation rate of mineral- based building materials — Determination by nuclide-specific gamma-ray spectrometry	8	Expression of results 8.1 General 8.2 Free exhalation rate 8.3 Standard uncertainty 8.4 Decision threshold	
based building materials — Total count determination using gamma-ray spectrometry 16 Annex B (informative) Method for determination of free radon exhalation rate of mineral- based building materials — Determination by nuclide-specific gamma-ray spectrometry	9	Test report	
Annex C (informative) Performance characteristics		based building materials — Total count determination using gamma-ray spectrometry Annex B (informative) Method for determination of free radon exhalation rate of mineral- based building materials — Determination by nuclide-specific gamma-ray	
	Ann		

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: Foreword - Supplementary information

This document was prepared by ISO/TC 85, *Nuclear energy, nuclear technologies, and radiological protection*, Subcommittee SC 2, *Radiological protection*.

This second edition cancels and replaces the first edition (ISO 11665-9:2016), which has been technically revised.

A list of all the parts in the ISO 11665 series can be found on the ISO website

Introduction

Radon isotopes 222, 219 and 220 are radioactive gases produced by the disintegration of radium isotopes 226, 223 and 224, which are decay products of uranium-238, uranium-235 and thorium-232 respectively, and are all found in the earth's crust. Solid elements, also radioactive, followed by stable lead are produced by radon disintegration^[1].

When disintegrating, radon emits alpha particles and generates solid decay products, which are also radioactive (polonium, bismuth, lead, etc.). The potential effects on human health of radon lie in its solid decay products rather than the gas itself. Whether or not they are attached to atmospheric aerosols, radon decay products can be inhaled and deposited in the bronchopulmonary tree to varying depths according to their size.

Radon is today considered to be the main source of human exposure to natural radiation. UNSCEAR[2] suggests that, at the worldwide level, radon accounts for around 52 % of global average exposure to natural radiation. The radiological impact of isotope 222 (48 %) is far more significant than isotope 220 (4 %), while isotope 219 is considered negligible. For this reason, references to radon in this document refer only to radon-222.

Radon activity concentration can vary from one to more orders of magnitude over time and space. Exposure to radon and its decay products varies tremendously from one area to another, as it depends on the amount of radon emitted by the soil, weather conditions, and on the degree of containment in the areas where individuals are exposed.

As radon tends to concentrate in enclosed spaces like houses, the main part of the population exposure is due to indoor radon. Soil gas is recognized as the most important source of residential radon through infiltration pathways. Other sources are described in other parts of ISO 11665 and ISO 13164 (all parts) for water^[3].

Radon enters into buildings via diffusion mechanism caused by the all-time existing difference between radon activity concentrations in the underlying soil and inside the building, and via convection mechanism inconstantly generated by a difference in pressure between the air in the building and the air contained in the underlying soil. Indoor radon activity concentration depends on radon activity concentration in the underlying soil, the building structure, the equipment (chimney, ventilation systems, among others), the environmental parameters of the building (temperature, pressure, etc.)

and the occupants' lifestyle.

To limit the risk to individuals, a national reference level of 100 Bq·m⁻³ is recommended by the World Health Organization^[4]. Wherever this is not possible, this reference level should not exceed 300 Bq·m⁻³. This recommendation was endorsed by the European Community Member States that shall establish national reference levels for indoor radon activity concentrations. The reference levels for the annual average activity concentration in air shall not be higher than 300 Bq·m⁻³[5].

To reduce the risk to the overall population, building codes should be implemented that require radon prevention measures in buildings under construction and radon mitigating measures in existing buildings. Radon measurements are needed because building codes alone cannot guarantee that radon concentrations are below the reference level.

The radon atoms in materials are produced by the disintegration of the radium-226 contained in the mineral grains of the material. Some of these atoms reach the interstitial spaces between the grains: this is the phenomenon of emanation. Some of these atoms produced by emanation reach the material's surface by diffusion and convection: this is the phenomenon of exhalation.

Values of the radon-222 surface exhalation rate observed for building materials vary from not detectable up to 5 mBq·m⁻²·s⁻¹[6][Z].

ISO 11665 consists of 12 parts (see Figure 1).




Figure 1 — Structure of the ISO 11665 series

Measurement of radioactivity in the environment — Air: Radon-222 —

Part 9: **Test methods for exhalation rate of building materials**

1 Scope

This document specifies a method for the determination of the free radon exhalation rate of a batch of mineral based building materials. This document only refers to ²²²Rn exhalation determination using two test methods: liquid Scintillation Counting (LSC) and gamma ray spectrometry (see <u>Annex A</u> and <u>Annex B</u>).

The exhalation of thoron (220 Rn) does not affect the test result when applying the determination methods described in this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 11665-1, Measurement of radioactivity in the environment — Air: radon-222 — Part 1: Origins of radon and its short-lived decay products and associated measurement methods

ISO 11929, Determination of the characteristic limits (decision threshold, detection limit and limits of the confidence interval) for measurements of ionizing radiation — Fundamentals and application ISO/IEC 17025, General requirements for the competence of testing and calibration laboratories

3 Terms, definitions and symbols

3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at http://www.iso.org/obp
- IEC Electropedia: available at <u>http://www.electropedia.org/</u>

3.1.1

batch

quantity of material that is regarded as a unit and for which it is assumed that it has uniform characteristics or an amount of fresh concrete produced under uniform conditions and which has the same strength and environmental class or which has the same composition

3.1.2

building material

product that is made of one or more materials and possibly admixtures and which has characteristics that meet previously set requirements after a formation process which may have been supplemented with a curing process if required

Note 1 to entry: The curing process, in which a chemical reaction occurs, may take place under ambient conditions (cold binding products), under elevated temperature (baked products) or under elevated temperature and pressures (autoclaved products).

3.1.3

building material laboratory sample

sample or sub-sample(s) of the *building material* (3.1.2) received by the laboratory

3.1.4

building material test sample

building material (3.1.2) sample that is either the laboratory sample or has been prepared from the laboratory sample used to determine the radon exhalation

3.1.5

adsorbent test sample

sample of adsorbent material, such as silica gel or charcoal, used to trap the radon exhaled from the *building material test sample* (3.1.4)

Note 1 to entry: This sample is used for testing.

3.1.6

free volume

volume of the exhalation vessel reduced by the volume of the *building material test sample* (3.1.4)

3.1.7

radon standard

Document Preview

solution of ²²⁶Ra with a defined activity which can be traced to the primary standard or a source of radon emanation with a defined radon emanation rate respectively

3.1:8s://standards.iteh.ai/catalog/standards/iso/c37c7814-b04c-4c6c-ab4b-7056f35d9a54/iso-11665-9-2019

Name of quantity

ventilation rate

rate at which the *free volume* (3.1.6) is refreshed

Note 1 to entry: The ventilation rate can be calculated by dividing the volume flow rate (m^3/s) by the *free volume* (3.1.6) (m^3) .

3.2 Symbols

For the purposes of this document, the symbols given in ISO 11665-1 and the following apply.

Symbol

A _{Ra,s}	²²⁶ Ra activity of the radon standard, in becquerel
A _{Ra}	²²⁶ Ra activity, in becquerel
F _c	Calibration factor
$\overline{F_{c}}$	Average calibration factor
i	Subscript of the determination for the <i>i</i> th counting measurement
<i>m</i> _g , <i>m</i> ₀	Number of repeated counting measurements of the same kind: test sample and back- ground, respectively

ISO 11665-9:2019(E)

<i>n</i> g,i, <i>n</i> _{0,i}	Number of counts in the <i>i</i> th measurement of the <i>m</i> counting measurements of the gross area of the peak of the adsorbent test sample and of the background spectrum, respectively
$\overline{n}_{ m g}$, $\overline{n}_{ m 0}$	Mean value of the number of counts of the <i>m</i> counting measurements of the adsorbent test sample and of the blank sample, respectively
n _{g,Pbi} , n _{0,Pb,i}	Number of counts in the peak of the adsorbent test sample spectrum and of the blank spectrum for the i^{th} measurement of the <i>m</i> counting measurements, respectively at the energy line of ²¹⁰ Pb
$\overline{n}_{\mathrm{g,Pb}}$, $\overline{n}_{\mathrm{0,Pb}}$	Mean value of the number of counts of the <i>m</i> counting measurements of the adsorbent test sample and of the blank sample, respectively in the gross area of the peak at the energy line of 210 Pb
n _{g,Bi,i} , n _{0,Bi,i}	Number of counts in the peak of the adsorbent test sample spectrum and of the blank spectrum for the i th measurement of the m counting measurements, respectively at the energy line of 214 Bi
$\overline{n}_{\mathrm{g,Bi}}$, $\overline{n}_{\mathrm{0,Bi}}$	Mean value of the number of counts of the m counting measurements of the adsorbent test sample and of the blank sample, respectively in the gross area of the peak at the energy line of 214 Bi
<i>R</i> _g , <i>R</i> ₀	Gross counting rate as the result of radon and/or radon decay products on the adsor- bent test sample and of the blank, respectively, in per second
${\overline R}_{ m g}$, ${\overline R}_{ m 0}$	Mean value of the <i>m</i> measurements of the gross counting rate as the result of radon and/or radon decay products on the adsorbent test sample and of the blank, respectively, counting rate in per second
$R_{g,Pb}, R_{0,Pb}$	Gross counting rate of the adsorbent test sample and of the blank, respectively, for ²¹⁰ Pb, in per second
R _{g,Bi} , R _{0,Bi}	Gross counting rate of the adsorbent test sample and of the blank, respectively, for ²¹⁴ Bi, in per second
t _a	Duration between the start and the end of the adsorption step, in seconds
$t_{ m g}$, t_0	Counting duration for the measurement of the background and the blank, respectively, in seconds
t _c	Counting duration of the adsorbent test sample, in seconds
t _w	Duration between the end of the adsorption period and the start of the count, in sec- onds
Ur	Expanded relative uncertainty, calculated by $U_r = k \cdot u$ (a) with $k = 2,$
V	Free volume to which the radon exhales, in cubic metres
Vp	Volume of the building material test sample, in cubic metres
λ_{Rn}	Radon decay constant, in per second
$\lambda_{\rm v}$	Ventilation rate, in per second
k	Coverage factor
$arphi_{ m f}$	Free radon exhalation rate, in becquerel per second

${\overline{\phi}_{\mathrm{f}}}$	Mean value of the free radon exhalation rate, in becquerel per second
$\mu(\bar{\phi}_{\rm f})$	Standard uncertainty of the free radon exhalation rate, in becquerel per second
$\overline{\phi}_{\mathrm{f}}^{*}$	Decision threshold, in becquerel per second, associated to the free radon exhalation rate
$ar{\phi}_{ m f}^{\#}$	Detection limit, in becquerel per second, associated to the free radon exhalation rate
${ar \phi}^*_{ m f,Pb}$, ${ar \phi}^*_{ m f,Bi}$	Decision threshold, in becquerel per second, associated to the free radon exhalation rate for ²¹⁰ PB and ²¹⁴ Bi respectively
$ar{\phi}^{\#}_{ m f,Pb}$, $ar{\phi}^{\#}_{ m f,Bi}$	Detection limit, in becquerel per second, associated to the free radon exhalation rate for ²¹⁰ PB and ²¹⁴ Bi respectively

All symbols belonging to the countings performed on the test samples, blanks and reference samples are indicated by subscripts g, 0 and r, respectively.

In each case, arithmetic averaging over m countings of the same kind carried out with the same preselected measurement duration, t (time preselection), is denoted by an overline.

Thus, for example, for *m* counting results, n_i (*i*=1,...,*m*; *m*>1), which are obtained in such a way and shall be averaged, the mean value, \overline{n} , and its uncertainty, $u^2(\overline{n})$, of the values, n_i , are given by

$$\overline{n} = \frac{1}{m} \sum_{i=1}^{m} n_i ; \ u^2(\overline{n}) = \frac{1}{m} \left(\overline{n} + \frac{m-1}{m-3} \overline{n} + \frac{1}{m-3} \sum_{i=1}^{m} (n_i - \overline{n})^2 \right)$$

4 Principle

The building material test sample (3.1.4) is conditioned at a temperature of (20 ± 2) °C and (50 ± 5) % relative humidity. After conditioning, the building material test sample (3.1.4) is placed in an exhalation vessel where the radon exhalation takes place.

https://standards.iteh.ai/catalog/standards/iso/c37c7814-b04c-4c6c-ab4b-7056f35d9a54/iso-11665-9-2019 The free radon exhalation rate is determined by flushing the exhaled radon from the free volume (<u>3.1.6</u>) using nitrogen and trapping it on an adsorbent material (purge and trap method) such as silica gel and charcoal. The radon content of these adsorbent materials is quantified using Liquid Scintillation Counting (LSC) for silica gel as described in the main text or using gamma ray spectrometry for charcoal as described in <u>Annex A</u> and <u>Annex B</u>.

5 Reagents and equipment

5.1 Reagents

- 5.1.1 Ice water.
- 5.1.2 Potassium hydroxide, KOH, solid (pellets).

5.1.3 Radon standard (<u>3.1.7</u>).

5.1.4 Scintillation cocktail.

NOTE A cocktail based on toluene has, in practice, been found to be the most suitable.

5.1.5 Silica gel with a particle size of 1 mm to 3 mm and dried at 105 °C until a constant mass is obtained.

A constant mass is obtained when the mass of the last weighing does not deviate by more than 0,5 % of the mass of the previous weighing when weighing with an intervening period of at least 24 h.

5.1.6 Nitrogen, N₂, gas.

NOTE By the blank determination, any radon content of the gas and the influence of this on the result is taken into account.

5.1.7 Nitrogen, N₂, liquid.

5.2 Equipment for sample preparation

5.2.1 Conditioning room in which the temperature can be set to a value of (20 ± 2) °C and the relative humidity can be set to a value of (50 ± 5) %.

5.2.2 Calibrated length measuring instrument, with a reading uncertainty of maximum 1 mm.

5.2.3 Calibrated weighing apparatus, with a measuring range of minimum 1,5 times the mass of the building material test sample (3.1.4) and reading uncertainty of a maximum 0,01 %.

5.2.4 Relative-humidity meter, with a measuring range of 40 % to 60 %, measurement uncertainty of maximum 3 %, and reading uncertainty of maximum 1 %.

5.2.5 Thermometer, with a measuring range of 15 °C to 25 °C, measurement uncertainty of maximum of 1 °C, and reading uncertainty of a maximum of 0,5 °C.

5.2.6 Saw.

ISO 11665-9:2019

ttps://standards.iteh.ai/catalog/standards/iso/c37c7814-b04c-4c6c-ab4b-7056f35d9a54/iso-11665-9-2019 5.3 Equipment for procedure

5.3.1 Adsorption column. Glass U tube of sufficient length and diameter, able to contain approximately 5 g silica gel.

5.3.2 Dewar flask.

5.3.3 Drying column, comprising a glass U tube of sufficient length and diameter, able to contain 20 g of KOH pellets.

5.3.4 Exhalation vessel, in which one or more adsorbent test samples (3.1.5) can be placed without touching each other or the walls of the vessel and which can be sealed airtight. The dimensions of the vessel shall be so that adequate flushing of the free volume (3.1.6) is possible. Ensure that the volume of the exhalation vessel has at least twice the volume of the adsorbent test sample (3.1.5).

The material used to manufacture the exhalation vessel shall not release radon. The vessel shall have an inlet and an outlet to allow flushing of the free volume (3.1.6) with nitrogen and shall be provided with a thermometer and a relative-humidity meter. The ingoing volume flow shall be distributed over various inlet points to ensure that the whole inner space of the vessel is flushed uniformly. Ensure that there are no dead corners in this inner space. Volume flow rate meters shall be mounted in the lines used to supply and exhaust the nitrogen.

5.3.5 Gas washing bottle(s). At least one, of volume 150 ml to 200 ml.

5.3.6 Calibrated length measuring instrument with a reading uncertainty of maximum 1 mm.

5.3.7 Glass vials, to be used as sample holders for the liquid scintillation counter; volume 20 ml.

5.3.8 Relative-humidity meter with a measuring range of 40 % to 60 %, measurement uncertainty of maximum 3 % in absolute terms, and reading uncertainty of at most 1 %.

5.3.9 Round bottom flasks or gas washing bottles of sufficient volume to ensure the ²²⁶Ra solution can be flushed.

5.3.10 Liquid scintillation counter, preferably with a sample changer and the option of setting windows and displaying pulse height spectra.

5.3.11 Thermometer with a measuring range of 15 °C to 25 °C, measurement uncertainty of maximum 1 °C, and reading uncertainty of maximum 0,5 °C.

5.3.12 Chronometer, with reading uncertainty of maximum 1 s.

5.3.13 Connection tubes, together with valves if required.

5.3.14 Plastic tubes.

5.3.15 Volume flow rate meter of accuracy such that the actual volume flow rate does not deviate by more than 1 % from the value set during the test, with a measurement uncertainty of maximum 2 % of the measured value, and a reading uncertainty of 1 % of the measured value.

5.4 Test bench

Set up the test bench as specified in <u>Figure 2</u> with the components described in <u>5.3</u>.

The components are connected with plastic tubes (5.3.14). The tubes that may be in contact with radon, 2019 that is, downstream from the exhalation vessel (5.3.4), shall be as short as possible. Split the nitrogen supply into two parts.

Pass one section over one or more gas washing bottles (5.3.5) filled with water to ensure that this volume flow can reach a relative humidity of at least 50 %. The ratio between the dry and the humidified volume flows can be changed through the valves mounted on the supply lines. Fit the relative-humidity meter (5.3.8) in the exhalation vessel (5.3.4), seal the vessel hermetically and start the nitrogen volume flow. Check after 1 h to ensure that:

- the volume flow rates in the supply and exhaust line(s) are the same within the reading accuracies (A + B = C);
- the relative-humidity meter is (50 ± 5) %. If this is not the case, the ratio of both volume flows shall be modified using the valves.