



SLOVENSKI STANDARD
SIST-TP CEN/TR 17996:2024

01-maj-2024

Cevi, fittingi, pribor in spoji iz duktilne železove litine za kanalizacijo - Smernice za vgradnjo cevovodov

Ductile iron pipes, fittings, accessories and their joints for sewerage applications - Guidelines for Pipelines Installation

Rohre, Formstücke, Zubehörteile aus duktilem Gusseisen und ihre Verbindungen für Wasserleitungen - Richtlinien für die Installation von Rohrleitungen

Iron Standards
(<https://standards.iteh.ai>)
Document Preview

Ta slovenski standard je istoveten z: CEN/TR 17996:2024

[SIST-TP CEN/TR 17996:2024](https://standards.iteh.ai/catalog/standards/sist/009300bb-6aa9-47f0-afaa-d875b3efeca6/sist-tp-cen-tr-17996-2024)

<https://standards.iteh.ai/catalog/standards/sist/009300bb-6aa9-47f0-afaa-d875b3efeca6/sist-tp-cen-tr-17996-2024>

ICS:

23.040.10	Železne in jeklene cevi	Iron and steel pipes
23.040.40	Kovinski fittingi	Metal fittings

SIST-TP CEN/TR 17996:2024 **en**

TECHNICAL REPORT

CEN/TR 17996

RAPPORT TECHNIQUE

TECHNISCHER REPORT

February 2024

ICS 23.040.10; 23.040.40

English Version

Ductile iron pipes, fittings, accessories and their joints for sewerage applications - Guidelines for Pipelines Installation

Rohre, Formstücke, Zubehörteile aus duktilem
Gusseisen und ihre Verbindungen für Wasserleitungen
- Richtlinien für die Installation von Rohrleitungen

This Technical Report was approved by CEN on 12 February 2024. It has been drawn up by the Technical Committee CEN/TC 203.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[SIST-TP CEN/TR 17996:2024](https://standards.iteh.ai/catalog/standards/sist/009300bb-6aa9-47f0-afaa-d875b3efeca6/sist-tp-cen-tr-17996-2024)

<https://standards.iteh.ai/catalog/standards/sist/009300bb-6aa9-47f0-afaa-d875b3efeca6/sist-tp-cen-tr-17996-2024>



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword	4
1 Scope.....	5
2 Normative references.....	5
3 Terms and definitions.....	6
4 Assembling methods for pipes and fittings	12
4.1 General.....	12
4.2 Crowbar method	12
4.3 Rope winches/Lever hoists method.....	13
4.4 Devices with lever/Joining tackle method.....	15
4.5 Trench excavator method.....	16
5 Laying in trench.....	16
5.1 General.....	16
5.2 Safety rules.....	17
5.3 Laying in the presence of excavation shoring	18
5.3.1 Obligations	18
5.3.2 Deployment.....	18
5.4 Laying on instable soils (low bearing capacity soils)	20
6 Laying above ground	21
6.1 Permanent installation.....	21
6.2 Interim installation.....	22
6.2.1 General.....	22
6.2.2 Basic requirements.....	22
6.2.3 Design and planning	23
6.2.4 Special rules on construction works.....	24
6.2.5 Disassembly and reuse of pipe material	24
7 Laying on steep inclines	24
8 Connections for manhole and inspection chambers.....	26
8.1 General.....	26
8.2 Connection through manhole connectors (Figures 26 and 27)	27
8.3 Connection through welded-on puddle flanges (Figure 28)	28
8.4 Connection through a wall sealing collar with clamp (Figure 29)	29
8.5 Connection through pipe seal gaskets (Figure 30)	29
8.6 Connection through a Ring-Seal kit or a Compact Seal piece (Figure 31)	29
9 Connections for gravity and sewer pipelines	30
9.1 Fittings for gravity sewers: Branch junction, access trap and saddle connections	30
9.2 Fittings for pressure and vacuum sewers	32
10 Trenchless technologies.....	33
10.1 General.....	33
10.2 Horizontal directional drilling (HDD)	33
10.2.1 General.....	33
10.2.2 First step – Pilot bore.....	33
10.2.3 Second step – Upsize bore.....	33
10.2.4 Third step – Pulling in	34

10.3	Pipe Bursting.....	34
10.4	Casing method (CM).....	35
10.4.1	General	35
10.4.2	Casing installation.....	35
10.4.3	Service Pipeline installation.....	35
10.5	Pipe jacking (PJ).....	36
10.6	Press/Pull Technique.....	36
10.6.1	Press/Pull Requirements	37
10.6.2	Description of technique.....	37
10.7	Ploughing-in Technique	38
10.7.1	General	38
10.7.2	Description of technique.....	38
10.8	Microtunnelling.....	39
11	Procedures and requirements for testing gravity pipelines	40
11.1	General	40
11.2	Testing with air (method "L").....	40
11.3	Testing with water (method "W").....	43
11.3.1	Test pressure.....	43
11.3.2	Conditioning time.....	44
11.3.3	Test requirements.....	44
11.3.4	Testing time	44
11.3.5	Testing individual joints	44
12	Testing of pressure pipelines.....	45
12.1	General	45
12.2	Safety.....	45
12.3	Backfilling and Anchorage	46
12.4	Filling with water and release of air/gas	47
12.5	Pressure testing procedure	49
12.5.1	General requirements.....	49
12.5.2	Preliminary operations.....	51
12.5.3	Preliminary test	51
12.5.4	Pressure drop test.....	52
12.5.5	Main pressure test.....	52
12.5.6	Test evaluation	55
12.5.7	Final system test (complete pipeline).....	55
12.5.8	Recording test results	55
	Bibliography	56

CEN/TR 17996:2024 (E)**European foreword**

This document (CEN/TR 17996:2024) has been prepared by Technical Committee CEN/TC 203 “Cast iron pipes, fittings and their joints”, the secretariat of which is held by AFNOR.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a Standardization Request given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s)/Regulation(s).

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[SIST-TP CEN/TR 17996:2024](https://standards.iteh.ai/catalog/standards/sist/009300bb-6aa9-47f0-afaa-d875b3efeca6/sist-tp-cen-tr-17996-2024)

<https://standards.iteh.ai/catalog/standards/sist/009300bb-6aa9-47f0-afaa-d875b3efeca6/sist-tp-cen-tr-17996-2024>

1 Scope

This document is a complementary document for the installation of ductile iron pipes, fittings, accessories and their joints, covered by EN 598:2009 harmonized standard. It is intended to describe, in a wider perspective, installation technologies, tools and pipelines particular examples, applicable for the construction, outside buildings, of:

- drainage pipeline systems;
- raw water pipeline systems;
- sewage pipeline systems;
- water reuse pipeline systems;
- pipeline systems conveying surface water (e.g. rainwater), domestic wastewater and/or certain types of industrial effluents, either in separate systems or in combined systems;
- operating without pressure (gravity sewers) or with positive or negative pressure;
- below or above ground installation types.

It also gives some site operation/site instructions for the application of fittings, intended to be used for the connection of ductile iron drains and sewers to other materials as plastic, concrete, vitrified clay, etc.

This document is not intended to cover:

- hydraulic design of drains and sewers systems outside buildings. For this purpose, EN 16933-2 applies;
- construction and site testing of drains and sewers. For this purpose, EN 1610 applies;
- trenchless construction and testing of drains and sewers. For this purpose, EN 12889 applies.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 476:2011, *General requirements for components used in drains and sewers*

EN 545:2010, *Ductile iron pipes, fittings, accessories and their joints for water pipelines - Requirements and test methods*

EN 598:2009, *Ductile iron pipes, fittings, accessories and their joints for sewerage applications - Requirements and test methods*

EN 752:2017, *Drain and sewer systems outside buildings - Sewer system management*

EN 805:2000, *Water supply - Requirements for systems and components outside buildings*

EN 1610:2015, *Construction and testing of drains and sewers*

CEN/TR 17996:2024 (E)**3 Terms and definitions**

For the purposes of this document, the terms and definitions given in EN 598:2009, EN 476:2011, EN 1333:2006, EN 773:1999 and EN 1610:2015 apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp/>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1**ductile iron**

cast iron used for pipes, fittings and accessories in which graphite is present substantially in spheroidal form

3.2**pipe**

casting of uniform bore, straight in axis, having either socket, spigot or flanged ends, except for flanged-socket pieces, flanged-spigot pieces and collars which are classified as fittings

3.3**fitting**

casting other than a pipe which allows pipeline deviation, change of direction or bore. In addition, flanged-socket pieces, flanged-spigot pieces and collars are also classified as fittings

3.4**accessory**

any casting/fabrication other than a pipe or fitting which is intended for the use in a ductile iron pipeline including:

- inspection chambers (see 3.5);
- manholes (see 3.6);
- glands and bolts for mechanical flexible joints (sec 3.16);
- glands, bolts and locking rings for restrained flexible joints (see 3.17);
- adjustable flanges and flanges to be welded or screwed;
- pipe saddles for service pipe connections;
- flange adaptors for use with ductile iron pipes and fittings;
- couplings for use with ductile iron pipes and fittings;
- valves for use with ductile iron pipes and fittings

3.5**inspection chamber**

structure with a removable cover, constructed on a drain or sewer that permits the introduction of cleaning and inspection equipment from surface level, but does not provide access for personnel

[SOURCE EN 16323:2014]

3.6**manhole**

structure with a removable cover, constructed on a drain or sewer to permit entry by personnel

[SOURCE EN 16323:2014]

3.7**access chamber**

component of a sewer, with one or two side inlets set at a variety of angles, ideal for making single connections

3.8**flange**

flat circular end of a pipe or fitting extending perpendicular to its axis, with bolt holes equally spaced on a circle

Note 1 to entry: A flange is either fixed (e.g. integrally cast or welded-on) or adjustable; an adjustable flange comprises a ring, in one or several parts assembled together, which bears on an end joint hub and can be freely rotated around the pipe axis before jointing.

3.9**spigot**

male end of a pipe or fitting

3.10**spigot end length**

spigot over a length equal to maximum insertion depth plus 50 mm

3.11**socket**

female end of a pipe or fitting to make the connection with the spigot of the next component

3.12**gasket**

sealing component of a joint

3.13**joint**

connection between the ends of two pipes and/or fittings in which a gasket is used to effect a seal

3.14**flexible joint**

joint which permits significant angular deflection both during and after installation and which can accept a slight offset of the centreline

3.15**push-in flexible joint**

flexible joint assembled by pushing the spigot through the gasket in the socket of the mating component

3.16**mechanical flexible joint**

flexible joint in which sealing is obtained by applying pressure to the gasket by mechanical means, e.g. a gland

CEN/TR 17996:2024 (E)**3.17****restrained flexible joint**

flexible joint in which a means is provided to prevent separation of the assembled joint

3.18**flanged joint**

joint between two flanged ends

3.19**nominal size (DN)**

alphanumerical designation of size for components of a pipework system, which is used for reference purposes

Note 1 to entry: It comprises the letters DN followed by a dimensionless whole number which is indirectly related to the physical size, in millimetres, of the bore or outside diameter of the end connections

[SOURCE EN ISO 6708:1995]

3.20**nominal pressure (PN)**

alphanumerical designation used for reference purposes related to a combination of mechanical and dimensional characteristics of a component of a pipework system

Note 1 to entry: It comprises the letters PN followed by a dimensionless number

Note 2 to entry: All equipment of the same nominal size DN designated by the same PN number have compatible mating dimensions.

[SOURCE EN 1333:2006]

3.21**leak tightness test pressure**

pressure applied to a component during manufacture in order to ensure its leak tightness

3.22**allowable operating pressure (PFA)**

maximum hydrostatic pressure that a component can withstand continuously in service

[SOURCE EN 773:1999]

3.23**allowable maximum operating pressure (PMA)**

maximum hydrostatic pressure, including surge, that a component can withstand from time to time in service

[SOURCE EN 773:1999]

3.24**allowable test pressure (PEA)**

maximum hydrostatic pressure that a newly installed component can withstand for a relatively short duration, when either fixed above ground level or laid and backfilled underground, in order to ensure the integrity and tightness of the pipeline

Note 1 to entry: This test pressure is different from the system test pressure (STP), which is related to the design pressure of the pipeline and is intended to ensure its integrity and leak tightness.

[SOURCE EN 773:1999]

3.25**working pressure****WP** P_w

highest pressure that occurs at a time and a point in the pipeline when operating continuously under stable conditions, without surge

[SOURCE ISO 10802:2020]

3.26**maximum working pressure****MWP** P_{MW}

maximum pressure to which a pipeline is subjected under surge conditions

[SOURCE ISO 10802:2020]

3.27**maximum design pressure****MDP** P_{MD}

maximum operating pressure of the system or of the pressure zone fixed by the designer considering future developments and including surge to which a pipeline is subjected under surge conditions

Note 1 to entry: It is the maximum pressure considering the design pressure and surge together, where:

- MDP is designated MDP_a , P_{MDa} , fixed allowance for surge (secondary distribution networks);
- MDP is designated MDP_c , P_{MDc} , surge is calculated (pumping and water mains).

[SOURCE ISO 10802:2020]

3.28**system test pressure****STP** P_{ST}

pressure to which a pipeline or a pipeline section is subjected for testing purposes

[SOURCE ISO 10802:2020]

3.29**diametral stiffness of a pipe**

characteristic of a pipe which allows it to resist ovalization under loading when installed

CEN/TR 17996:2024 (E)**3.30****discharge system**

system of pipes, fittings, accessories and joints used to collect and drain wastewater and rainwater of a building

Note 1 to entry: It comprises discharge pipes, stack ventilation pipes and rainwater downpipes, installed within the limits of a building or attached to the building.

3.31**drain**

system of pipes, fittings, accessories and joints installed outside the limits of a building in order to connect the discharge system of this building to a sewer or a septic tank

3.32**sewer**

pipeline designed to collect wastewater and rainwater from buildings and surface water and to convey them to the point of disposal or treatment

3.33**gravity sewer**

sewer operating normally under free flowing conditions

3.34**pressure sewer; pumping sewer**

sewer (or section of a sewer) operating under positive pressure

3.35**vacuum sewer**

sewer operating under negative pressure

3.36**combined system**

sewerage system collecting together rainwater, surface water and wastewater

3.37**separate system**

sewerage system which collects wastewater separately from rainwater and surface water

3.38**length**

effective length of a pipe or fitting

Note 1 to entry: Lengths are:

— as shown on Figure 6 and given in table 2 of the EN 598:2009, for socket and spigot pipes;

— as given by EN 545:2010, clause 4.3.3.2, for flanged pipes;

— as given by EN 545:2010, clauses 8.3, 8.4, and 4.3.3.3, for pressure fittings

Note 2 to entry: the length of fittings used for gravity sewers are available by the manufacturer.

3.39**deviation**

design length allowance with respect to the standardized length of a pipe

3.40**ovality**

out of roundness of a pipe section

Note 1 to entry: It is equal to: $100 \left(\frac{A_1 - A_2}{A_1 + A_2} \right)$

where

A_1 is the maximum axis in millimetres

A_2 is the minimum axis, in millimetres

3.41**bentonite**

clay mineral, primarily montmorillonite, with high swelling properties, which forms the primary component in drilling muds used in horizontal directional drilling technology

[SOURCE ISO 13470:2012]

3.42**bore**

cavity that is created to receive a pipe or conduit

[SOURCE ISO 13470:2012]

3.43**casing**

continuous structural shell that acts as an envelope and support for the service pipeline during construction and service

[SOURCE ISO 13470:2012]

3.44**casing method**

method in which a casing is put into place and then a pipe is inserted into the casing

[SOURCE ISO 13470:2012]

3.45**horizontal directional drilling**

steerable method for the underground installation of pipes using a surface launched drilling rig

[SOURCE ISO 13470:2012]

3.46**pilot bore**

initial hole drilled along the drill path

3.47**pipe bursting method**

method for replacement of an existing pipe by longitudinal splitting

[SOURCE ISO 13470:2012]

CEN/TR 17996:2024 (E)

3.48

pipe jacking method

system of directly installing pipes behind a cutting head and/or shield, by hydraulic thrust

[SOURCE ISO 13470:2012]

3.49

microtunnelling

trenchless steerable remote-control method for drain and sewage pipelines installation, using microtunnel boring machines

3.50

pulling head

reusable component mounted at the beginning of the pipe string, which transmits the pulling force from the drilling rod to the pipes

[SOURCE ISO 13470:2012]

3.51

service pipeline

ductile iron pipeline intended to carry water or wastewater, operated with or without pressure

[SOURCE ISO 13470:2012]

3.52

overcut

the annular space around the pipe deliberately created by using a cutting head or shield of greater dimension than the outside dimension of the pipe

[SOURCE EN 12889:2000]

3.53

water reuse

wastewater that has been treated to meet specific water quality for intended beneficial use

[SOURCE ISO 20678:2018]

4 Assembling methods for pipes and fittings

4.1 General

The assembling can be done by several different methods as given below:

4.2 Crowbar method

For small diameter pipes, usually up to DN 125, the assembling of pipes can be achieved by pushing the pipe with a crowbar against a timber held against the face of the socket of the entering pipe. The crowbar takes support on the ground. In case of the assembly of fittings, the crowbar pushes the fitting in the direction of the spigot, keeping the socket of the fitting centred and perpendicular with the spigot end (see Figures 1 and 2).