



~~Designation: D6890-10a~~ Designation: D6890 – 11

## Standard Test Method for Determination of Ignition Delay and Derived Cetane Number (DCN) of Diesel Fuel Oils by Combustion in a Constant Volume Chamber<sup>1, 2</sup>

This standard is issued under the fixed designation D6890; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

### 1. Scope\*

1.1 This automated laboratory test method covers the quantitative determination of the ignition characteristics of conventional diesel fuel oil, oil-sands based fuels, blends of fuel containing biodiesel material, diesel fuel oils containing cetane number improver additives, and is applicable to products typical of ASTM Specification D975 grades No. 1-D and 2-D regular and low-sulfur diesel fuel oils, European standard EN 590, and Canadian standards CAN/CGSB-3.517 and 3.6-2000. The test method may also be applied to the quantitative determination of the ignition characteristics of diesel fuel blending components.

1.2 This test method measures the ignition delay and utilizes a constant volume combustion chamber with direct fuel injection into heated, compressed air. An equation correlates an ignition delay determination to cetane number by Test Method D613, resulting in a derived cetane number (DCN).

1.3 This test method covers the ignition delay range from 3.1 to 6.5 ms (64 to 33 DCN). The combustion analyzer can measure shorter and longer ignition delays, but precision may be affected. For these shorter or longer ignition delays the correlation equation for DCN is given in Appendix X2. There is no information about how DCNs outside the 33 to 64 range compare to Test Method D613 cetane numbers.

1.4 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

### 2. Referenced Documents

#### 2.1 ASTM Standards:<sup>3</sup>

D613 Test Method for Cetane Number of Diesel Fuel Oil

D975 Specification for Diesel Fuel Oils

D1193 Specification for Reagent Water

D4057 Practice for Manual Sampling of Petroleum and Petroleum Products

D4175 Terminology Relating to Petroleum, Petroleum Products, and Lubricants

D4177 Practice for Automatic Sampling of Petroleum and Petroleum Products

D5854 Practice for Mixing and Handling of Liquid Samples of Petroleum and Petroleum Products

D6299 Practice for Applying Statistical Quality Assurance and Control Charting Techniques to Evaluate Analytical Measurement System Performance

D6300 Practice for Determination of Precision and Bias Data for Use in Test Methods for Petroleum Products and Lubricants

D6708 Practice for Statistical Assessment and Improvement of Expected Agreement Between Two Test Methods that Purport to Measure the Same Property of a Material

E456 Terminology Relating to Quality and Statistics

#### 2.2 ISO Standards:<sup>4</sup>

ISO 4010 Diesel Engines—Calibrating Nozzle, Delay Pintle Type

<sup>1</sup> This test method is under the jurisdiction of ASTM Committee D02 on Petroleum Products and Lubricants and is the direct responsibility of Subcommittee D02.01 on Combustion Characteristics.

Current edition approved Aug. 1, 2010; April 1, 2010; 2011. Published September 2010; April 2011. Originally approved in 2003. Last previous edition approved in 2010 as D6890-10a. DOI: 10.1520/D6890-10A; 10.1520/D6890-11.

<sup>2</sup> This test method is based on IP PM CQ/2001, published in the IP Standard Methods for Analysis and Testing of Petroleum and Related Products and British Standard 2000 Parts. Copyrighted by Energy Institute, 61 New Cavendish Street, London, W1G 7AR, UK. Adapted with permission of Energy Institute.

<sup>3</sup> For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For Annual Book of ASTM Standards volume information, refer to the standard's Document Summary page on the ASTM website.

<sup>4</sup> Available from American National Standards Institute, 25 W. 43rd St., 4th floor, New York, NY 10036.

\*A Summary of Changes section appears at the end of this standard.

ISO 4259 Petroleum products—Determination and application of precision data in relation to methods of test

2.3 *EN Standard:*

EN 590 Automotive Fuels—Diesel—Requirements and Test Methods<sup>5</sup>

2.4 *Energy Institute Standard:*

IP 41 Ignition Quality of Diesel Fuels—Cetane Engine Test Method<sup>6</sup>

2.5 *Canadian Standards:*

CAN/CGSB-3.517-2000 Automotive Low Sulfur Diesel Fuel—Specification<sup>7</sup>

CAN/CGSB 3.6-2000 Automotive Diesel Fuel—Specification<sup>7</sup>

### 3. Terminology

3.1 *Definitions:*

3.1.1 *accepted reference value (ARV), n*—value that serves as an agreed-upon reference for comparison and that is derived as (1) a theoretical or established value, based on scientific principles, (2) an assigned value, based on experimental work of some national or international organization, such as the U.S. National Institute of Standards and Technology (NIST), or (3) a consensus value, based on collaborative experimental work under the auspices of a scientific or engineering group. **E456**

3.1.1.1 *Discussion*—In the context of this test method, accepted reference value is understood to apply to the ignition delay of specific reference materials determined under reproducibility conditions by collaborative experimental work.

3.1.2 *cetane number (CN), n*—a measure of the ignition performance of a diesel fuel oil obtained by comparing it to reference fuels in a standardized engine test. **D4175**

3.1.2.1 *Discussion*—In the context of this test method, cetane number is that defined by Test Method D613/IP 41.

3.1.3 *check standard, n*—in *QC testing*, material having an accepted reference value used to determine the accuracy of a measurement system. **D6299**

3.1.3.1 *Discussion*—In the context of this test method, check standard refers to heptane.

3.1.4 *quality control (QC) sample, n*—for use in quality assurance programs to determine and monitor the precision and stability of a measurement system, a stable and homogeneous material having physical or chemical properties, or both, similar to those of typical samples tested by the analytical measurement system. The material is properly stored to ensure sample integrity, and is available in sufficient quantity for repeated, long term testing. **D6299**

3.2 *Definitions of Terms Specific to This Standard:*

3.2.1 *calibration reference material, n*—pure chemical having an assigned ignition delay accepted reference value.

3.2.2 *charge air, n*—compressed air at a specified pressure introduced to the combustion chamber at the beginning of each test cycle.

3.2.3 *charge air temperature, n*—temperature, in °C, of the air inside the combustion chamber.

3.2.4 *combustion analyzer, n*—integrated compression ignition apparatus to measure the ignition characteristics of diesel fuel oil.

3.2.5 *derived cetane number (DCN), n*—number calculated using an equation that correlates a combustion analyzer ignition delay result to cetane number by Test Method D613. —a number calculated using a conversion equation to determine a cetane number.

3.2.5.1 *Discussion*—The conversion equation relates a measured ignition delay or ignition delay and combustion delay from a combustion analyzer to a cetane number.

3.2.6 *ignition delay (ID), n*—that period of time, in milliseconds (ms), between the start of fuel injection and the start of combustion as determined using the specific combustion analyzer applicable for this test method.

3.2.6.1 *Discussion*—In the context of this test method, start of fuel injection is interpreted as the initial movement or lift of the injector nozzle needle as measured by a motion sensor; start of combustion is interpreted as that point in the combustion cycle when a significant and sustained increase in rate-of-change in pressure, as measured by a pressure sensor in the combustion chamber, ensures combustion is in progress.

3.2.7 *operating period, n*—the time, not to exceed 12 h, between successive calibration or QC testing, or both, of the combustion analyzer by a single operator.

3.3 *Abbreviations:*

3.3.1 *ARV*—accepted reference value.

3.3.2 *CN*—cetane number.

3.3.3 *DCN*—derived cetane number.

3.3.4 *ID*—ignition delay.

3.3.5 *QC*—quality control.

### 4. Summary of Test Method

4.1 A small specimen of diesel fuel oil is injected into a heated, temperature-controlled constant volume chamber, which has

<sup>5</sup> Available from European Committee for Standardization. Central Secretariat: rue de Stassart, 36, B-1050 Brussels, Belgium.

<sup>6</sup> Available from Institute of Petroleum, 61 New Cavendish St., London, W1G 7AR, U.K.

<sup>7</sup> Available from the Canadian General Standards Board, Gatineau, Canada, K1A 1G6.

previously been charged with compressed air. Each injection produces a single-shot, compression ignition combustion cycle. ID is measured using sensors that detect the start of fuel injection and the start of significant combustion for each cycle. A complete sequence comprises 15 preliminary cycles and 32 further cycles. The ID measurements for the last 32 cycles are averaged to produce the ID result. An equation ~~correlates~~converts the ID result to cetane number by Test Method D613, ~~resulting in a DCN.~~

## 5. Significance and Use

5.1 The ID and DCN values determined by this test method can provide a measure of the ignition characteristics of diesel fuel oil in compression ignition engines.

5.2 This test can be used by engine manufacturers, petroleum refiners and marketers, and in commerce as a specification aid to relate or match fuels and engines.

5.3 The relationship of diesel fuel oil DCN determinations to the performance of full-scale, variable-speed, variable-load diesel engines is not completely understood.

5.4 This test may be applied to non-conventional fuels. It is recognized that the performance of non-conventional fuels in full-scale engines is not completely understood. The user is therefore cautioned to investigate the suitability of ignition characteristic measurements for predicting performance in full-scale engines for these types of fuels.

5.5 This test determines ignition characteristics and requires a sample of approximately 100 mL and a test time of approximately 20 min on a fit-for-use instrument.

## 6. Interferences

6.1 Minimize exposure of sample fuels, calibration reference materials, QC samples, and check standard to sunlight or fluorescent lamp UV emissions to minimize induced chemical reactions that can affect ignition delay measurements.<sup>8</sup>

6.1.1 Exposure of these fuels and materials to UV wavelengths shorter than 550 nanometers for a short period of time may significantly affect ignition delay measurements.

NOTE 1—The formation of peroxide and radicals can effect ignition delay measurement. These formations are minimized when the sample or material is stored in the dark in a cold room at a temperature of less than 10°C, and covered by a blanket of nitrogen.

6.2 Statistical analysis of data from a sequential testing study (Note 2) revealed a possible carryover effect in succeeding tests on samples containing 2-ethylhexylnitrate cetane improver at concentrations above 2000 ppm.

NOTE 2—In the sequential testing study, a fuel without cetane improver was tested three times back-to-back. Then a fuel with 2-ethylhexylnitrate cetane improver at concentrations above 2000 ppm was tested. Subsequently, the same fuel without cetane improver was tested three times. Statistical analyses of repeat data on two units were examined for evidence of hysteresis.

## 7. Apparatus

7.1 *General*—This test method uses an integrated automated analytical measurement system<sup>9</sup> comprised of: (1) a constant volume compression ignition combustion chamber with external electrical heating elements, suitable insulation and pneumatically actuated intake and exhaust valves, (2) a heated, pneumatically actuated fuel injection system<sup>10</sup> with pump, injector nozzle assembly, and associated sample reservoir, (3) a coolant system with a liquid-to-air heat exchanger, filter, circulating pump and flow control valves, (4) temperature thermocouples, pressure gages and sensors, an injector nozzle needle motion sensor, compressed gas pressure regulators, control valves, pneumatic actuator components, and solenoid valves, and (5) a computer to control test sequencing, acquire and accumulate sensor signal data, provide processing calculations, and automatically output a printed report of some important test parameters (see Fig. 1).

7.2 See Annex A2, Combustion Analyzer Equipment Description and Specifications, for detailed information.

7.3 *Compressed Gas Pressure Regulators:*

7.3.1 *Charge Air Regulator*, a two-stage regulator capable of controlling the downstream pressure to a minimum pressure of 2.2 MPa.

7.3.2 *Actuator Utility Compressed Air Regulator*, a two-stage regulator capable of controlling the downstream pressure to a minimum pressure of 1.3 MPa.

7.3.3 *Fuel Reservoir Utility Compressed Nitrogen Regulator*, a single or two-stage regulator capable of controlling the downstream pressure to a minimum pressure of 350 kPa.

7.4 *Auxiliary Apparatus:*

7.4.1 *Diesel Fuel Oil Sample Filter*, a single-use glass fiber, polytetrafluorethylene (PTFE), or nylon filter with a nominal pore size of 3 to 5 micrometers ( $\mu\text{m}$ ) for use with a glass syringe.

<sup>8</sup> Supporting data have been filed at ASTM International Headquarters and may be obtained by requesting Research Report RR- RR:D02-1502.

<sup>9</sup> The sole source of supply of the combustion analyzer known to the committee at this time is Advanced Engine Technology Ltd. (AET), 17 Fitzgerald Road, Suite 102, Ottawa, Canada, K2H 9G1. If you are aware of alternative suppliers, please provide this information to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend.

<sup>10</sup> The fuel injection system is covered by a patent. Interested parties are invited to submit information regarding the identification of an alternative(s) to this patented item to the ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend.




FIG. 1 Combustion Analyzer Schematic

7.4.2 Syringe, a glass syringe of a minimum volume of 100 mL.

## 8. Reagents and Materials

### 8.1 Calibration Reference Materials:

8.1.1 *Heptane (n-heptane)*, with a minimum purity of 99.5 volume percent. The assigned  $ID_{ARV}$  for this material is 3.78 ms. (**Warning**—Flammable. Vapor harmful. Vapor may cause flash fire.)

8.1.2 *Methylcyclohexane (MCH)*, with a minimum purity of 99.0 volume percent. The assigned  $ID_{ARV}$  for this material is 10.4 ms. (**Warning**—Flammable. Vapor harmful. Vapor may cause flash fire.)

NOTE 3—Experience has found some MCH meeting the purity specification but which does not meet Ignition Delay $_{ARV}$  (typically 1 to 1.5 milliseconds shorter). It is recommended that new material be qualified prior to use.

### 8.2 Check Standard:

8.2.1 *Heptane (n-heptane)*, with a minimum purity of 99.5 volume percent. The assigned  $ID_{ARV}$  for this material is 3.78 ms. (**Warning**—Flammable. Vapor harmful. Vapor may cause flash fire.)

8.3 *Quality Control Sample*, a stable and homogeneous diesel fuel oil having physical and chemical properties similar to those of typical sample fuels routinely tested. (**Warning**—Combustible. Vapor harmful.)



8.4 *Charge Air*, compressed air containing  $20.9 \pm 1.0$  volume percent oxygen, less than 0.003 volume percent hydrocarbons, and less than 0.025 volume percent water. For charge air cylinders supplied with a blend of oxygen and nitrogen, it is required that a quality control test be performed after an air cylinder has been changed. (**Warning**—Compressed gas under high pressure that supports combustion.)

8.5 *Coolant System Fluid*, a 50:50 volume mixture of water and commercial ethylene glycol-based antifreeze. (**Warning**—Poison. May be harmful or fatal if inhaled or swallowed.)

8.5.1 *Antifreeze*, commercial automotive cooling system ethylene glycol-based solution.

8.5.2 *Water*, distilled or reagent-grade, conforming to Specification D1193, Type IV.

8.6 *Actuator Utility Compressed Air*, oil free compressed air having less than 0.1 volume percent water supplied at a minimum sustained pressure of 1.5 MPa. (**Warning**—Compressed gas under high pressure that supports combustion.)

8.7 *Fuel Reservoir Utility Compressed Nitrogen*, compressed nitrogen having a minimum purity of 99.9 volume percent. (**Warning**—Compressed gas under high pressure.)

## 9. Sampling and Test Specimen Preparation

### 9.1 Sampling:

9.1.1 Collect diesel fuel oil samples in accordance with Practices D4057 or D4177.

9.1.1.1 Collect and store diesel fuel samples in a suitable container such as a dark brown bottle, a metal can, or a minimally reactive plastic container to minimize exposure to UV emissions.

9.1.2 Refer to Practice D5854 for appropriate information relating to the mixing and handling of diesel fuel oil samples.

### 9.2 Test Specimen Preparation:

9.2.1 *Sample Fuel Temperature*—Condition the diesel fuel sample before opening the storage container, so that it is at room temperature, typically 18 to 32°C.

9.2.2 *Filtration*—Prepare a test specimen by filtering at least 100 mL of diesel fuel oil sample through a nominal 3 to 5  $\mu\text{m}$  porosity filter element using a glass syringe.

9.2.2.1 Collect the specimen in a dark brown bottle, metal can or minimally reactive plastic container.

## 10. Basic Apparatus Settings and Standard Operating Conditions

10.1 Installation of the apparatus requires placement on a level floor and connection of all utilities. Engineering and technical support for this function is required, and the user shall be responsible to comply with all local and national codes and installation requirements.

10.2 Operation of the combustion analyzer, associated equipment, instrumentation and computer system requires setting a series of testing variables to prescribed specifications. Some of these settings are established by component specifications, others are operating conditions that are monitored/controlled by the computer software or by operator adjustment.

### 10.3 Settings Based on Component Specifications:

10.3.1 *Injector Nozzle Opening Pressure*—Each time the nozzle assembly is reassembled or replaced, or both, set the pressure-adjusting nut to release fuel in conformance with the requirements in the manufacturer's equipment manual, using an injector nozzle tester. For additional details, refer to the instruction manual of the manufacturer.

10.3.2 *Injector Nozzle Motion Sensor Position*—Manually position the motion sensor while visually observing the nozzle needle movement signal on the computer monitor (see Fig. A4.1). The criteria for optimized setting are as follows:

10.3.2.1 The signal prior to the steep increase in needle lift is required to indicate some signal noise. If the signal trace is flat and constant, the motion sensor is too far away from the nozzle needle extension pin.

10.3.2.2 The peak of the steep increase in signal level is required to be visible on the computer monitor screen. If the signal peak is flat, the motion sensor is too close to the nozzle needle extension pin. For additional details, refer to the instruction manual of the manufacturer.

10.3.3 *Injector Nozzle Coolant Passage Thermocouple Position*—Proper positioning of the thermocouple in the injector nozzle coolant passage is set by installing a compression fitting nut and associated plastic ferrule on the stainless steel sheath of the thermocouple, using a specialized depth setting tool to establish the correct depth of penetration. Adjust the depth of penetration (in accordance with the instruction manual of the manufacturer) by repositioning the plastic ferrule on the stainless steel sheath of the thermocouple and tightening the nut to a snug level of tightness. For additional details, refer to the instruction manual of the manufacturer.

10.3.4 *Charge Air Thermocouple Position*—Proper positioning of the thermocouple in the combustion chamber is set by installing a compression fitting nut and associated ferrule on the stainless steel sheath of the thermocouple, crimping the ferrule on the sheath using a specialized depth setting tool to establish the correct depth of penetration. For additional details, refer to the instruction manual of the manufacturer.

10.3.5 *Rate of Decrease of Combustion Chamber Pressure*, less than 3.5 kPa/s, as measured during the check of the sealing integrity of the combustion chamber (see A3.5).

### 10.4 Standard Operating Conditions:

10.4.1 *Charge Air Pressure (P2)*,  $2.137 \pm 0.007$  MPa.

10.4.2 *Charge Air Temperature (T4)*,  $545 \pm 30$ °C.

10.4.2.1 The difference in temperature ( $T4_{max} - T4_{min}$ ) as determined and recorded by the computer, shall be less than 2.5°C during a 32 combustion cycle measurement determination.

10.4.3 *Combustion Chamber Outer Surface Temperature (T1)*—Initially set by the manufacturer, the surface temperature is monitored and controlled by the computer. Operator adjustment of the controller set-point is required, in accordance with the calibration procedure.

10.4.4 *Combustion Chamber Pressure Sensor Temperature (T3)*,  $130 \pm 20^\circ\text{C}$ .

10.4.4.1 The difference in temperature ( $T3_{max} - T3_{min}$ ) as determined and recorded by the computer, shall be less than 8.0°C during a 32 combustion cycle measurement determination.

10.4.5 *Coolant Return Temperature (T7)*,  $40 \pm 10^\circ\text{C}$ .

10.4.6 *Fuel Sample Reservoir Pressure (P5)*,  $345 \pm 35$  kPa. Visually check the gage reading, as this parameter is not recorded by the data acquisition system.

10.4.7 *Fuel Injection Pump Temperature (T2)*,  $35 \pm 3^\circ\text{C}$ .

10.4.8 *Injector Nozzle Coolant Passage Temperature (T6)*—The maximum ( $T6_{max}$ ) and minimum ( $T6_{min}$ ) temperatures as determined and recorded by the computer, shall be within  $50 \pm 4.0^\circ\text{C}$  during a 32 combustion cycle measurement determination.

10.4.9 *Injection Actuator Air Pressure (P3)*,  $1.21 \pm 0.03$  MPa.

10.4.10 *Inlet/Exhaust Valve Actuator Air Pressure (P4)*,  $480 \pm 35$  kPa. Visually check the gage reading, as this parameter is not recorded by the data acquisition system.

## 11. Calibration and Quality Control Testing

11.1 *Calibration*—Calibrate the combustion analyzer for only the following reasons: (1) after it is installed and commissioned, (2) once a week, (3) after replacement of critical parts or components of combustion chamber assembly (see A2.2), fuel injection system (see A2.3) or instrument sensors (see A2.4), (4) after calibration of the data acquisition board, injection actuator air pressure sensor or charge air pressure sensor, (5) whenever check standard or QC sample determinations are not acceptable.

11.2 *Precalibration Procedures:*

11.2.1 Clean the combustion chamber pressure sensor assembly (see A3.3 and A3.4).

11.2.2 If necessary, start and warm-up the combustion analyzer (see A3.1).

11.3 *Calibration Procedure*—Two filtered calibration reference materials are tested: (1) heptane to affirm that the combustion chamber charge air temperature setting produces ignition delay measurements for this material that are within specification limits and, (2) methylcyclohexane to affirm that the measurement sensitivity of the combustion analyzer produces ignition delay measurements for this material that are within specification limits.

11.3.1 *Heptane Calibration Reference Material*—Perform three consecutive ignition delay determinations.

11.3.1.1 The average of three acceptable ID results is required to be within  $3.78 \pm 0.01$  ms.

11.3.1.2 If the average ID is outside the limits, the combustion chamber outer surface temperature controller set-point requires adjustment to cause a change in the combustion chamber charge air temperature.

NOTE 4—ID increases when the combustion chamber outer surface temperature decreases and vice versa.

11.3.1.3 If the temperature controller set-point adjustment from the previous setting, exceeds  $\pm 4^\circ\text{C}$ , a system malfunction is suspected and diagnostic procedures to determine and remedy the problem are recommended. Refer to the instructions provided by the manufacturer.

NOTE 5—After a change of charge air cylinders that employ a blend of oxygen and nitrogen, a temperature controller set-point adjustment beyond  $4^\circ\text{C}$  can accommodate the extreme limits of the  $20.9 \pm 1.0$  volume percent oxygen in the blend.

11.3.1.4 After a temperature controller set-point adjustment, wait at least 10 min before initiating a new calibration so that the combustion analyzer attains thermal equilibrium.

11.3.1.5 To be an acceptable data set, each single result is required to be within  $3.78 \pm 0.06$  ms.

11.3.1.6 If any of the three results is outside the limits, a system malfunction is suspected and diagnostic procedures to determine and remedy the problem are recommended before performing a new calibration. Refer to the instructions provided by the manufacturer.

11.3.2 *Methylcyclohexane Calibration Reference Material*—Perform two consecutive ignition delay determinations.

11.3.2.1 To be an acceptable data set, each single result is required to be within  $10.4 \pm 0.6$  ms and the average of the two results is required to be within  $10.4 \pm 0.5$  ms.

11.3.2.2 If either of the two single results or the average of the two results is outside the respective limits, system performance is unacceptable and it is recommended that diagnostic procedures be used to determine and remedy the problem before performing a new calibration. Refer to the instructions provided by the manufacturer.

11.3.3 The combustion analyzer calibration is complete when both heptane and methylcyclohexane data sets are acceptable.

11.4 *Quality Control (QC Testing)*—Conduct a regular statistical quality assurance (quality control) program in accordance with the techniques of Practice D6299 or equivalent.

11.4.1 This test method requires quality control testing at the beginning of each operating period by a single ignition delay determination for both the check standard (heptane) and one QC sample.