



SLOVENSKI STANDARD

SIST-TS CLC/TS 50600-5-1:2023

01-november-2023

**Informacijska tehnologija - Naprave in infrastruktura podatkovnega centra - 5-1.
del: Zrelostni model za upravljanje z energijo in okoljsko trajnostjo**

Information technology - Data centre facilities and infrastructures - Part 5-1: Maturity Model for Energy Management and Environmental Sustainability

Informationstechnik - Einrichtungen und Infrastrukturen von Rechenzentren - Teil 5-1: Reifegradmodell für Energiemanagement und Umweltverträglichkeit

Technologies de l'information - Installation et infrastructures des centres de traitement de données - Partie 5-1: Modèle de maturité pour la gestion de l'énergie et la durabilité environnementale

Ta slovenski standard je istoveten z: CLC/TS 50600-5-1:2023

ICS:

13.020.20	Okoljska ekonomija. Trajnostnost	Environmental economics. Sustainability
35.110	Omreževanje	Networking

SIST-TS CLC/TS 50600-5-1:2023 **en**

TECHNICAL SPECIFICATION
SPÉCIFICATION TECHNIQUE
TECHNISCHE SPEZIFIKATION

CLC/TS 50600-5-1

September 2023

ICS 35.110; 35.020; 35.160

Supersedes CLC/TS 50600-5-1:2021; CLC/TR 50600-99-2:2021; CLC/TR 50600-99-1:2021

English Version

**Information technology - Data centre facilities and infrastructures
- Part 5-1: Maturity Model for Energy Management and
Environmental Sustainability**

Technologies de l'information - Installation et infrastructures
des centres de traitement de données - Partie 5-1: Modèle
de maturité pour la gestion de l'énergie et la durabilité
environnementale

Informationstechnik - Einrichtungen und Infrastrukturen von
Rechenzentren - Teil 5-1: Reifegradmodell für
Energiemanagement und Umweltverträglichkeit

This Technical Specification was approved by CENELEC on 2023-08-28.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

[SIST-TS CLC/TS 50600-5-1:2023](https://standards.iteh.ai/catalog/standards/sist/318973ab-f568-447c-b034-3e2b5ecfa01c/sist-ts-clc-ts-50600-5-1-2023)

<https://standards.iteh.ai/catalog/standards/sist/318973ab-f568-447c-b034-3e2b5ecfa01c/sist-ts-clc-ts-50600-5-1-2023>



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

CLC/TS 50600-5-1:2023 (E)

Contents	Page
European foreword	5
Introduction.....	6
1 Scope.....	10
2 Normative references	10
3 Terms, definitions and abbreviations	11
3.1 Terms and definitions	11
3.2 Abbreviations	11
4 Concepts of data centre maturity	12
4.1 Overview	12
4.2 Basis of the maturity model	13
4.2.1 Elements of the maturity model.....	13
4.2.2 Reporting scheme.....	13
4.3 Progress along the Levels of the maturity model	14
4.4 Reporting of maturity model Levels.....	14
4.5 Presentation of the maturity model	15
5 Management and reporting	16
5.1 Existing Data Centres (in operation) and new data centres	16
5.1.1 Level 1 to level 3	16
5.1.2 Level 4	20
5.1.3 Level 5	21
5.2 New data centre infrastructure.....	23
5.2.1 Level 1 to level 3	23
5.2.2 Level 4	23
5.2.3 Level 5	24
6 Building infrastructure.....	25
6.1 Existing data centres (in operation) and new data centres	25
6.1.1 Level 1 to level 3	25
6.1.2 Level 4	25
6.1.3 Level 5	25
6.2 New data centre infrastructure.....	25
6.2.1 Level 1 to level 3	25
6.2.2 Level 4	26
6.2.3 Level 5	27
7 Power supply and distribution infrastructure	27
7.1 Existing data centres (in operation) and new data centres	27
7.1.1 Level 1 to level 3	27
7.1.2 Level 4	28
7.1.3 Level 5	29
7.2 New data centre infrastructure.....	29
7.2.1 Level 1 to level 3	29
7.2.2 Level 4	30
7.2.3 Level 5	30
8 Environmental control infrastructure	30
8.1 Existing data centres (in operation) and new data centres	30

8.1.1	Level 1 to 3	30
8.1.2	Level 4	34
8.1.3	Level 5	36
8.2	New data centre infrastructure.....	36
8.2.1	Level 1 to level 3	36
8.2.2	Level 4	38
8.2.3	Level 5	38
9	ICT compute.....	39
9.1	Existing data centres (in operation) and new data centres	39
9.1.1	Level 1 to level 3	39
9.1.2	Level 4	42
9.1.3	Level 5	44
9.2	New data centre infrastructure.....	44
9.2.1	Level 1 to level 3	44
9.2.2	Level 4	44
9.2.3	Level 5	44
10	ICT Storage.....	45
10.1	Existing data centres (in operation) and new data centres	45
10.1.1	Level 1 to level 3	45
10.1.2	Level 4	46
10.1.3	Level 5	48
10.2	New data centre infrastructure.....	48
10.2.1	Level 1 to level 3	48
10.2.2	Level 4	48
10.2.3	Level 5	49
11	ICT network.....	49
11.1	Existing data centres (in operation) and new data centres	49
11.1.1	Level 1 to level 3	49
11.1.2	Level 4	50
11.1.3	Level 5	51
11.2	New data centre infrastructure.....	51
11.2.1	Level 1 to level 3	51
11.2.2	Level 4	51
11.2.3	Level 5	51
12	ICT Software	51
12.1	Existing data centres (in operation) and new data centres	51
12.1.1	Level 1 to level 3	51
12.1.2	Level 4	52
12.1.3	Level 5	52
12.2	New data centre infrastructure.....	53
12.2.1	Level 1 to level 3	53
12.2.2	Level 4	53
12.2.3	Level 5	53
Annex A (informative)	Additional practices for energy management	54
A.1	Practices for energy management	54
A.2	Environmental classifications.....	56

CLC/TS 50600-5-1:2023 (E)

Annex B (informative) Additional practices for environmental sustainability	58
B.1 General	58
B.2 Practices for environmental sustainability	60
Annex C (informative) Cooling technologies	63
Bibliography	64
Figures	
Figure 1 — Schematic relationship between the EN 50600 series of documents	8
Figure 2 — Example of the graphical representation of data centre maturity elements	15
Figure 3 — Example of the graphical representation of data centre maturity elements including some of Level 0	16
Figure B.1 — Example system boundary for data centre LCA	60
Tables	
Table A.1 — Equipment environmental specifications	57
Table A.2 — Equipment environmental specifications	57
Table C.1 — Examples of data centre cooling technologies	63

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST-TS CLC/TS 50600-5-1:2023](https://standards.iteh.ai/catalog/standards/sist/318973ab-f568-447c-b034-3e2b5ecfa01c/sist-ts-clc-ts-50600-5-1-2023)

<https://standards.iteh.ai/catalog/standards/sist/318973ab-f568-447c-b034-3e2b5ecfa01c/sist-ts-clc-ts-50600-5-1-2023>

European foreword

This document (CLC/TS 50600-5-1:2023) has been prepared by CLC/TC 215, "Electrotechnical aspects of telecommunication equipment".

This document supersedes CLC/TS 50600-5-1:2021, CLC/TR 50600-99-1:2021 and CLC/TR 50600-99-2:2021 and all of their amendments and corrigenda (if any).

CLC/TS 50600-5-1:2023 includes the following significant technical changes with respect to CLC/TS 50600-5-1:2021:

- a) document has been completely restructured with clauses organized in topics rather than maturity levels;
- b) previous references to CLC/TR 50600-99-1:2021 and CLC/TR 50600-99-2:2021 have been replaced by including the text into this document;
- c) the practices have been technically revised and consolidated to remove redundant requirements;
- d) practices of CLC/TR 50600-99-1:2021 and CLC/TR 50600-99-2:2021 not used in the maturity levels have been transferred to Annex A and Annex B, respectively, thus replacing the Technical Reports CLC/TR 50600-99-1:2021 and CLC/TR 50600-99-2:2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a standardization request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

CLC/TS 50600-5-1:2023 (E)**Introduction**

The unrestricted access to internet-based information demanded by the information society has led to an exponential growth of both internet traffic and the volume of stored/retrieved data. Data centres are housing and supporting the information technology and network telecommunications equipment for data processing, data storage and data transport. They are required both by network operators (delivering those services to customer premises) and by enterprises within those customer premises.

Data centres usually provide modular, scalable and flexible facilities and infrastructures to easily accommodate the rapidly changing requirements of the market. In addition, energy consumption of data centres has become critical both from an environmental point of view (reduction of environmental footprint) and with respect to economical considerations (cost of energy) for the data centre operator.

The implementation of data centres varies in terms of:

- a) purpose (enterprise, co-location, co-hosting or network operator facilities);
- b) security level;
- c) physical size;
- d) accommodation (mobile, temporary and permanent constructions).

The needs of data centres also vary in terms of availability of service, the provision of security and the objectives for energy efficiency. These needs and objectives influence the design of data centres in terms of building construction, power distribution, environmental control, telecommunications cabling and physical security as well as the operation of the data centre. Effective management and operational information is important in order to monitor achievement of the defined needs and objectives.

Recognizing the substantial resource consumption, particularly of energy, of larger data centres, it is also important to provide tools for the assessment of that consumption both in terms of overall value and of source mix and to provide Key Performance Indicators (KPIs) to evaluate trends and drive performance improvements.

At the time of publication of this document, the EN 50600 series is designed as a framework of standards, technical specifications and technical reports covering the design, the operation and management, the key performance indicators for energy efficient operation of the data centre as well as a data centre maturity model.

The EN 50600-2 series defines the requirements for the data centre design.

The EN 50600-3 series defines the requirements for the operation and the management of the data centre.

The EN 50600-4 series defines the key performance indicators for the data centre.

The CLC/TS 50600-5 series defines the data centre maturity model requirements and recommendations.

The CLC/TR 50600-99-X Technical Reports cover recommended practices and guidance for specific topics around data centre operation and design.

This series of documents specifies requirements and recommendations to support the various parties involved in the design, planning, procurement, integration, installation, operation, maintenance and assessment of facilities and infrastructures within data centres. These parties include:

- 1) owners, operators, facility managers, ICT managers, project managers, main contractors;
- 2) consulting engineers, architects, building designers and builders, system and installation designers, auditors, testing and commissioning agents;
- 3) facility and infrastructure integrators, suppliers of equipment;
- 4) installers, maintainers;
- 5) policy makers, assessors.

At the time of publication of this document, the EN 50600 series will comprise the following standards and documents:

- EN 50600-1, *Information technology — Data centre facilities and infrastructures — Part 1: General concepts*
- EN 50600-2-1, *Information technology — Data centre facilities and infrastructures — Part 2-1: Building construction*
- EN 50600-2-2, *Information technology — Data centre facilities and infrastructures — Part 2-2: Power supply and distribution*
- EN 50600-2-3, *Information technology — Data centre facilities and infrastructures — Part 2-3: Environmental control*
- EN 50600-2-4, *Information technology — Data centre facilities and infrastructures — Part 2-4: Telecommunications cabling infrastructure*
- EN 50600-2-5, *Information technology — Data centre facilities and infrastructures — Part 2-5: Security systems*
- EN 50600-3-1, *Information technology — Data centre facilities and infrastructures — Part 3-1: Management and operational information*
- EN 50600-4-1, *Information technology — Data centre facilities and infrastructures — Part 4-1: Overview of and general requirements for key performance indicators*
- EN 50600-4-2, *Information technology — Data centre facilities and infrastructures — Part 4-2: Power Usage Effectiveness*
- EN 50600-4-3, *Information technology — Data centre facilities and infrastructures — Part 4-3: Renewable Energy Factor*
- EN 50600-4-6, *Information technology — Data centre facilities and infrastructures — Part 4-6: Energy Reuse Factor*
- EN 50600-4-7, *Information technology — Data centre facilities and infrastructures — Part 4-7: Cooling Efficiency Ratio*
- EN 50600-4-8, *Information technology — Data centre facilities and infrastructures — Part 4-8: Carbon usage effectiveness*
- EN 50600-4-9, *Information technology — Data centre facilities and infrastructures — Part 4-9: Water usage effectiveness*
- CLC/TS 50600-5-1, *Information technology — Data centre facilities and infrastructures — Part 5-1: Maturity Model for Energy Management and Environmental Sustainability*
- CLC/TR 50600-99-3, *Information technology — Data centre facilities and infrastructures — Part 99-3: Guidance for the application of EN 50600 series*

The inter-relationship of the documents within the EN 50600 series is shown in Figure 1.

CLC/TS 50600-5-1:2023 (E)




Figure 1 — Schematic relationship between the EN 50600 series of documents

EN 50600-2-X documents specify requirements and recommendations for particular facilities and infrastructures to support the relevant classification for “availability”, “physical security” and “energy efficiency enablement” selected from EN 50600-1.

EN 50600-3-X documents specify requirements and recommendations for data centre operations, processes and management.

EN 50600-4-X documents specify requirements and recommendations for key performance indicators (KPIs) used to assess and improve the resource usage efficiency and effectiveness, respectively, of a data centre.

This document, CLC/TS 50600-5-1 describes a 5-level maturity model which separately addresses multiple elements of the facilities, infrastructures, the information and communication technology (ICT) equipment and software of the data centre; while the current document focusses on the environmental impact (energy management and environmental sustainability), other elements are expected to be included in future documents.

NOTE The term “environmental sustainability” is used recognizing that well established treatments of “sustainability” feature three separate viability objectives (environmental, economic and social). For the purposes of this document, only elements of environmental viability are considered.

The maturity model covers design, procurement, operation and end-of-life.

The purpose of the document is to enable data centre owners/operators to:

- employ a framework to baseline their data centre design and practices;
- determine the level of maturity applicable to their data centre by assessment;
- identify relevant guidance on potential areas of improvement together with the anticipated benefits to justify the resources required;
- develop an action plan to migrate to higher maturity levels.

This document supports the wider adoption of recommended practices of other documents in the EN 50600 series and those of other recognized relevant standards in the area of energy management and environmental

sustainability. The document can be useful in an assessment process to define the level of environmental impact maturity of a data centre.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST-TS CLC/TS 50600-5-1:2023](https://standards.iteh.ai/catalog/standards/sist/318973ab-f568-447c-b034-3e2b5ecfa01c/sist-ts-clc-ts-50600-5-1-2023)

<https://standards.iteh.ai/catalog/standards/sist/318973ab-f568-447c-b034-3e2b5ecfa01c/sist-ts-clc-ts-50600-5-1-2023>

CLC/TS 50600-5-1:2023 (E)**1 Scope**

This document specifies a maturity model addressing the environmental impact (energy management and environmental sustainability) of the facilities, infrastructures and the information and communication technology (ICT) equipment accommodated by and the and ICT software deployed in the data centre.

NOTE The term “environmental sustainability” is used recognizing that well established treatments of “sustainability” feature three separate viability objectives (environmental, economic and social). For the purposes of this document, only elements of environmental viability are considered.

The elements address the whole life cycle including design, procurement, operation and decommissioning.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 14511 (all parts), *Air conditioners, liquid chilling packages and heat pumps with electrically driven compressors for space heating and cooling*

EN 50600 (all parts), *Information technology – Data centre facilities and infrastructures*

EN 50600-1, *Information technology - Data centre facilities and infrastructures - Part 1: General concepts*

EN 50600-4-2, *Information technology - Data centre facilities and infrastructures - Part 4-2: Power Usage Effectiveness*

EN 50600-4-3, *Information technology - Data centre facilities and infrastructures - Part 4-3: Renewable Energy Factor*

EN 50600-4-6, *Information technology - Data centre facilities and infrastructures - Part 4-6: Energy Reuse Factor*

EN 50600-4-7, *Information technology - Data centre facilities and infrastructures - Part 4-7: Cooling Efficiency Ratio*

EN 50600-4-9, *Information technology - Data centre facilities and infrastructures - Part 4-9: Water Usage Effectiveness*

ISO/IEC 20000 (all parts), *Information technology — Service management*

ISO/IEC 30134-4, *Information technology — Data centres — Key performance indicators — Part 4: IT Equipment Energy Efficiency for servers (ITEEsv)*

ISO/IEC 30134-5, *Information technology — Data centres — Key performance indicators — Part 5: IT Equipment Utilization for servers (ITEUsv)*

EN ISO 14040, *Environmental management - Life cycle assessment - Principles and framework (ISO 14040)*

EN ISO 16890-1, *Air filters for general ventilation - Part 1: Technical specifications, requirements and classification system based upon particulate matter efficiency (ePM) (ISO 16890-1)*

ITU-T L.1410, *Methodology for environmental life cycle assessments of information and communication technology goods, networks and services*

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in the EN 50600 series and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1.1

airflow pathway

route taken by air to reach a specific point

3.1.2

albedo

diffuse reflectivity or reflecting power of a surface

3.1.3

embodied impact

environmental impact caused pre- and post-use, including during manufacture and disposal

3.1.4

make-up air

air introduced into a data centre space to replace air that is exhausted through ventilation or combustion processes

3.1.5

managed service

data centre operated to provide a defined set of services to its clients either proactively or as the managed service provider (not the client) determines that services are needed

3.1.6

system boundary

boundary that defines which processes are included in the LCA, chosen during goal and scope definition, and governs what is included in the flow model constructed in the subsequent inventory analysis

3.1.7

virtualization

creation of a virtual version of physical ICT equipment or resource to offer a more efficient use of ICT hardware

3.2 Abbreviations

For the purposes of this document the abbreviations of the EN 50600 series documents and the following apply.

ADP	abiotic depletion potential
BIOS	Basic input/output system
BMS	building management system
BREEAM	Building Research Establishment Environmental Assessment Methodology
DC-CED	Data Centre Cumulative Energy Demand
DC-CF	Data Centre Carbon Footprint

CLC/TS 50600-5-1:2023 (E)

DC-DMI	Direct Material Input of a Data Centre
DCiE	Data centre infrastructure efficiency
DCIM	Data centre infrastructure management
DMTF	Distributed Management Task Force
DX	direct expansion
EMS	Energy Management System
ICT	Information and communications technology
IP	Internet protocol
IPMI	Intelligent Platform Management Interface
ITIL	Information Technology Infrastructure Library
LCA	life cycle assessment
LCI	life cycle inventory
LEED	Leadership in Energy and Environmental Design
OCP	Open Compute Project
SMASH	Systems Management Architecture for Server Hardware
SNMP	Simple network management protocol
SPEC	Standard Performance Evaluation Corporation
WEEE	Waste Electrical and Electronic Equipment

4 Concepts of data centre maturity**4.1 Overview**

The maturity model specified by this document is applicable to all data centres and recognizes that the implementation of data centres varies in terms of:

- a) purpose (enterprise, co-location, co-hosting, or network operator facilities);
- b) availability class;
- c) security level;
- d) physical size;
- e) accommodation (mobile, temporary and permanent constructions).

The maturity model also recognizes that the purpose, or business model, of a data centre can prevent some of the elements to be addressed fully, or in part.

4.2 Basis of the maturity model

4.2.1 Elements of the maturity model

The eight elements addressed by the maturity model are:

- a) Management and Reporting;
- b) Building infrastructure;
- c) Power supply and distribution infrastructure;
- d) Environmental control infrastructure;
- e) ICT Compute;
- f) ICT Storage;
- g) ICT Networking;
- h) ICT Software.

NOTE Security systems and telecommunications cabling are not addressed in this document.

There are 5 levels applicable to each element with the progression within the model designated Level 1 to Level 5.

4.2.2 Reporting scheme

In many cases, the application of practices requires documentation of the result, e.g. in terms of a design decision, a policy or a process to be implemented. While there is no specific format mandated this document recommends using a structured reporting as follows.

A Business Organization Report can comprise the documentation of:

- a) ICT and facility organization;
- b) procurement policies;
- c) service design and charging models;
- d) maintenance strategy.

An Operational Management Report can comprise the documentation of:

- 1) Operational Management (see EN 50600-3-1 for further information);
- 2) Design Reference Documentation (see EN 50600-1 for further information);
- 3) Energy Management Report (see EN ISO 50001 for further information).

An Environmental Management Plan can comprise the documentation of:

- renewable energy use (REF - see EN 50600-4-3 for further information);
- carbon usage report (CUE - see EN 50600-4-8 for further information);
- water management report (WUE - see EN 50600-4-9 for further information);
- pollutant emission to air;