

Designation: B228-04 Designation: B228 - 11

Standard Specification for Concentric-Lay-Stranded Copper-Clad Steel Conductors¹

This standard is issued under the fixed designation B228; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

1. Scope

- 1.1 This specification covers bare concentric-lay-stranded conductors made from bare round copper-clad steel wires for general use for electrical purposes.
 - 1.2 For the purpose of this specification, conductors are classified as follows: Grade 40 HS, Grade 30 HS, and Grade 30 EHS.
 - 1.3The values stated in inch-pound units are to be regarded as the standard. The values given in parentheses are in SI units.
- 1.3 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.
- 1.4 This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

2. Referenced Documents

- 2.1 The following documents of the issue in effect on the date of material purchase form a part of this specification to the extent referenced herein:
 - 2.2 ASTM Standards:²
 - B227 Specification for Hard-Drawn Copper-Clad Steel Wire
 - B354 Terminology Relating to Uninsulated Metallic Electrical Conductors
 - 2.3 ANSI Standards:
 - C 42 Definitions of Electrical Terms³
 - 2.4 National Institute of Standards and Technology: Compared Technology
 - NBS Handbook 100—Copper Wire Tables⁴

3. Ordering Information

- 3.1 Orders for material under this specification shall include the following information: be82fdd03c/astm-b228-11
- 3.1.1 Quantity of each size and grade;
- 3.1.2 Conductor size: approximate diameter in fractions of an inch, or number and AWG size of individual wires (Section 7 and Table 1);
 - 3.1.3 Grade (see 1.2 and Table 1);
 - 3.1.4 Direction of lay of outer layer, if other than left-hand (see 6.3);
 - 3.1.5 When physical tests shall be made (see 8.2);
 - 3.1.6 Package size (see 13.1);
 - 3.1.7 Special package marking, if required (Section 12);
 - 3.1.8 Lagging, if required (see 13.2); and
 - 3.1.9 Place of inspection (Section 14).
- 3.2 In addition, Supplementary Requirements shall apply only when specified by the purchaser in the inquiry, contract, or purchase order for direct procurement by agencies of the U. S. Government (S1, S2, and S3).

¹ This specification is under the jurisdiction of ASTM Committee B01 on Electrical Conductors and is the direct responsibility of Subcommittee B01.06 on Composite Conductors.

Current edition approved April 1, 2004:2011. Published April 2004:May 2011. Originally approved in 1948. Last previous edition approved in 2002:2004 as B228 – 024. DOI: 10.1520/B0228-04.10.1520/B0228-11.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, http://www.ansi.org.

⁴ Available from National Institute of Standards and Technology (NIST), 100 Bureau Dr., Stop 3460;1070, Gaithersburg, MD 20899-3460;20899-1070, http://www.nist.gov.



TABLE 1 Construction Requirements and Breaking Strength of Concentric-Lay-Stranded Copper-Clad Steel Conductors

Note 1—Metric Equivalents—For diameter, 1 in. = 25.40 mm (round to four significant figures); for breaking strength, 1 lb = 0.45359 kg (round to four significant figures).

Size Designation		 Conductor Diameter, in.^A 	Rated Breaking Strength, min, lb ^B		
Inch ^C	AWG ^D	— Conductor Diameter, In." —	Grade 40 HS	Grade 30 HS	Grade 30 EHS
7∕8	19 No. 5	0.910	50 240	55 570	66 910
7 <u>/8</u> 13/ ₁₆	19 No. 5	0.910	48 740	53 910	64 910
13/16	19 No. 6	0.810	41 600	45 830	55 530
13/16	19 No. 6	0.810	40 370	44 470	53 880
23/32	19 No. 7	0.721	34 390	37 740	45 850
23/32	19 No. 7	0.721	33 360	36 610	44 480
<u>21/₃₂</u>	19 No. 8	0.642	28 380	31 040	37 690
21/32	19 No. 8	0.642	27 550	30 140	36 590
9/16	19 No. 9	0.572	23 390	25 500	30 610
	19 No. 9	0.572	22 690	24 730	29 700
9/16 5/8	7 No. 4	0.613	22 310	24 780	29 430
<u>5/8</u>	7 No. 4	<u>0.613</u>	<u>21 630</u>	24 040	28 540
9/16	7 No. 5	0.546	18 510	20 470	24 650
	7 No. 5	0.546	17 960	19 860	23 910
$\frac{9/16}{1/2}$	7 No. 6	0.486	15 330	16 890	20 460
1/2	7 No. 6	0.486	14 870	16 390	19 850
<u>1⁄2</u> 7 <u>∕16</u>	7 No. 7	0.433	12 670	13 910	16 890
7/16 7/16	7 No. 7	0.433	12 290	13 490	16 390
716	<u>/ No. /</u>	0.400	12 230	10 400	10 390
3/8	7 No. 8	0.385	10 460	11 440	13 890
3/8	7 No. 8	0.385	<u>10 150</u>	<u>11 100</u>	13 480
11/32	7 No. 9	0.343	-8616	-9393 -	11 280
11/32	7 No. 9	<u>0.343</u>	<u>8359</u>	<u>9113</u>	10 940
5/16	7 No. 10	0.306	7121	-7758	9 196
<u>5/16</u>	7 No. 10	0.306	6913	<u>7531</u>	8928
	3 No. 5	0.392	8373	-9262	11 860
<u></u>	3 No. 5	0.392	8122	8985	10 820
	3 No. 6	0.349	6934	7639	-9754
····	3 No. 6	0.349	6728	7412	8980
	3 No. 7	0.311 And	5732	6291	7922
····	3 No. 7	<u>0.311</u>	5559	6102	<u>7413</u>
	3 No. 8	0.277	-4730	-5174	-6282
<u></u>	3 No. 8	0.277 CTM D	1 4592	5023	6099
	3 No. 9	0.247 STWI B2	3898	4250	5129
https://stand	dards it 3 No. 9 atalog	g/standard <u>0.247</u> / e8fb895	2-f09c <u>3781</u> 89-bd8	6-92be 4122 d 03c/a	astm-b2 4950 1
	-3 No. 10	0.220	3221	-3509	-4160
· · ·	3 No. 10	0.220	<u>3127</u>	<u>3407</u>	<u>4039</u>
· · ·	-3 No. 12	0.174	-1715		
<u></u>	3 No. 12	<u>0.174</u>	<u>1647</u>	<u>1719</u>	<u>2564</u>

^A Diameter of circumscribing circle.

4. Material for Wires

- 4.1 The purchaser shall specify the grade of wire to be used in the conductor.
- 4.2 Before stranding, the copper-clad steel wire shall meet all the requirements of Specification B227.
- 4.3 All wires in the conductor shall be of the same grade and quality.

5. Joints

5.1 Joints or splices may be made in the finished individual copper-clad steel wires composing concentric-lay-stranded conductors, using more than three wires provided that such joints or splices have a protection equivalent to that of the wire itself and that they do not decrease the strength of the finished stranded conductor below the minimum breaking strength shown in Table 1. Such joints or splices shall be not closer than 50 ft (15 m) to any other joint in the same layer in the conductor (Note 1).

Note 1—Joints or splices in individual copper-clad steel wires in their finished size are made by electrical butt welding. Two types of joints are used and are described as follows:

(a) Weld-Annealed Joints—After butt welding, the wire is annealed for a distance of approximately 5 in. (127 mm) on each side of the weld. The weld is then protected from corrosion with a snug fitting seamless copper sleeve which extends at least 3/8 in. (9.5 mm) on each side of the weld and which is thoroughly sealed to the wire with solder. The wall thickness of the sleeve is at least 10 % of the radius of the wire.

^B Minimum breaking strength is calculated using the minimum diameter of the individual wire and the minimum tensile strength from B227. Breaking loads of 7-wire and 19-wire conductors are taken as 90 % of the sum of the breaking loads of the individual wires; breaking load of 3-wire conductors is taken as 95 % of the sum of the breaking loads of the individual wires.

^C The designation "Inch" is the approximate diameter in proper fraction of an inch.

^D The designation of "AWG" is a combination of the number of wires each of the American Wire Gage size indicated by "No."