



**SLOVENSKI STANDARD**  
**oSIST prEN IEC 61788-23:2023**  
**01-september-2023**

---

**Superprevodnost - 23. del: Meritve deleža preostale upornosti - Delež preostale upornosti niobijskih superprevodnikov**

Superconductivity - Part 23: Residual resistance ratio measurement - Residual resistance ratio of cavity-grade Nb superconductors

Supraleitfähigkeit - Teil 23: Messung des Restwiderstandsverhältnisses - Restwiderstandsverhältnis von hochreinen Nb-Supraleitern für Kavitäten

Supraconductivité - Partie 23: Mesurage du rapport de résistance résiduelle - Rapport de résistance résiduelle des supraconducteurs de Nb à cavités

**Ta slovenski standard je istoveten z: prEN IEC 61788-23:2023**

---

**ICS:**

17.220.20	Merjenje električnih in magnetnih veličin	Measurement of electrical and magnetic quantities
29.050	Superprevodnost in prevodni materiali	Superconductivity and conducting materials

**oSIST prEN IEC 61788-23:2023**                      **en**





# 90/503/CDV

## COMMITTEE DRAFT FOR VOTE (CDV)

PROJECT NUMBER:  
**IEC 61788-23 ED3**

DATE OF CIRCULATION:  
**2023-06-09**

CLOSING DATE FOR VOTING:  
**2023-09-01**

SUPERSEDES DOCUMENTS:  
**90/499/RR**

IEC TC 90 : SUPERCONDUCTIVITY	
SECRETARIAT: Japan	SECRETARY: Mr Jun Fujikami
OF INTEREST TO THE FOLLOWING COMMITTEES:	PROPOSED HORIZONTAL STANDARD: <input type="checkbox"/> Other TC/SCs are requested to indicate their interest, if any, in this CDV to the secretary.
FUNCTIONS CONCERNED: <input type="checkbox"/> EMC <input type="checkbox"/> ENVIRONMENT <input type="checkbox"/> QUALITY ASSURANCE <input type="checkbox"/> SAFETY	
<input checked="" type="checkbox"/> SUBMITTED FOR CENELEC PARALLEL VOTING <b>Attention IEC-CENELEC parallel voting</b> The attention of IEC National Committees, members of CENELEC, is drawn to the fact that this Committee Draft for Vote (CDV) is submitted for parallel voting. The CENELEC members are invited to vote through the CENELEC online voting system.	<input type="checkbox"/> NOT SUBMITTED FOR CENELEC PARALLEL VOTING

This document is still under study and subject to change. It should not be used for reference purposes.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Recipients of this document are invited to submit, with their comments, notification of any relevant "In Some Countries" clauses to be included should this proposal proceed. Recipients are reminded that the CDV stage is the final stage for submitting ISC clauses. (SEE [AC/22/2007](#) OR [NEW GUIDANCE DOC](#)).

TITLE:

**Superconductivity - Part 23: Residual resistance ratio measurement - Residual resistance ratio of cavity-grade Nb superconductors**

PROPOSED STABILITY DATE: 2030

NOTE FROM TC/SC OFFICERS:

**Copyright © 2023 International Electrotechnical Commission, IEC.** All rights reserved. It is permitted to download this electronic file, to make a copy and to print out the content for the sole purpose of preparing National Committee positions. You may not copy or "mirror" the file or printed version of the document, or any part of it, for any other purpose without permission in writing from IEC.

1

## CONTENTS

2	FOREWORD .....	4
3	INTRODUCTION .....	6
4	1 Scope .....	7
5	2 Normative references .....	7
6	3 Terms and definitions .....	7
7	4 Principle .....	8
8	5 Measurement apparatus .....	9
9	5.1 Mandrel or base plate .....	9
10	5.2 Cryostat and support of mandrel or base plate .....	9
11	6 Specimen preparation .....	10
12	7 Data acquisition and analysis .....	11
13	7.1 Data acquisition hardware .....	11
14	7.2 Resistance ( $R_1$ ) at room temperature .....	11
15	7.3 Residual resistance ( $R_2$ ) just above the superconducting transition .....	11
16	7.4 Validation of the residual resistance measurement .....	13
17	7.5 Residual resistance ratio .....	13
18	8 Uncertainty of the test method .....	13
19	9 Test report .....	13
20	9.1 General .....	13
21	9.2 Test information .....	13
22	9.3 Specimen information .....	14
23	9.4 Test conditions .....	14
24	9.5 RRR value .....	14
25	Annex A (informative) Additional information relating to the measurement of RRR .....	15
26	A.1 Considerations for specimens and apparatus .....	15
27	A.2 Considerations for specimen mounting orientation .....	16
28	A.3 Alternative methods for increasing temperature of specimen above superconducting transition temperature .....	16
29	A.3.1 General .....	16
30	A.3.2 Heater method .....	16
31	A.3.3 Controlled methods .....	16
32	A.4 Other test methods .....	16
33	A.4.1 General .....	16
34	A.4.2 Measurement of resistance versus time .....	17
35	A.4.3 Comparison of ice point and room temperature .....	17
36	A.4.4 Extrapolation of the resistance to 4,2 K .....	17
37	A.4.5 Use of magnetic field to suppress superconductivity at 4,2 K .....	18
38	A.4.6 AC techniques .....	18
39	Annex B (informative) Uncertainty considerations .....	19
40	B.1 Overview .....	19
41	B.2 Definitions .....	19
42	B.3 Consideration of the uncertainty concept .....	20
43	B.4 Uncertainty evaluation example for IEC TC 90 standards .....	22
44	Annex C (informative) Uncertainty evaluation for resistance ratio measurement of Nb superconductors .....	24
45		
46		

47	C.1	Evaluation of uncertainty .....	24
48	C.1.1	Room temperature measurement uncertainty .....	24
49	C.1.2	Cryogenic measurement uncertainty .....	25
50	C.1.3	Estimation of uncertainty for typical experimental conditions .....	27
51	C.2	Inter-laboratory comparison summary .....	28
52		Bibliography .....	29
53			
54		Figure 1 – Relationship between temperature and resistance near the superconducting	
55		transition.....	8
56		Figure A.1 – Determination of the value of $R_2$ from a resistance versus time plot .....	17
57		Figure C.1 – Graphical description of the uncertainty of regression related to the	
58		measurement of $R_2$ .....	27
59			
60		Table B.1 – Output signals from two nominally identical extensometers .....	20
61		Table B.2 – Mean values of two output signals .....	20
62		Table B.3 – Experimental standard deviations of two output signals .....	21
63		Table B.4 – Standard uncertainties of two output signals .....	21
64		Table B.5 – Coefficients of variation of two output signals .....	21
65		Table C.1 – Uncertainty of measured parameters .....	27
66		Table C.2 – RRR values obtained by inter-laboratory comparison using liquid helium .....	28

67

68

oSIST prEN IEC 61788-23:2023

<https://standards.iteh.ai/catalog/standards/sist/4d624d4e-38fa-45ad-9d70-6830948ee2d6/osist-pren-iec-61788-23-2023>

69

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

70

71

72

73

74

75

76

77

**SUPERCONDUCTIVITY –****Part 23: Residual resistance ratio measurement –  
Residual resistance ratio of cavity-grade Nb superconductors****FOREWORD**

78

79

80

81

82

83

84

85

86

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.

87

88

89

2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.

90

91

92

93

3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.

94

95

96

4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.

97

98

99

5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.

100

6) All users should ensure that they have the latest edition of this publication.

101

102

103

104

105

7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.

106

107

8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

108

109

9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

110

111

IEC 61788-23 has been prepared by IEC technical committee 90: Superconductivity. It is an International Standard.

112

113

This second edition cancels and replaces the first edition published in 2018. This edition constitutes a technical revision.

114

115

This edition includes the following significant technical changes with respect to the previous edition:

116

117

a) The scope of this standard was modified to restrict the range of residual resistance ratio to that encountered by providers of material for superconducting radio-frequency cavities.

118

b) The references to technical material were updated and corrected.

119 The text of this International Standard is based on the following documents:

FDIS	Report on voting
90/478/FDIS	90/482/RVD

120 Full information on the voting for its approval can be found in the report on voting indicated in  
121 the above table.  
122

123 The language used for the development of this International Standard is English.

124 This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in  
125 accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available  
126 at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are  
127 described in greater detail at [www.iec.ch/standardsdev/publications](http://www.iec.ch/standardsdev/publications).

128 A list of all parts in the IEC 61788 series, published under the general title *Superconductivity*,  
129 can be found on the IEC website.

130 The committee has decided that the contents of this document will remain unchanged until the  
131 stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the  
132 specific document. At this date, the document will be

- 133 • reconfirmed,
- 134 • withdrawn,
- 135 • replaced by a revised edition, or
- 136 • amended.

137 <https://standards.iteh.ai/catalog/standards/sist/4d624d4e-38fa-45ad-9d70->

**IMPORTANT – The 'color inside' logo on the cover page of this publication indicates that it contains colors which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a color printer.**

138

139

140

## INTRODUCTION

141 High-purity niobium is the chief material used to make superconducting radio-frequency cavities.  
142 Similar grades of niobium may be used in the manufacture of superconducting wire.  
143 Procurement of raw materials and quality assurance of delivered products often use the residual  
144 resistance ratio (RRR) to specify or assess the purity of a metal. RRR is defined for non-  
145 superconducting metals as the ratio of electrical resistance measured at room temperature  
146 (293 K) to the resistance measured for the same specimen at low temperature (~4,2 K). The  
147 low-temperature value is often called the residual resistance. Higher purity is associated with  
148 higher values of RRR.

149 Niobium presents special problems due to its transformation to a superconducting state at ~9 K,  
150 so DC electrical resistance is effectively zero below this temperature. The definition above  
151 would then yield an infinite value for RRR. This document describes a test method to determine  
152 the residual resistance value by using a plot of the resistance to temperature as the test  
153 specimen is gradually warmed through the superconducting transition in the absence of an  
154 applied magnetic field. This results in a determination of the residual resistance at just above  
155 superconducting transition, ~10 K, from which RRR is subsequently determined.

156 International Standards also exist to determine the RRR of superconducting wires. In contrast  
157 to superconducting wires, which are usually a composite of a superconducting material and a  
158 non-superconducting material and the RRR value is representative of only the non-  
159 superconducting component, here the entire specimen is composed of superconducting niobium.  
160 Frequently, niobium is procured as a sheet, bar, tube, or rod, and not as a wire. For such forms,  
161 test specimens will likely be a few millimetres in the dimensions transverse to electric current  
162 flow. This difference is significant when making electrical resistance measurements, since  
163 niobium samples will likely be much longer than that for the same length-to-diameter ratio as a  
164 wire, and higher electrical current may be required to produce sufficient voltage signals.  
165 Guidance for sample dimensions and electrical connections is provided in Annex A. Test  
166 apparatus should also take into consideration aspects such as the orientation of a test specimen  
167 relative to the liquid helium surface, accessibility through ports on common liquid helium dewars,  
168 design of current contacts, and minimization of thermal gradients over long specimen lengths.  
169 These aspects distinguish this document from similar wire standards.

170 Other test methods have been used to determine RRR. Some methods use a measurement at  
171 a temperature other than 293 K for the high resistance value. Some methods use extrapolations  
172 at 4,2 K in the absence of an applied magnetic field for the low resistance value. Other methods  
173 use an applied magnetic field to suppress superconductivity at 4,2 K. A comparison between  
174 this document and some other test methods is presented in Annex A. Note that systematic  
175 differences of up to 10 % are produced by these other methods, which is larger than the target  
176 uncertainty of this document. It is therefore important to apply this document or the appropriate  
177 corrections listed in Annex A according to the test method used.

178 Whenever possible, this test method should be transferred to vendors and collaborators who  
179 also perform RRR measurements. To promote consistency, the results of inter-laboratory  
180 comparisons are described in Clause C.2.

181

182



## SUPERCONDUCTIVITY –

### Part 23: Residual resistance ratio measurement – Residual resistance ratio of cavity-grade Nb superconductors

183  
184  
185  
186  
187  
188  
189

#### 190 **1 Scope**

191 This part of IEC 61788 addresses a test method for the determination of the residual resistance  
192 ratio (RRR),  $r_{RRR}$ , of cavity-grade niobium. This method is intended for high-purity niobium  
193 grades with  $150 < r_{RRR} < 600$ . The test method is valid for specimens with rectangular or round  
194 cross-section, cross-sectional area greater than  $1 \text{ mm}^2$  but less than  $20 \text{ mm}^2$ , and a length not  
195 less than 10 nor more than 25 times the width or diameter.

#### 196 **2 Normative references**

197 The following documents are referred to in the text in such a way that some or all of their content  
198 constitutes requirements of this document. For dated references, only the edition cited applies.  
199 For undated references, the latest edition of the referenced document (including any  
200 amendments) applies.

201 IEC 60050-815, *International Electrotechnical Vocabulary – Part 815: Superconductivity*  
202 (available at: [www.electropedia.org](http://www.electropedia.org))

#### 203 **3 Terms and definitions** oSIST prEN IEC 61788-23:2023

<https://standards.iteh.ai/catalog/standards/sist/4d624d4e-38fa-45ad-9d70->

204 For the purposes of this document, the terms and definitions given in IEC 60050-815 and the  
205 following apply.

206 ISO and IEC maintain terminological databases for use in standardization at the following  
207 addresses:

- 208 • IEC Electropedia: available at <http://www.electropedia.org/>
- 209 • ISO Online browsing platform: available at <http://www.iso.org/obp>

#### 210 **3.1** 211 **residual resistance ratio**

##### 212 **RRR**

213  $r_{RRR}$

214 ratio of resistance at room temperature to the resistance just above the superconducting  
215 transition


$$r_{RRR} = R_1 / R_2 \quad (1)$$

216

217 where

218  $R_1$  is the resistance at 293 K;

219  $R_2$  is the resistance just above the superconducting transition, at  $\sim 10 \text{ K}$ .



220

221

222

223

**Figure 1 – Relationship between temperature and resistance near the superconducting transition**

224 Note 1 to entry: In this document, the room temperature is defined as  $20\text{ °C} = 293\text{ K}$ , and  $r_{\text{RRR}}$  is obtained as  
 225 follows: Figure 1 shows schematically resistance versus temperature data and the graphical procedure used to  
 226 determine the value of  $R_2$ . In Figure 1, the region of maximum slope is extrapolated upward in resistance, as shown  
 227 by line (a), and the region of minimum slope at temperatures above the transition temperature is extrapolated  
 228 downward in temperature, as shown by line (b). The intersection of these extrapolations at point A determines the  
 229 value of  $R_2$  as well as a temperature value  $T_c^*$ .

230 Note 2 to entry: The value  $T_c^*$  is similar to the transition value defined in [1]<sup>1</sup>, and should not be confused with the  
 231 value defined at the midpoint of the transition, called  $T_c$  in [2].

232 Note 3 to entry: Some standards or documented techniques, e.g. [3], [4], [5], [6], define  $r_{\text{RRR}}$  with the value of  $R_1$   
 233 determined at a temperature other than  $293\text{ K}$ , or the value of  $R_2$  determined at a temperature below the  
 234 superconducting transition. The user of this document should be alert for such differences in definition.

## 235 4 Principle

236 The 4-point DC electrical resistance technique shall be performed both at room temperature  
 237 and at cryogenic temperature. The test of resistance shall be done as a function of temperature.  
 238 Another test method of resistance as a function of time with increasing temperature is described  
 239 in Annex A.4.2.

240 The relative combined standard uncertainty of this method is 3 % with coverage factor 2.

241 Measurements shall have the following attributes.

242 a) Measuring current is sufficiently high to provide voltage signals of the order of  $1\text{ }\mu\text{V}$ . For  
 243 electrical safety, maximum current density should never exceed  $1\text{ A mm}^{-2}$ .

<sup>1</sup> Numbers in square brackets refer to the Bibliography.

- 244 b) Contact resistance for current leads is sufficiently low to avoid excessive heating of the  
245 sample. Typical cryogenic measurement conditions require power dissipation at contacts to  
246 be less than 1 mW.
- 247 c) Sample sizes are sufficiently large to minimize effects from cutting and handling damage.  
248 Typical samples are 1 mm to 3 mm in cross-section dimension and  $> 5 \text{ mm}^2$  in cross-  
249 sectional area.
- 250 d) Sample length is at least 10 times and not more than 25 times the width or diameter.
- 251 Annex A discusses considerations for sample dimensions and measuring current.

## 252 5 Measurement apparatus

### 253 5.1 Mandrel or base plate

254 A straight mandrel or base plate shall be used to support the specimen. Possible materials of  
255 construction include pure copper, pure aluminium, pure silver, electrical grades of Cu-Zr,  
256 Cu-Cr-Zr, Cu-Be, and other copper alloys, electrical grades of Al-Mg, Al-Ag, and other  
257 aluminium alloys, and electrical grades of silver alloys. These provide high thermal conductivity  
258 and serve to remove thermal gradients during measurement. The specimen shall be insulated  
259 from the mandrel. Possible insulating materials include polyethylene terephthalate, polyester,  
260 and polytetrafluoroethylene, which may be applied as foils, tapes, or coatings. Glass-fibre  
261 reinforced epoxy or other composite materials with good thermal conductivity at cryogenic  
262 temperature may also be used.

263 The base plate should have a clean and smooth surface finish. There should be no burrs, ridges,  
264 seams, or other asperities that may affect the specimen. High-purity niobium specimens are  
265 soft and are susceptible to indentation by surface flaws, and such indentations may alter the  
266 sample and invalidate the resistance measurement.

267 The mandrel or base plate shall support the entire length and width of the specimen. Mandrel  
268 or base plate geometry should not impose a bending strain of more than 0,2 % on the sample.

269 A thermometer accurate to 0,1 K is helpful but not required. The mandrel or base plate may  
270 incorporate a mounting for a cryogenic thermometer directly against the body of the mandrel or  
271 base plate and near the centre of the test specimen.

272 Practical base plates are at least 30 mm in length to accommodate assembly of pieces and  
273 handling of samples by human hands. Multiple samples may be mounted against a single base  
274 plate.

### 275 5.2 Cryostat and support of mandrel or base plate

276 The apparatus shall make provisions for mechanical support of the mandrel or base plate. In  
277 addition, such support shall provide electrical leads to carry currents for samples and  
278 thermometers, and measure their voltages. For  $R_1$  and  $R_2$  measurements, the support shall  
279 permit current to flow through only the sample, so that the entire resulting voltage measured is  
280 only that generated by the sample.

281 The support structure shall permit measurement of both  $R_1$  and  $R_2$  without dismounting or  
282 remounting the test specimen. Measurement of  $R_2$  shall require the use of a cryostat, which  
283 shall, moreover, integrate with the support.

284 The cryostat shall include a liquid helium reservoir at the bottom of a substantial vertical column.  
285 A support structure shall accommodate the raising and lowering of the sample into or out of the  
286 helium bath. In addition, anchoring of the sample position, either when immersed in liquid helium  
287 or suspended above the surface of the liquid at an arbitrary height, shall be provided. Such  
288 suspension permits the equilibration of temperature during measurement and slow increase of  
289 temperature with height above the helium bath. Alternatively, immersion of the sample into the  
290 bath followed by reduction of the bath level via boil-off or pressurized transfer can also be used  
291 to vary temperature.

292 A heater may be employed to warm the mandrel or base plate. The heater should be distributed  
293 along the mandrel and excessive power settings should be avoided. For instance, a point source  
294 of 1 W heat input operating at the centre of a 1 cm<sup>2</sup> mandrel upon which a 5 cm sample is  
295 mounted could produce temperature difference of 2,5 K along the sample if the thermal  
296 conductivity is 100 W m<sup>-1</sup> K<sup>-1</sup>.

297 Proper cryogenic techniques shall be followed for the construction of the cryostat and apparatus.  
298 This includes the use of low thermal conductivity materials such as thin-walled stainless steel  
299 tubes, composite materials, ceramics, and insulation, to prevent excessive boil-off due to heat  
300 conduction from the surroundings. A can or shield may surround the base plate or mandrel with  
301 mounted sample to improve thermal stability. Provisions for pressure relief and vacuum isolation  
302 of the liquid helium should be incorporated with the apparatus.

## 303 6 Specimen preparation

304 High-purity niobium is quite malleable, and even the slightest force can produce deformation of  
305 the material. Since dislocations are one source of electron scattering, specimen deformation  
306 can inadvertently contribute to the residual resistivity and affect the test result. Therefore,  
307 special protocols shall be observed when preparing the specimen. Cutting techniques shall  
308 avoid heat and strain to the extent possible. Discharge machining, fluid-jet cutting, or low-speed  
309 conventional machining are acceptable and widely-used techniques for applications using high-  
310 purity niobium. Specimens cut from larger pieces shall be protected and immobilized against a  
311 support piece during transport. Operations to de-burr samples shall not bend, excessively heat  
312 or otherwise damage the sample. Light sanding with fine paper is one acceptable approach.

313 Specimens should be rectangular or circular bars with uniform cross-section. Long sides of the  
314 specimen shall be parallel. Any twisting or curvature shall be avoided to ensure that bending or  
315 torsion is not applied to the test specimen during mounting to the mandrel or base plate.  
316 Specimens that form an arc or a U shape are acceptable provided that the entire curvature can  
317 be supported on a plane, without applying torsion to the bent specimen.

318 The specimen shall be clean and have no trace of residues from cutting fluids or any other  
319 surface contaminants. Degreasing with solvents, followed by ultrasonic cleaning using a mild  
320 water-based detergent, followed by rinsing with distilled or ultra-pure water, then drying in air,  
321 is preferred for cleaning residues. Chemical etching to clean the surface poses a risk of  
322 introducing contaminants, especially hydrogen and oxygen, and should be avoided. Gentle  
323 mechanical polishing of the regions where voltage taps and current leads attach is usually  
324 sufficient to remove surface oxides. Coating these regions with indium foil or another metal, for  
325 example by evaporation or sputtering, is an acceptable method to protect polished contacts  
326 provided that coating the entire specimen is avoided.

327 The test specimen shall be a single piece and shall not include any joints or splices.

328 A mechanical method shall be used to affix the test specimen to the mandrel or base plate.  
329 Installation and instrumentation of the specimen shall not apply excessive force, bending strain,  
330 tensile strain, or torsion to the specimen.