



Designation: ~~E 482–89(Reapproved 1996)~~ Designation: E482 – 11

Standard Guide for Application of Neutron Transport Methods for Reactor Vessel Surveillance, E706 (IID)¹

This standard is issued under the fixed designation E482; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 *Need for Neutronics Calculations*—An accurate calculation of the neutron fluence and fluence rate at several locations is essential for the analysis of integral dosimetry measurements and for predicting irradiation damage exposure parameter values in the pressure vessel. Exposure parameter values may be obtained directly from calculations or indirectly from calculations that are adjusted with dosimetry measurements; Guide E-944E944 and Practice E-853E853 define appropriate computational procedures.

1.2 *Methodology*—Neutronics calculations for application to reactor vessel surveillance encompass three essential areas: (1) validation of methods by comparison of calculations with dosimetry measurements in a benchmark experiment, (2) determination of the neutron source distribution in the reactor core, and (3) calculation of neutron fluence rate at the surveillance position and in the pressure vessel.

1.3 *This standard may involve hazardous materials, operations, and equipment. This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations requirements prior to use.*

2. Referenced Documents

2.1 ASTM Standards:

~~E170 Terminology Relating to Radiation Measurements and Dosimetry~~

~~E560 Practice for Extrapolating Reactor Vessel Surveillance Dosimetry Results, E706(IC)²~~

~~E693 Practice for Characterizing Neutron Exposures in Iron and Low Alloy Steels in Terms of Displacements Per Atom (DPA), E706(ID)^{2,2}~~

~~E706 Master Matrix for Light-Water Reactor Pressure Vessel Surveillance Standards, E706(O)²E 706(O)~~

~~E844 Guide for Sensor Set Design and Irradiation for Reactor Surveillance, E 706 (IIC)~~

~~E853 Practice for Analysis and Interpretation of Light-Water Reactor Surveillance Results, E706 (IA)²E706(IA)~~

~~E944 Guide for Application of Neutron Spectrum Adjustment Methods in Reactor Surveillance, (IIA)²~~

~~E1018 Guide for Application of ASTM Evaluated Cross Section Data File (ENDF/A), E706(IIIB)²~~

~~E706(IE) Damage Correlation for Reactor Vessel Surveillance~~

~~E706(IIIE) Benchmark Testing of Reactor Vessel Dosimetry³ Guide for Application of Neutron Spectrum Adjustment Methods in Reactor Surveillance, E 706 (IIA)~~

~~E1018 Guide for Application of ASTM Evaluated Cross Section Data File, Matrix E706 (IIB)~~

~~E2006 Guide for Benchmark Testing of Light Water Reactor Calculations~~

2.2 Nuclear Regulatory Documents:³

NUREG/CR-1861 LWR Pressure Vessel Surveillance Dosimetry Improvement Program: PCA Experiments and Blind Test

NUREG/CR-3318 LWR Pressure Vessel Surveillance Dosimetry Improvement Program: PCA Experiments, Blind Test, and Physics-Dosimetry Support for the PSF Experiments

NUREG/CR-3319 LWR Pressure Vessel Surveillance Dosimetry Improvement Program: LWR Power Reactor Surveillance Physics-Dosimetry Data Base Compendium

NUREG/CR-5049 Pressure Vessel Fluence Analysis and Neutron Dosimetry

¹ This guide is under the jurisdiction of ASTM Committee E-10 on Nuclear Technology and Applications and is the direct responsibility of Subcommittee E10.05 on Nuclear Radiation Metrology.

Current edition approved Oct. 27, 1989. Published December 1989. Originally published as E 482–76. Last previous edition E 482–82¹.

Current edition approved June 1, 2011. Published June 2011. Originally approved in 1976. Last previous edition approved in 2007 as E482 – 07 DOI: 10.1520/E0482-11.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* Vol 12.02, volume information, refer to the standard's Document Summary page on the ASTM website.

³ For standards that are in the draft stage and have not received an ASTM designation, see Section 5, as well as, Figures 1 and 2 of Matrix E 706E 706.

³ Available from Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

3. Significance and Use

3.1 General:

3.1.1 The methodology recommended in this guide specifies criteria for validating computational methods and outlines procedures applicable to pressure vessel related neutronics calculations for test and power reactors. The material presented herein is useful for validating computational methodology and for performing neutronics calculations that accompany reactor vessel surveillance dosimetry measurements (see Master Matrix E-706E706 and Practice E-853E853). Briefly, the overall methodology involves: (1) methods-validation calculations based on at least one well-documented benchmark problem, and (2) neutronics calculations for the facility of interest. The neutronics calculations ~~on~~of the facility of interest and ~~on~~of the benchmark problem should be ~~as nearly performed consistently, with important modeling parameters kept the same or as similar as is feasible;~~ feasible. In particular, the same energy group structure and common broad-group microscopic cross sections should be preserved for both problems. The neutronics calculations involve two tasks: (1) determination of the neutron source distribution in the reactor core by utilizing diffusion theory (or transport theory) calculations in conjunction with reactor power distribution measurements, and (2) performance of a fixed fission rate neutron source (fixed-source) transport theory calculation to determine the neutron fluence rate distribution in the reactor core, through the internals and in the pressure vessel. Some neutronics modeling details for the benchmark, test reactor, or the power reactor calculation will differ; therefore, the procedures described herein are general and apply to each case. (See NUREG/CR-5049, NUREG/CR-1861, NUREG/CR-3318, and NUREG/CR-3319.)

3.1.2 It is expected that transport calculations will be performed whenever pressure vessel surveillance dosimetry data become available and that quantitative comparisons will be performed as prescribed by 3.2.2. All dosimetry data accumulated that are applicable to a particular facility should be included in the comparisons.

3.2 *Validation*—Prior to performing transport calculations for a particular facility, the computational methods must be validated by comparing results with measurements made on a benchmark experiment. Criteria for establishing a benchmark experiment for the purpose of validating neutronics methodology should include those set forth in ~~Guide E-944~~Guides E944 and E2006 as well as those prescribed in 3.2.1. ~~A discussion of the limiting accuracy of benchmark validation procedures for the LWR surveillance program is given in Footnote 5.~~ A discussion of the limiting accuracy of benchmark validation discrete ordinate radiation transport procedures for the LWR surveillance program is given in Reference (1). Reference (2) provides details on the benchmark validation for a Monte Carlo radiation transport code.

3.2.1 *Requirements for Benchmarks* —In order for a particular experiment to qualify as a calculational benchmark, the following criteria are recommended:

3.2.1.1 Sufficient information must be available to accurately determine the neutron source distribution in the reactor core,

3.2.1.2 Measurements must be reported in at least two ex-core locations, well separated by steel or coolant,

3.2.1.3 Uncertainty estimates should be reported for dosimetry measurements and calculated fluences including calculated exposure parameters and calculated dosimetry activities,

3.2.1.4 Quantitative criteria, consistent with those specified in the methods validation 3.2.2, must be published and demonstrated to be achievable,

3.2.1.5 Differences between measurements and calculations should be consistent with the uncertainty estimates in 3.2.1.3,

3.2.1.6 Results for exposure parameter values of neutron fluence greater than 1 MeV and 0.1 MeV [$\phi(E > 1 \text{ MeV}$ and 0.1 MeV)] and of displacements per atom (dpa) in iron should be reported consistent with Practices E-693 and E-853E-693 and E853; and,

3.2.1.7 Reaction rates (preferably established relative to neutron fluence standards) must be reported for $^{237}\text{Np}(n,f)$ or $^{238}\text{U}(n,f)$, and $^{58}\text{Ni}(n,p)$ or $^{54}\text{Fe}(n,p)$; additional reactions that aid in spectral characterization, such as provided by Cu, Ti, and Co-A1, should also be included in the benchmark measurements. The $^{237}\text{Np}(n,f)$ reaction is an important reaction since it gives information similar to dpa. Practices E-693 and E-853E-693E-853 and Guides E-844 and E-944E-844E-944 Np(n,f) reaction is particularly important because it is sensitive to the same neutron energy region as the iron dpa. Practices and E853 and Guides E844 and E944 discuss this criterion.

3.2.2 *Methodology Validation*—It is essential that the neutronics methodology employed for predicting neutron fluence in a power-reactor pressure vessel be validated by accurately predicting appropriate benchmark dosimetry results. In addition, the following documentation should be submitted: (1) convergence study results, and (2) ~~estimates of variances and covariances for fluences and reaction rates arising from uncertainties in both the source and geometric modeling.~~

3.2.2.1 ~~For example, model specifications for S_n methods on which convergence studies should be performed include: (1) estimates of variances and covariances for fluence rates and reaction rates arising from uncertainties in both the source and geometric modeling. For Monte Carlo calculations, the convergence study results should also include (3) an analysis of the figure-of-merit (FOM) as a function of particles history, and if applicable, (4) the description of the technique utilized to generate the weight window parameters.~~

3.2.2.1 For example, model specifications for discrete-ordinates method on which convergence studies should be performed include: (1) group structure, (2) neutron cross-sections or energy group structure, (2) spatial mesh, and (3) angular quadrature. One-dimensional calculations may be performed to check the adequacy of group structure and spatial mesh. Two-dimensional

calculations should be employed to check the adequacy of the angular quadrature. A P_3 cross section expansion is recommended along with $\text{an} S_8$ minimum quadrature.

3.2.2.2 Uncertainties that are propagated from known uncertainties in nuclear data are recommended, but they are not required. Appropriate computer programs and covariance data are available, however, and sensitivity data may be obtained as an intermediate step in determining uncertainty estimates.

3.2.2.2 Uncertainties that are propagated from known uncertainties in nuclear data need to be addressed in the analysis. The uncertainty analysis for discrete ordinates codes may be performed with sensitivity analysis as discussed in References (3, 4). In Monte Carlo analysis the uncertainties can be treated by a perturbation analysis as discussed in Reference (5). Appropriate computer programs and covariance data are available and sensitivity data may be obtained as an intermediate step in determining uncertainty estimates.⁴

3.2.2.3 Effects of known uncertainties in geometry and source distribution should be evaluated based on the following test cases: (1) reference calculation with a time-averaged source distribution and with best estimates of the core, thermal shield and pressure vessel locations, (2) reference case geometry with maximum and minimum expected deviations in the source distribution, and (3) reference case source distribution with maximum expected spatial perturbations of the core, thermal shield, pressure vessel, and pressure vessel, other pertinent locations.

3.2.2.4 Measured and calculated integral parameters should be compared for all test cases. It is expected that larger uncertainties are associated with geometry and neutron source specifications than with parameters included in the convergence study. Problems associated with space, energy, and angle discretizations can be identified and corrected. Uncertainties associated with geometry specifications are inherent in the structure tolerances. Calculations based on the expected extremes provide a measure of the sensitivity of integral parameters to the selected variables. Variations in the proposed convergence and uncertainty evaluations are appropriate when the above procedures are inconsistent with the methodology to be validated. As-built data could be used to reduce the uncertainty in geometrical dimensions.

3.2.2.5 In order to illustrate quantitative criteria based on measurements and calculations that should be satisfied, let ψ denote a set of logarithms of calculation (C_i) to measurement (E_i) ratios. Specifically,

$$\psi = \{q_i; q_i = w_i \ln (C_i/E_i), i = 1 \dots N\} \quad (1)$$

E0482-11_1

where q_i and N are defined implicitly and the w_i are weighting factors. Because some reactions provide a greater response over a spectral region of concern than other reactions, weighting factors may be utilized when their selection method is well documented and adequately defended. The mean of the set are weighting factors. Because some reactions provide a greater response over a spectral region of concern than other reactions, weighting factors may be utilized when their selection method is well documented and adequately defended, such as through a least squares adjustment method as detailed in Guide E944. In the absence of the use of a least squares adjustment methodology, the mean of the set q is given by

E0482-11_2

and the best estimate of the variance, S^2 , is

E0482-11_3

3.2.2.6 The neutronics methodology is validated, if (in addition to qualitative model evaluation) all of the following criteria are satisfied:

- (1) The bias, $|\bar{q} - \bar{q}|$, is less than ϵ_1 ,
- (2) The standard deviation, S , is less than ϵ_2 ,
- (3) All absolute values of log- All absolute values of the natural logarithmic of the C/E ratios ($|q|$, $i = 1 \dots N$) are less than ϵ_3 , and
- (4) ϵ_1 , ϵ_2 , and ϵ_3 are defined by the benchmark measurement documentation and demonstrated to be attainable for all items with which calculations are compared.

3.2.2.7 Note that a nonzero log-mean of the C_i/E_i ratios indicates that a bias exists. Possible sources of a bias are: (1) source normalization, (2) neutronics data, (3) transverse leakage corrections, (4) transverse leakage corrections (if applicable), (4) geometric modeling, and (5) mathematical approximations. Reaction rates, equivalent fission fluence rates, or exposure parameter values [for example, $\phi(E > 1 \text{ MeV})$ and dpa] may be used for validating the computational methodology if appropriate criteria (that is, as established by) are documented for the benchmark of interest. Accuracy requirements for benchmark validation procedures are discussed in Footnote 5. $> 1 \text{ MeV})$ and dpa] may be used for validating the computational methodology if appropriate criteria (that is, as established by 3.2.2.5 and 3.2.2.6) are documented for the benchmark of interest. Accuracy requirements for reactor vessel surveillance specific benchmark validation procedures are discussed in Guide E2006. The validation testing for the generic discrete ordinates and Monte Carlo transport methods is discussed in References (1, 2).

3.2.2.8 One acceptable procedure for performing these comparisons is: (1) obtain group fluence rates at dosimeter locations from neutronics calculations, (2) collapse the ENDF Guide E1018 recommended dosimetry cross section data to a multigroup set

⁴ Available from Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

⁴ Much of the nuclear covariance and sensitivity data have been incorporated into a benchmark database employed with the LEPRICON Code system. See Ref (6).