
**Information technology — Data
centres key performance indicators —**

**Part 9:
Water usage effectiveness (WUE)**

*Technologies de l'information — Indicateurs de performance clés des
centres de données —*

Partie 9: Efficacité dans l'utilisation de l'eau (WUE)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO/IEC 30134-9:2022

<https://standards.iteh.ai/catalog/standards/sist/3ab1c7b3-2184-4fea-918f-477af63dc940/iso-iec-30134-9-2022>



iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO/IEC 30134-9:2022

<https://standards.iteh.ai/catalog/standards/sist/3ab1c7b3-2184-4fea-918f-477af63dc940/iso-iec-30134-9-2022>



COPYRIGHT PROTECTED DOCUMENT

© ISO/IEC 2022

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms, definitions, abbreviated terms and symbols	1
3.1 Terms and definitions.....	1
3.2 Abbreviated terms.....	3
3.3 Symbols.....	3
4 Applicable area of the data centre	4
5 Determination of WUE	5
6 Measurement of WUE	5
6.1 General.....	5
6.2 Measuring actual water usage.....	5
6.2.1 Calculation, measurement period and frequency.....	5
6.2.2 Categories of WUE.....	5
7 Application of WUE	8
8 Reporting of WUE	8
8.1 Requirements.....	8
8.1.1 Standard construct for communicating WUE data.....	8
8.1.2 Data for public reporting of WUE.....	9
8.2 Recommendations.....	9
8.3 Example of reporting WUE values.....	10
8.4 WUE derivatives.....	10
8.4.1 Purpose of WUE derivatives.....	10
8.4.2 Interim WUE.....	11
8.4.3 Partial WUE.....	11
8.4.4 Design WUE.....	11
8.4.5 Quality WUE.....	11
8.4.6 Peak WUE.....	12
8.5 Water reuse factor (WRF).....	12
Annex A (informative) Examples of use	13
Annex B (normative) Water significance	15
Annex C (informative) Energy water intensity factor	16
Annex D (normative) Land consumption	17
Bibliography	19

Foreword

ISO (the International Organization for Standardization) and IEC (the International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards through technical committees established by the respective organization to deal with particular fields of technical activity. ISO and IEC technical committees collaborate in fields of mutual interest. Other international organizations, governmental and non-governmental, in liaison with ISO and IEC, also take part in the work.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives or www.iec.ch/members_experts/refdocs).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO and IEC shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents) or the IEC list of patent declarations received (see <https://patents.iec.ch>).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html. In the IEC, see www.iec.ch/understanding-standards.

This document was prepared by Joint Technical Committee ISO/IEC JTC 1, *Information technology*, Subcommittee SC 39, *Sustainability, IT and data centres*.

A list of all parts in the ISO/IEC 30134 series can be found on the ISO and IEC websites.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html and www.iec.ch/national-committees.

Introduction

The global economy is today reliant on information and communication technologies and the associated generation, transmission, dissemination, computation and storage of digital data. All markets have experienced exponential growth in that data, for social, educational and business sectors and while the internet backbone carries the traffic, there are a wide variety of data centres at nodes and hubs within both private enterprise and shared/collocation facilities.

The historical data generation growth rate exceeds the capacity growth rate of information and communications technology hardware. In addition, with many governments having “digital agendas” to provide both citizens and businesses with ever-faster broadband access, the very increase in network speed and capacity will, by itself, generate ever more usage (Jevons Paradox). Data generation and the consequential increase in data processing and storage are directly linked to increasing power consumption.

With this background, data centre growth, and power consumption in particular, is an inevitable consequence; this growth will demand increasing power consumption despite the most stringent energy efficiency strategies. This makes the need for key performance indicators (KPIs) that cover the effective use of resources (including but not limited to energy and water) and the reduction of CO₂ emissions essential.

Within the ISO/IEC 30134 series, the term “resource usage effectiveness” is more generally used for KPIs in preference to “resource usage efficiency”, which is restricted to situations where the input and output parameters used to define the KPI have the same units.

Water usage effectiveness (WUE) is intended to support data centre practitioners in obtaining an in depth understanding of the performance of the data centre’s cooling installation in comparison with similar systems, thereby creating a tool for improving the sustainability of the data centre. The impact of operational water usage is emerging as being extremely important in the design, location and operation of current and future data centres.

In order to determine the overall resource efficiency of a data centre, a holistic suite of metrics is required. This document is one of a series of International Standards for such KPIs and has been produced in accordance with ISO/IEC 30134-1, which defines common requirements for a holistic suite of KPIs for data centre resource efficiency. This document does not specify limits or targets for the KPI and does not describe or imply, unless specifically stated, any form of aggregation of this KPI into a combination with other KPIs for data centre resource efficiency. This document presents specific rules on WUE’s use, along with its theoretical and mathematical development. This document concludes with several examples of site concepts that could employ the WUE metric.

Information technology — Data centres key performance indicators —

Part 9: Water usage effectiveness (WUE)

1 Scope

This document specifies water usage effectiveness (WUE) as a key performance indicator (KPI) for quantifying the water consumption of a data centre during the use phase of the data centre life cycle.

WUE is a simple method for reporting the water intensity of the data centre operating. By reporting water consumption, it is possible to present the data centre's resource effectiveness.

This document:

- a) defines the WUE of a data centre;
- b) introduces WUE measurement categories;
- c) describes the relationship of this KPI to a data centre's infrastructure, information technology equipment and information technology operations;
- d) defines the measurement, the calculation and the reporting of the parameter; and
- e) provides information on the correct interpretation of the WUE.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO/IEC 30134-1, *Information technology — Data centres — Key performance indicators — Part 1: Overview and general requirements*

ISO 8601-1, *Date and time — Representations for information interchange — Part 1: Basic rules*

3 Terms, definitions, abbreviated terms and symbols

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO/IEC 30134-1 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1.1

total data centre energy consumption

total annual energy consumption for all energy types serving the data centre at its boundary

Note 1 to entry: The total data centre energy is measured in MWh; the energy is measured with energy metering devices at the boundary of the data centre or points of generation within the boundary.

Note 2 to entry: This includes electricity, natural gas, hydrogen, bioethanol and district utilities such as supplied chilled water or condenser water.

Note 3 to entry: Total annual energy includes supporting infrastructure.

[SOURCE: ISO/IEC 30134-2:2016, 3.1.7, modified.]

3.1.2

IT equipment energy consumption

energy consumed by equipment that is used to manage, process, store or route data within the compute space

Note 1 to entry: IT equipment energy consumption is measured in MWh; examples for IT equipment are servers, storage equipment, and telecommunications equipment.

Note 2 to entry: IT equipment energy use follows the same categories as in ISO 30134-2 Power usage effectiveness.

[SOURCE: ISO/IEC 30134-2:2016, 3.1.1, modified.]

3.1.3

water usage effectiveness

ratio of the data centre water consumption divided by the energy consumed by IT equipment

3.1.4

water use

water that is used by end-users for a specific purpose within a given territory

Note 1 to entry: For the purposes of this document, water use corresponds to the water consumption caused by the processing of data in a data centre.

Note 2 to entry: Domestic use, irrigation or industrial processing are examples of a given territory.

Note 3 to entry: Water use is measured in water volume (m³) consumed.

3.1.5

reused water

water that is leaving the data centre boundaries for an alternative non-data-centre use

Note 1 to entry: The non-data-centre use of water is usually defined by local regulations for reuse.

3.1.6

potable water

water that is free from contamination and that is safe to drink or to use for food and beverage preparation and personal hygiene

Note 1 to entry: Potable water is also known as drinking water.

Note 2 to entry: The definition of the quality criteria of potable water is usually subject to national or local regulations; if there is no information about the criteria see Reference [2].

3.1.7

energy water intensity factor

amount of water that is used to produce energy

Note 1 to entry: Energy water intensity factor is measured in m³ per MWh.

3.1.8**water significance**

amount of renewable freshwater that is available for each person each year

Note 1 to entry: Within the approach of this document, water significance is categorized by different levels of water stress.

3.1.9**water stress**

ability to meet human and ecological demand for freshwater

3.1.10**water quality**

physical, chemical and biological characteristics of water concerning its suitability for an intended use by humans, ecosystems or industrial processes

3.1.11**land consumption**

loss of water permeability of the soil intended for use by humans, ecosystems or industrial processes

3.2 Abbreviated terms

For the purposes of this document, the abbreviated terms in ISO/IEC 30134-1 and the following apply.

DC	data centre
dWUE	design water usage effectiveness
EWIF	energy water intensity factor
FI	falkenmark indicator
iWUE	interim water usage effectiveness
peakWUE	peak water usage effectiveness
PUE	power usage effectiveness
pWUE	partial water usage effectiveness
qWUE	quality water usage effectiveness
WRF	water reuse factor
WUE	water usage effectiveness

3.3 Symbols

For the purposes of this document the following symbols apply:

E_{DC}	total data centre energy consumption (annual) in MWh
E_{IT}	IT equipment energy consumption (annual) in MWh
f_{EWI}	energy water intensity factor (EWIF)
$f_{r,w}$	water reuse factor (WRF)
$f_{s(F)}$	drainage factor of fully sealed surfaces

$f_{s(f)}$	drainage factor of few sealed surfaces
$f_{s(h)}$	drainage factor of heavily sealed surfaces
I_w	total water input from outside the data centre boundaries (annual) measured by total volume in m ³
$I_{w,e}$	water input from water consumption of energy production
$I_{w,p}$	water input from potable water
$I_{w,rw}$	water input from rainwater
i_F	falkenmark indicator (FI)
L_{DC}	data centre land consumption
O_w	total water returned out of the data centre boundaries (annual) measured by total volume in m ³
p	population
s_F	fully sealed surface
s_f	few sealed surfaces
s_h	heavily sealed surfaces
s_{run}	surface runoff (annual) measured in m ³
U_w	water usage of the data centre (annual) measured by total volume in m ³
$U_{r,w}$	water reuse of the data centre (annual) measured by total volume in m ³
$U_{r,w,I}$	industrial water reuse
$U_{r,w,NI}$	non-industrial water reuse
$\eta_{U,W}$	water usage effectiveness
$\eta_{U,W,i}$	interim water usage effectiveness
NOTE	Unlike for PUE, the unit of the energy used in WUE is MWh.

4 Applicable area of the data centre

WUE as specified in this document:

- is associated with the data centre infrastructure and IT equipment within its boundaries only;
- describes the water usage in relation to facilities with given environmental conditions, IT load characteristics, availability requirements, maintenance and security requirements;
- measures the relationship between the total data centre water usage and the IT equipment energy consumed.

WUE does not:

- account for efficiency of other resources such as human resources, space or CO₂;
- provide a data centre productivity metric;

- provide a standalone, comprehensive efficiency metric;
- account for quality of the water reuse process outside the data centre boundaries;
- account for water down- or upgrade (reducing or improving water quality).

5 Determination of WUE

WUE provides a way to determine the water usage associated with data centres. A value of 0,0 indicates that no water use is associated with the data centre's operations. WUE has no theoretical upper and no theoretical lower boundary.

WUE is defined according to [Formula \(1\)](#):

$$\eta_{U,W} = \frac{U_w}{E_{IT}} \quad (1)$$

Annual water usage is calculated according to [Formula \(2\)](#) as:

$$U_w = I_w - O_w \quad (2)$$

WUE may be applied in mixed-use buildings when measurement of the difference between water used for the data centre and that for other functions is possible.

6 Measurement of WUE

6.1 General

All KPIs of the ISO/IEC 30134 series are defined within the boundaries of a data centre (see ISO/IEC 30134-1).

6.2 Measuring actual water usage

6.2.1 Calculation, measurement period and frequency

The minimum calculation and measurement period requires twelve months of cumulative energy and water values. Annualized data used to calculate WUE shall be documented. The annual energy values for energy consumption of the IT equipment collected shall cover the same time period. It is not necessary to define the frequency of measurement or assessments for the annual WUE determination, as the annual water value is a continuous integration of energy consumed in that timeframe. Examples of the calculation are shown in the [Annex A](#).

NOTE The measurement or assessment frequency can be necessary for subsystem improvements (refer to partial PUE), but is not required for WUE disclosures.

6.2.2 Categories of WUE

6.2.2.1 Introduction

The categories of WUE are defined, as shown in [Table 1](#), to provide a defined route to refine the accuracy of the WUE measured. WUE considers different water qualities and types of reused water. Category 3 requires additional reporting for regional water significance (level of water stress, in accordance with [Annex B](#)) and land consumption (in accordance with [Annex D](#)).