



SLOVENSKI STANDARD
oSIST prEN ISO 19396-2:2024
01-september-2024

Barve in laki - Določanje pH-vrednosti - 2. del: pH-elektrode s tehnologijo ISFET (ISO/DIS 19396-2:2024)

Paints and varnishes - Determination of pH value - Part 2: pH electrodes with ISFET technology (ISO/DIS 19396-2:2024)

Beschichtungsstoffe - Bestimmung des pH-Wertes - Teil 2: pH-Elektroden mit ISFET-Technologie (ISO/DIS 19396-2:2024)

Peintures et vernis - Détermination de la valeur de pH - Partie 2: Électrodes de pH dotées de la technologie ISFET (ISO/DIS 19396-2:2024)

Ta slovenski standard je istoveten z: prEN ISO 19396-2

[oSIST prEN ISO 19396-2:2024](https://standards.sist.net/catalog/standards/sist/8704426-8022-4a24-8000-19396224/ta-19396-2-2024)

<https://standards.sist.net/catalog/standards/sist/8704426-8022-4a24-8000-19396224/ta-19396-2-2024>

ICS:

87.040 Barve in laki Paints and varnishes

oSIST prEN ISO 19396-2:2024 **en,fr,de**



DRAFT International Standard

ISO/DIS 19396-2

Paints and varnishes — Determination of pH value —

Part 2: pH electrodes with ISFET technology

*Peintures et vernis — Détermination de la valeur de pH —
Partie 2: Électrodes de pH dotées de la technologie ISFET*

ICS: 87.040

ISO/TC 35/SC 9

Secretariat: **BSI**

Voting begins on:
2024-07-04

Voting terminates on:
2024-09-26

iteh Standards
(<https://standards.iteh.ai>)
Document Preview

oSIST prEN ISO 19396-2:2024

<https://standards.iteh.ai/catalog/standards/sist/b46f4a2c-3c22-4a24-bd6c-f9032534a4c0/osist-pren-iso-19396-2-2024>

This document is circulated as received from the committee secretariat.

ISO/CEN PARALLEL PROCESSING

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENTS AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

ISO/DIS 19396-2:2024(en)

iTeh Standards (<https://standards.itih.ai>) Document Preview

[oSIST prEN ISO 19396-2:2024](https://standards.itih.ai/catalog/standards/sist/b46f4a2c-3c22-4a24-bd6c-f9032534a4c0/osist-pren-iso-19396-2-2024)

<https://standards.itih.ai/catalog/standards/sist/b46f4a2c-3c22-4a24-bd6c-f9032534a4c0/osist-pren-iso-19396-2-2024>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2024

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

ISO/DIS 19396-2:2024(en)

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Principle	4
5 Apparatus and materials	4
6 Sampling	7
7 Procedure	8
7.1 Test conditions.....	8
7.2 Calibration.....	8
7.3 Number of determinations.....	8
7.4 Measuring the pH value.....	8
8 Evaluation	8
9 Precision	9
9.1 General.....	9
9.2 Repeatability limit, <i>r</i>	9
9.3 Reproducibility limit, <i>R</i>	9
10 Test report	9
Annex A (informative) Determination of precision	10
Bibliography	12

iTech Standards
<https://standards.iteh.ai>
 Document Preview

[oSIST prEN ISO 19396-2:2024](https://standards.iteh.ai/catalog/standards/sist/b46f4a2c-3c22-4a24-bd6c-f9032534a4c0/osist-pren-iso-19396-2-2024)

<https://standards.iteh.ai/catalog/standards/sist/b46f4a2c-3c22-4a24-bd6c-f9032534a4c0/osist-pren-iso-19396-2-2024>

ISO/DIS 19396-2:2024(en)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 35, *Paints and varnishes*, Subcommittee SC 9, *General test methods for paints and varnishes*.

This second edition cancels and replaces the first edition (ISO 19396-1:2017), which has been technically revised.

The main changes are as follows:

- definitions for “theoretical slope” and “stability of measured value” have been deleted;
- “measuring medium” has been harmonized to “measuring solution” in the entire text;
- the calibration (7.2) has been clarified;
- the normative references have been updated.

A list of all parts in the ISO 19396 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

ISO/DIS 19396-2:2024(en)

Introduction

The pH value of aqueous products is of decisive importance for the product properties and durability.

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

[oSIST prEN ISO 19396-2:2024](https://standards.itih.ai/catalog/standards/sist/b46f4a2c-3c22-4a24-bd6c-f9032534a4c0/osist-pren-iso-19396-2-2024)

<https://standards.itih.ai/catalog/standards/sist/b46f4a2c-3c22-4a24-bd6c-f9032534a4c0/osist-pren-iso-19396-2-2024>

Paints and varnishes — Determination of pH value —

Part 2: pH electrodes with ISFET technology

1 Scope

This document specifies a method for measuring the pH value of dispersions and coating materials using pH electrodes with ion-sensitive field-effect transistor (ISFET) technology. ISO 19396-1 specifies a method for measuring the pH value using pH electrodes with a glass membrane.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 1513, *Paints and varnishes — Examination and preparation of test samples*

ISO 4618, *Paints and varnishes — Vocabulary*

ISO 15528, *Paints, varnishes and raw materials for paints and varnishes — Sampling*

ISO 80000-9, *Quantities and units — Part 9: Physical chemistry and molecular physics*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 4618, ISO 80000-9 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at <https://www.iso.org/obp>

— IEC Electropedia: available at <https://www.electropedia.org/>

3.1

pH

measure for the acidic or basic reaction of an aqueous solution or polymer dispersion

Note 1 to entry: Notation of pH: the p and the H are vertically on one line. The same is valid for pOH.

Note 2 to entry: The acidic reaction is determined by the activity of the existing “hydrogen ions”. The basic reaction is determined by the activity of the existing hydroxide ions. The direct relationship between the activities of the “hydrogen ions” and the hydroxide ions is described by the ionic product of the water.

[SOURCE: ISO 19396-1:—, 3.1]

3.2

pH value

ISO/DIS 19396-2:2024(en)

decadal logarithm of the hydrogen ion activity multiplied with (-1)

$$\text{pH} = \text{p}a_{\text{H}^+} = -\lg \left(\frac{a_{\text{H}^+}}{m^0} \right) = -\lg \left(\frac{m_{\text{H}^+} \cdot \gamma_{\text{H}^+}}{m^0} \right)$$

with $a_{\text{H}^+} = m_{\text{H}^+} \cdot \gamma_{\text{H}^+}$

where

- a_{H^+} is the activity of the hydrogen ion, in mol/kg;
- m^0 is the standard molality (1 mol/kg);
- γ_{H^+} is the activity coefficient of the hydrogen ion;
- m_{H^+} is the molality of the hydrogen ion, in mol/kg.

Note 1 to entry: The pH value is not measurable as a measure of a single ion activity. Therefore, pH (PS) values of solutions of primary reference material (PS, en: Primary Standard) are determined, which are approximate to it and can be attributed to it.

[SOURCE: ISO 19396-1:—, 3.2]


3.3

ISFET electrode

combined pH electrode with ISFET technology
potentiometric cell providing a voltage which depends on the *pH value* (3.2) of the measuring solution

Note 1 to entry: One of the two electrochemical cells is the ISFET; the second is a reference electrode.

Note 2 to entry: An integrated temperature sensor is recommended (see [Figure 1](#)).



Key

- | | | | |
|---|---|-----|--|
| 1 | reference electrode, consisting of 2, 3 and 4 | 7 | opening to the measuring solution (gate) |
| 2 | reference element | 8 | temperature sensor |
| 3 | reference electrolyte | U | pH proportional voltage |