

SLOVENSKI STANDARD oSIST prEN ISO 16486-4:2024

01-september-2024

Cevni sistemi iz polimernih materialov za oskrbo s plinastimi gorivi - Cevni sistemi iz nemehčanega poliamida (PA-U) z zvari in mehanskimi spoji - 4. del: Ventili (ISO/DIS 16486-4:2024)

Plastics piping systems for the supply of gaseous fuels - Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing - Part 4: Valves (ISO/DIS 16486-4:2024)

Kunststoff-Rohrleitungssysteme für die Gasversorgung - Rohrleitungssysteme aus weichmacherfreiem Polyamid (PA-U) mit Schweißverbindungen und mechanischen Verbindungen - Teil 4: Armaturen (ISO/DIS 16486-4:2024)

Systèmes de canalisations en matières plastiques pour la distribution de combustibles gazeux - Systèmes de canalisations en polyamide non plastifié (PA-U) avec assemblages par soudage et assemblages mécaniques - Partie 4 : robinets (ISO/DIS 16486-4:2024)

Ta slovenski standard je istoveten z: prEN ISO 16486-4

ICS:

75.200 Oprema za skladiščenje Petroleum products and nafte, naftnih proizvodov in natural gas handling

zemeljskega plina equipment

83.140.30 Polimerne cevi in fitingi za Plastics pipes and fittings for

snovi, ki niso tekočine non fluid use

oSIST prEN ISO 16486-4:2024 en,fr,de

oSIST prEN ISO 16486-4:2024



DRAFTInternational Standard

ISO/DIS 16486-4

Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing —

Part 4: **Valves**

Systèmes de canalisations en matières plastiques pour la distribution de combustibles gazeux — Systèmes de canalisations en polyamide non plastifié (PA-U) avec assemblages par soudage et assemblages mécaniques —

Partie 4: Robinets

ICS: ISO ics

This document is circulated as received from the committee secretariat.

ISO/CEN PARALLEL PROCESSING

ISO/TC 138/SC 7

Secretariat: UNI

Voting begins on: **2024-06-13**

Voting terminates on: 2024-09-05

(https://standards.iteh.ai)

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENTS AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

iTeh Standards (https://standards.iteh.ai) Document Preview

oSIST prEN ISO 16486-4:2024

https://standards.iteh.ai/catalog/standards/sist/e0f84f96-fa2c-4fab-9455-30d6c90/a89b/osist-pren-iso-f6486-4-2024



COPYRIGHT PROTECTED DOCUMENT

© ISO 2024

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office CP 401 • Ch. de Blandonnet 8 CH-1214 Vernier, Geneva Phone: +41 22 749 01 11 Email: copyright@iso.org Website: www.iso.org

Published in Switzerland

Contents			Page
Fore	word		v
Introduction			vi
1	Scop	e	1
2	-	native references	
3			
	3.1	ns and definitions General	
	3.2	Terms relating to design	3
4	Syml	bols and abbreviated terms	3
5	Mate	3	
	5.1	Compound for valve body	
		5.1.1 Compound	
	F 0	5.1.2 Fusion compatibility	
	5.2	Material for non-polyamide parts5.2.1 General	
		5.2.1 General 5.2.2 Metal parts	
		5.2.3 Elastomers	
		5.2.4 Greases and lubricants	
		5.2.5 Assembly	5
6	Gene	eral characteristics	5
Ū	6.1	Appearance of the valve	
	6.2	Colour	
	6.3	Design	
		6.3.1 General	
		6.3.2 Valve body	5 E
		6.3.3 Valve terminal ends 6.3.4 Operating device 6.3.4	5 E
		6.3.5 Seals	
7	Cana		
7	Geon 7.1	netrical characteristics	
	7.1 7.2	Measurement of dimensions ST prEN ISO 16486-4-2024	_
		"= 1	so-1648664-2024
	7.4	Dimensions of valves with electrofusion sockets	6
	7.5	Dimensions of the operating device	6
8	Mechanical characteristics of assembled valves and regional requirements		6
	8.1	General	
	8.2	Conditioning	
	8.3	Requirements	
		8.3.1 Generals	
	8.4	8.3.2 Air flow rate	
9			
	Pnys 9.1	ical characteristics	
	9.1	ConditioningRequirement	
10		ormance requirements	
11		nical File	
12			
	маг 12.1	k ing	
	12.2	Minimum required marking of valves	
	12.3	Additional marking	

13 Delivery Conditions	14
Annex A (normative) Determination of the leaktightness of seat(s) and packing	15
Annex B (normative) Test method for leaktightness and ease of operation after tensile loading	18
Riblingraphy	20

iTeh Standards (https://standards.iteh.ai) Document Preview

oSIST prEN ISO 16486-4:2024

https://standards.iteh.ai/catalog/standards/sist/e0f84196-1a2c-4fab-9455-30d6c907a89b/osist-pren-iso-16486-4-2024

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fittings and valves for the transport of fluids*, Subcommittee SC 7, *Valves and auxiliary equipment of plastics materials,* in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 155, *Plastics piping systems and ducting systems,* in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This third edition cancels and replaces the second edition (ISO 16486-4:2022), which has been technically revised.

http. The main changes are as follows: lards/sist/e0f84196-1a2c-4fab-9455-30d6c907a89b/osist-pren-iso-16486-4-2024

- The revision of this System Standard has been carried to add reference to information related to the suitability of PA-U piping systems for 100 % hydrogen and its admixtures with natural gas;
- Bibliography is extended with additional references.

A list of all parts in the ISO 16486 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document specifies the requirements for valves used in a piping system made from unplasticized polyamide (PA-U) that is intended to be used for the supply of gaseous fuels.

General requirements for unplasticized polyamide (PA-U) materials used for a piping system and its components, intended for the supply of gaseous fuels, are specified in ISO 16486-1.

Requirements and test methods for pipes are specified in ISO 16486-2 and for fittings in ISO 16486-3.

Characteristics for fitness for purpose of the system and generic fusion parameters are specified in ISO 16486-5.

Recommended practice for installation is given in ISO 16486-6, which will not be implemented as a European Standard under the Vienna Agreement.

NOTE Recommended practice for installation is also given in CEN/TS 12007-6^[2],which has been prepared by Technical Committee CEN/TC 234, *Gas infrastructure*.

Assessment of conformity of the system is given in ISO/TS 16486-7.

Training and assessment of fusion operators is covered by ISO/TS 16486-8[11].

NOTE For CEN member countries, the recommended practice for installation is given in CEN/TS 12007- $6^{[2]}$ and the qualification of welders is given by EN 13067 $^{[12]}$.

ISO 16486-1, ISO 16486-2, ISO 16486-3, ISO 16486-5 and ISO 16486-6 as well as ISO/TS 16486-7^[1] and ISO/TS 16486-8^[11] have been prepared by ISO/TC138/SC4. ISO 16486-4 (this document) has been prepared by ISO/TC138/SC 7.

For CEN member countries, all components are to conform to the relevant EN standard(s). Alternative standards may be applied in cases where the suitable EN standard(s) do not exist.

The ISO 16486 series covers a range of maximum operating pressures and gives requirements concerning colours.

It is the responsibility of the purchaser or specifier to make the appropriate selections from these aspects, taking into consideration their particular requirements and any relevant national regulations and installation practices or codes.

Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing —

Part 4:

Valves

1 Scope

This document specifies the characteristics of valves made from unplasticized polyamide (PA-U) in accordance with ISO 16486-1, intended to be buried and used for the supply of gaseous fuels.

NOTE Additional information about the suitability for 100 % hydrogen and its admixtures with natural gas is given by informative Annex C *Continuous liquid hydrocarbon exposure from transported fluid or soil contamination* and by informative Annex D *Permeation of different gases* of ISO 16486-1:2023.

It is applicable to isolating unidirectional and bi-directional valves with spigot ends or electrofusion sockets intended to be fused with PA-U pipes or fittings conforming to ISO 16486-2 and ISO 16486-3 respectively.

Valves made from material other than unplasticized polyamide designed for the supply of gaseous fuels conforming to the relevant standards are permitted to be used in PA-U piping systems according to the ISO 16486 series provided they have relevant PA-U connections for butt fusion or electrofusion ends (see ISO 16486-3). The component, i.e. the complete valve, is required to fulfil the requirements of this document.

This document also specifies the test parameters for the test methods it describes.

In conjunction with ISO 16486-1, ISO 16486-2, ISO 16486-3 and ISO 16486-5, this document is applicable to PA-U valves and their joints and to joints with components of PA-U and other materials intended to be used under the following conditions:

- a) a maximum operating pressure (MOP) of up to and including 18 bar¹⁾, or limited to 16 bar under regional CEN requirements, at a reference temperature of 20 °C for design purposes;
 - NOTE 1 For the purpose of this document and the references to ISO 8233, MOP is considered to be nominal pressure.
- b) an operating temperature of -20 °C to 40 °C;

NOTE 2 For operating temperatures between 20 °C and 40 °C, derating coefficients are specified in ISO 16486-5.

This document covers valves for pipes with a nominal outside diameter, $d_n \le 400$ mm.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 291, Plastics — Standard atmospheres for conditioning and testing

ISO 307, Plastics — Polyamides — Determination of viscosity number

¹⁾ $1 \text{ bar} = 0.1 \text{ MPa} = 10^5 \text{ Pa}; 1 \text{ MPa} = 1 \text{ N/mm}^2.$

ISO 1167-1, Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 1: General method

ISO 1167-4, Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 4: Preparation of assemblies

ISO 3126, Plastics piping systems — Plastics components — Determination of dimensions

ISO 3127, Thermoplastics pipes — Determination of resistance to external blows — Round-the-clock method

ISO 8233, Thermoplastics valves — Torque — Test method

ISO 16010, Elastomeric seals — Material requirements for seals used in pipes and fittings carrying gaseous fuels and hydrocarbon fluids

ISO 16486-1, Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 1: General

ISO 16486-2, Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 2: Pipes

ISO 16486-3:2020, Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 3: Fittings

ISO 16486-5, Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 5: Fitness for purpose of the system

ISO 17778, Plastics piping systems — Fittings, valves and ancillaries — Determination of gaseous flow rate/pressure drop relationships

EN 682, Elastomeric seals - Material requirements for seals used in pipes and fittings carrying gas and hydrocarbon fluids

EN 736-1, Valves Terminology — Part 1: Definition of types of valves

EN 736-2, Valves Terminology — Part 2: Definition of components of valves

EN 1680, Plastics piping systems — Valves for polyethylene (PE) piping systems — Test method for leaktightness under and after bending applied to the operating mechanisms

EN 1704, Plastics piping systems — Thermoplastics valves — Test method for the integrity of a valve after temperature cycling under bending

EN 1705, Plastics piping systems — Thermoplastics valves — Test method for the integrity of a valve after an external blow

EN 12100, Plastics piping systems — Polyethylene (PE) valves — Test method for resistance to bending between supports

EN 12119, Plastics piping systems — Polyethylene (PE) valves — Test method for resistance to thermal cycling

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 16486-1, EN 736-1, EN 736-2 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at https://www.iso.org/obp
- IEC Electropedia: available at https://www.electropedia.org/