



Designation: ~~C1373-03~~ Designation: C1373/C1373M - 11

# Standard Practice for Determination of Thermal Resistance of Attic Insulation Systems Under Simulated Winter Conditions<sup>1</sup>

This standard is issued under the fixed designation C1373/C1373M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

## 1. Scope

1.1 This practice presents a laboratory procedure to determine the thermal resistance of attic insulation systems under simulated steady-state winter conditions. The practice applies only to attic insulation systems that face an open attic air space.

1.2 The thermal resistance of the insulation is inferred from calculations based on measurements on a ceiling system consisting of components consistent with the system being studied. For example, such a system might consist of a gypsum board or plywood ceiling, wood ceiling joists, and attic insulation with its top exposed to an open air space. The temperature applied to the gypsum board or plywood shall be in the range of 18 to 24°C (64[64 to 75°F]; 75°F]. The air temperature above the insulation shall correspond to winter conditions and ~~may range~~ ranges from -46°C to 10°C (-51[-51 to 50°F]; 50°F]. The gypsum board or plywood ceiling shall be sealed to prevent direct airflow between the warm and cold sides of the system.

1.3 This practice applies to a wide variety of loose-fill or blanket thermal insulation products including fibrous glass, rock/slag wool, or cellulosic fiber materials; granular types including vermiculite and perlite; pelletized products; and any other insulation material that ~~may be~~ is installed pneumatically or poured in place. The practice considers the effects on heat transfer of structures, specifically the ceiling joists, substrate, for example, gypsum board, air films, and possible facings, films, or other materials that ~~may be~~ are used in conjunction with the insulation.

1.4 This practice measures the thermal resistance of the attic/ceiling system in which the insulation material has been preconditioned according to the material Specifications C549, C665, C739, and C764.

1.5 The specimen preparation techniques outlined in this standard do not cover the characterization of loose-fill materials intended for enclosed applications.

~~1.6 This practice may be used to characterize material behavior under controlled steady-state laboratory conditions intended to simulate actual temperature conditions of use. The practice does not simulate forced air flow conditions.~~

~~1.7 All values shall be reported in both SI and inch-pound units unless specified otherwise by the client.~~

~~1.6 This practice is be used to characterize material behavior under controlled steady-state laboratory conditions intended to simulate actual temperature conditions of use. The practice does not simulate forced air flow conditions.~~

~~1.7 The values stated in either SI units or inch-pound units are to be regarded separately as standard. The values stated in each system may not be exact equivalents; therefore, each system shall be used independently of the other. Combining values from the two systems may result in non-conformance with the standard.~~

~~1.7.1 All values shall be reported in both SI and inch-pound units unless specified otherwise by the client.~~

1.8 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

## 2. Referenced Documents

### 2.1 ASTM Standards:<sup>2</sup>

C167 Test Methods for Thickness and Density of Blanket or Batt Thermal Insulations

C168 Terminology Relating to Thermal Insulation

C177 Test Method for Steady-State Heat Flux Measurements and Thermal Transmission Properties by Means of the Guarded-Hot-Plate Apparatus

<sup>1</sup> This practice is under the jurisdiction of ASTM Committee C16 on Thermal Insulation and is the direct responsibility of Subcommittee C16.30 on Thermal Measurements.

Current edition approved April 10, 2003. Published May 2003. Originally approved in 1998. Last previous edition approved in 2001 as C1373-01. DOI: 10.1520/C1373-03 on Thermal Measurement.

Current edition approved Nov. 1, 2011. Published December 2011. Originally approved in 1998. Last previous edition approved in 2003 as C1373-03. DOI: 10.1520/C1373\_C1373M-11.

<sup>2</sup> For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For Annual Book of ASTM Standards volume information, refer to the standard's Document Summary page on the ASTM website.

- C518 Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus
- C520 Test Methods for Density of Granular Loose Fill Insulations
- C549 Specification for Perlite Loose Fill Insulation
- C665 Specification for Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing
- C687 Practice for Determination of Thermal Resistance of Loose-Fill Building Insulation
- C739 Specification for Cellulosic Fiber Loose-Fill Thermal Insulation
- C764 Specification for Mineral Fiber Loose-Fill Thermal Insulation
- C1045 Practice for Calculating Thermal Transmission Properties Under Steady-State Conditions
- C1058 Practice for Selecting Temperatures for Evaluating and Reporting Thermal Properties of Thermal Insulation
- C1114 Test Method for Steady-State Thermal Transmission Properties by Means of the Thin-Heater Apparatus
- C1363 Test Method for Thermal Performance of Building Materials and Envelope Assemblies by Means of a Hot Box Apparatus

**3. Terminology**

3.1 *Definitions*— Unless otherwise stated, the definitions listed in Terminology C168 are applicable herein.

**4. Significance and Use**

4.1 The thermal resistance of a ceiling system is used to characterize its steady-state thermal performance.

4.2 The thermal resistance of insulation is related to the density and thickness of the insulation. Test data on thermal resistance are obtained at a thickness and density representative of the end use applications. In addition, the thermal resistance of the insulation system will be different from that of the thermal insulation alone because of the system construction and materials.


4.3 This practice is needed because the in-service thermal resistance of some permeable attic insulations under winter conditions may be different, lower or higher *R*, than that measured at or close to simulated room temperature conditions utilizing small-scale tests in which the insulation is sandwiched between two isothermal impermeable plates that have a temperature difference ( $\Delta T$ ) of 20 to 30°C (36[36 to 54°F]; 54°F). When such insulation is installed in an attic, on top of a ceiling composed of normal building materials such as gypsum board or plywood, with an open top surface exposed to the attic air space, the thermal resistance under winter conditions with heat flow up and large temperature differences may be significantly less because of additional heat transfer by natural convection. Fig. 1 illustrates the difference between results from small scale tests and tests under the conditions of this practice. See Ref (1-12) for discussions of this phenomenon.<sup>3</sup>

4.4 In normal use, the thickness of insulation products may range from 75 mm (3 in.) to 500 mm (20 in.). Installed densities will depend upon the product type, the installed thickness, the installation equipment used, the installation technique, and the geometry of the insulated space.

4.5 The onset of natural convection under winter conditions may be a function of specimen thickness for some materials. For purposes of this practice, the tests shall be carried out at thicknesses at which the product is used.

4.6 Since this practice simulates winter conditions, the heat flow direction shall be vertically upwards.

<sup>3</sup> The boldface numbers in parentheses refer to the list of references at the end of this standard.



NOTE 1—A constant hot-side temperature ( $T_{hot}$ ) is used for both tests and the temperature difference increases as the cold side temperature ( $T_{cold}$ ) is decreased. See 5.1.6 for requirements on size of air space.

**FIG. 1 Schematic of Thermal Resistance for a Permeable Attic Insulation Under Simulated Winter Conditions (Heat Flow Up)**

4.7 Specimens shall be prepared in a manner consistent with the intended installation procedure. Products for pneumatic installation shall be pneumatically-applied (blown), and products for pour-in-place installation shall be poured into place. See 5.2.

**5. Equipment**

5.1 Thermal test apparatus used for this practice shall meet the following requirements:

5.1.1 *Conformance to Standards*—The apparatus shall conform to all requirements of the ASTM thermal test method used, except as required by 5.1.2-5.1.6.

5.1.2 *Size*—The apparatus shall be capable of testing specimens at the thickness intended for product use. Length and width of the metering area shall be at least twice the spacing of the wood joists or four times the specimen thickness, whichever is greater (see Fig. 2).

5.1.3 *Temperature*—The apparatus shall be capable of testing with the hot side surface maintained between 18 and 24°C (64[64 and 75°F], 75°F], and with the cold side air temperature maintained near the winter condition for the particular climate being simulated, which may range ranges from -46 to 10°C (-51[-51 to 50°F], 50°F]. In the absence of specified temperatures, the ambient temperatures listed in Table 2 of C1058 on Temperatures for Thermal Transmittance Evaluations may be used. Temperatures for Thermal Transmittance Evaluations is one source of test temperatures.

NOTE 1—Only those with a hot ambient of 24°C (75°F)[75°F] are applicable.

5.1.4 *Humidity*—The absolute humidity on both sides of the test apparatus shall be maintained low enough to prevent condensation within the specimen. See 6.9.6 of Test Method C1363 for humidity requirements for the hot box methods, 6.6 of Test Method C177 for the guarded hot plate method, and 7.10 of Test Method C518 for the heat flow meter apparatus.

5.1.5 *Orientation and Direction of Heat Flow*—The thermal test specimen shall be oriented horizontally with heat flow up.

5.1.6 *Thermal Test Specimen and Holder*—The test assembly shall be sized to match the test apparatus and shall be made of construction materials representative of the intended application. The substrate on which the insulation rests shall be representative of the intended application, typically gypsum board. The substrate shall be sealed to prevent direct airflow between the warm and cold sides of the system. Wood joists also shall be included. The test assembly shall be constructed such that the top of the insulation is open to an air space having a minimum thickness of 150 mm (6 in.)[6 in.]. Test Methods C1363 is preferred because of its ability to accommodate a large air space. Other apparatuses that can simulate in-service conditions also may be used, must meet the requirements of this practice, (for example, modifications of Test Methods C177, C518, or C1114 with Practice C1045). In all cases, the size requirements given in 5.1.2 shall be met. Fig. 3 shows a schematic of an attic test module that has been used for these types of tests. Other configurations without the roof structure are acceptable as long as the minimum 150 mm (6 in.)[6 in.] air space is maintained.


**5.2 Specimen Preparation Equipment:**

5.2.1 *Blowing Apparatus*—A blowing apparatus is required when pneumatically-applied specimens are to be tested. Choose the combination of hopper, blower, hose size and length that is representative of common use for the application of the material to be tested. The following machine specifications have been developed for use with mineral fiber and cellulosic materials.

5.2.1.1 A commercial blowing machine with a design capacity for delivering the subject material at a rate recommended by the insulation manufacturer shall be used. The machine ~~should~~must utilize 46 m (150 ft)[150 ft] of flexible, internally corrugated blowing hose with an appropriate sized diameter as specified by the machine manufacturer. At least 30 m (100 ft)[100 ft] of the hose ~~should~~must be elevated between 3 and 6 m (10[10 and 20 ft])ft] above the blowing machine to simulate typical installation configuration. The hose ~~should~~must have no more than eight 90° bends and no bends may be less than 1.2 m (4 ft)[4 ft] radius. It is good practice to clean the hose periodically by mechanically agitating it with the blower operating. This practice ~~should~~dislodgedislodges any pieces of old insulation that might be caught in the hose.

**6. Sampling**

6.1 A sample of material shall be selected from a lot according to sampling plans given in the material specifications,



**FIG. 2 Requirements on Dimensions of Test Specimen Metering Area**

## LARGE SCALE CLIMATE SIMULATOR




FIG. 3 Schematic of Attic Test Module and Large Scale Climate Simulator Used for Tests on Attic Insulation Under Simulated Winter Conditions

regulations, or other appropriate documents when applicable. In the absence of such directions, material from at least two randomly chosen packages shall be combined in equal portions (mass) so as to combine materials as uniformly as practicable.

6.2 The insulation material should be is preconditioned to a moisture content in equilibrium with the laboratory conditions prior to the specimen installation. Preconditioning of materials not only ensures controlled installation conditions but may reduce reduces the time required to condition the prepared specimen prior to thermal testing. For conditioning requirements, see the applicable materials Specifications C520, C549, C665, C739, and C764.

### 7. Specimen Preparation

#### 7.1 General Instructions:

7.1.1 All specimens shall be prepared to a thickness and unit area mass that are given for the label *R*-value specification of interest for the material under test.

7.1.2 Specimens shall be prepared in a manner consistent with the intended installation procedure. All materials shall be installed carefully using the manufacturer's recommended installation practice. Batts shall be cut, as required, to fit the available specimen holder. Products for pneumatic installation shall be pneumatically-applied (blown), and products for pour-in-place installation shall be poured into the specimen holder. See 7.2.2 for the density of pneumatically-installed insulation. Other materials should must be installed at the density suggested by the manufacturer.

7.1.3 The specimen holder shall represent typical attic frame construction, wherever possible. This requires, as a minimum, horizontal members representing the bottom chord of a truss system or rafter framing and an air-tight gypsum board or plywood bottom. The specimen holder shall be clean and free of insulation residue prior to installation of the sample insulation.

NOTE 2—For commonly available loose-fill insulation, state and federal energy codes, ASTM material specifications and the Federal Trade Commission have identified those materials that shall apply a correction for settling when determining thermal performance. It is beyond the scope of this practice to outline the procedures for this determination.

NOTE 3—Many factors can influence the characteristics of the loose-fill insulation. These include blowing rate, machine adjustments, the size and length of the hose, and the angle and dimensions of the hose outlet in relation to the specimen holder. Trained operators are required to duplicate field-installed conditioning.