



Designation: F2611 – 11

## Standard Guide for Design and Construction of Chain Link Security Fencing<sup>1</sup>

This standard is issued under the fixed designation F2611; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reappraisal. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reappraisal.

### 1. Scope

1.1 This guide provides the material and installation standards for selection in the design of a security chain link fence system. The proper material selection, system installation and layout can substantially increase the difficulty to penetrate; thereby, increasing the intrusion delay time.

1.2 This guide does not purport to address all of the physical protection security concerns. It is the responsibility of the user of this standard to establish the appropriate design for the level of physical protection required and determine the applicability of regulatory requirements or limitations prior to use.

1.3 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.4 It is recommended that Guide F1553 be followed for the format of this guide.

### 2. Referenced Documents

#### 2.1 *ASTM Standards*:<sup>2</sup>

- A121 Specification for Metallic-Coated Carbon Steel Barbed Wire
- A392 Specification for Zinc-Coated Steel Chain-Link Fence Fabric
- A491 Specification for Aluminum-Coated Steel Chain-Link Fence Fabric
- A817 Specification for Metallic-Coated Steel Wire for Chain-Link Fence Fabric and Marcellled Tension Wire
- A824 Specification for Metallic-Coated Steel Marcellled Tension Wire for Use With Chain Link Fence
- F552 Terminology Relating to Chain Link Fencing
- F567 Practice for Installation of Chain-Link Fence
- F626 Specification for Fence Fittings

<sup>1</sup> This guide is under the jurisdiction of ASTM Committee F14 on Fences and is the direct responsibility of Subcommittee F14.50 on High Security Fences and Perimeter Barriers.

Current edition approved Dec. 1, 2011. Published January 2012. Originally approved in 2006. Last previous edition approved in 2006 as F2611-06. DOI:10.1520/F2611-11.

<sup>2</sup> For referenced ASTM standards, visit the ASTM website, [www.astm.org](http://www.astm.org), or contact ASTM Customer Service at [service@astm.org](mailto:service@astm.org). For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

- F668 Specification for Polyvinyl Chloride (PVC), Polyolefin and Other Polymer-Coated Steel Chain Link Fence Fabric
  - F900 Specification for Industrial and Commercial Steel Swing Gates
  - F934 Specification for Colors for Polymer-Coated Chain Link Fence Materials
  - F1043 Specification for Strength and Protective Coatings on Steel Industrial Fence Framework
  - F1083 Specification for Pipe, Steel, Hot-Dipped Zinc-Coated (Galvanized) Welded, for Fence Structures
  - F1184 Specification for Industrial and Commercial Horizontal Slide Gates
  - F1345 Specification for Zinc-5 % Aluminum-Mischmetal Alloy-Coated Steel Chain-Link Fence Fabric
  - F1553 Guide for Specifying Chain Link Fence
  - F1664 Specification for Poly(Vinyl Chloride) (PVC) and Other Conforming Organic Polymer-Coated Steel Tension Wire Used with Chain-Link Fence
  - F1665 Specification for Poly(Vinyl Chloride) (PVC) and Other Conforming Organic Polymer-Coated Steel Barbed Wire Used With Chain-Link Fence
  - F1712 Specification for Steel Chain-Link Fencing Materials Used for High Security Applications
  - F1910 Specification for Long Barbed Tape Obstacles
  - F1911 Practice for Installation of Barbed Tape
  - F2200 Specification for Automated Vehicular Gate Construction
  - F2656 Test Method for Vehicle Crash Testing of Perimeter Barriers
  - F2781 Practice for Testing Forced Entry, Ballistic and Low Impact Resistance of Security Fence Systems
- 2.2 *Chain Link Fence Manufacturers Institute*:  
WLG 2445 Chain Link Fence Wind Load Guide for the Selection of Line Post and Line Post Spacing<sup>3</sup>  
The Tested and Proven Performance of Security Grade Chain Link Fencing Systems
- 2.3 *U. S. Department of Defense*:  
UFC 4-010-01 United Facilities Criteria, DOD Minimum Antiterrorism Standards for Buildings<sup>4</sup>

<sup>3</sup> Available from Chain Link Fence Manufacturers Institute, 10015 Old Columbia Road, Suite B-215, Columbia, MD 21046, <http://www.chainlinkinfo.org>.

<sup>4</sup> Available electronically from United Facilities Criteria (UFC) Index, [http://65.204.17.188/report/doc\\_ufc.html](http://65.204.17.188/report/doc_ufc.html)

**TABLE 1 Security Chain Link Mesh Configurations**

Security Chain Link Fabric Considerations	Mesh Size and Gauge
Standard Industrial Commercial Chain Link Mesh	2 in. mesh 9 gauge
Bolt cutters required for heavier 6 gauge wire	2 in. mesh 6 gauge
Smaller mesh size increases difficulty to climb and time to cut thru	1 ¾ in. mesh 9 gauge
Bolt cutters required for heavier 6 gauge wire	1 ¾ in. mesh 6 gauge
1 in. mesh increases difficulty to climb and increases time to cut thru	1 in. mesh 11 gauge
9 gauge wire increases cutting time to that of 11 gauge, above	1 in. mesh 9 gauge
Small mesh sizes eliminates finger hold for climbing	¾ in. mesh 11 gauge
Small mesh requires special equipment to cut through	½ in. mesh 11 gauge
Small mesh with larger wire, maximum security	½ in. mesh 9 gauge
Penetration time is increased to cut through small mesh	¾ in. mesh 11 gauge
Metric Equivalents: 2 in. (50 mm), 1¾ in. (44.45 mm), 1 in. (25 mm), ¾ in. (16 mm), ½ in. (13 mm), ¾ in. (10 mm)	
6ga. 0.192 in. (4.88 mm), 9 ga. 0.148 in. (3.76 mm), 11 ga. 0.120 in. (3.05 mm)	

### 3. Terminology

3.1 Definitions, see Terminology **F552**.

### 4. Summary of Practice

4.1 Chain link fence systems can be designed to provide greater levels of security by selecting products and configurations that increase the difficulty to penetrate and in turn increase delay time. Some examples; increase the height of the fence, the configuration of chain link mesh size and wire gauge, securing the bottom of the fence by means of bottom rail, burying the chain link mesh, adding barbed wire to the top or barbed tape to the top, side or bottom of the fence, selecting stronger framework, adding multiple fence lines to create isolation zones, adding slats to the fencing to restrict visibility when required, and adding anti-ram cable systems to resist vehicle penetration into a protected perimeter.

### 5. Part 1—General

5.1 List the scope of work included; the performance requirements of the overall project security design criteria, the performance design criteria for the fence system, referenced contract documents, fence design and detail drawings, material specifications, related site work, site drawings with the specific fence layout, product and data submittals, certifications, site preparation, contractor qualifications, warranties and the fence integration with other security products.

5.1.1 Fence placement can be critical and should be well thought out and defined by the contract specifications and drawings. Placement should be coordinated with the grading plan to ensure it does not inhibit drainage flow by location or debris buildup.

5.1.2 Consideration should be given to the fence location to provide the proper offset to protect a building or provide a clear zone from trees, underbrush, buildings and structures. Qualifying Federal building sites require specified fence set back distances from the building in compliance with the DoD Minimum Antiterrorism Standards for Buildings, UFC 4-040-01.

5.1.3 Consideration should be given during design of the fence to ensure it will properly support the application of added intrusion detection devices. An integrated system using light-

ing with video surveillance requires a specific fence layout, for example, the fence must be located to avoid blocking the view or reduce shadows.

5.1.4 Signage posted along the fence line should always be a consideration.

5.1.5 Review Specification **F1712** for security chain link material recommendations, Practice **F2781** for testing security fence systems, and the Chain Link Fence Manufacturers Institute Tested and Proven Performance of Security Grade Chain Link Fencing Systems.

### 6. Materials and Sizes

#### 6.1 Chain Link Fabric:

6.1.1 There are many chain link mesh design configurations; those to be considered for security fencing, in order of difficulty to penetrate are listed in **Table 1**.

6.1.2 Select the chain link mesh configuration from **Table 1**; choose the type of coating required from one of the following:

6.1.2.1 Zinc-Coated Steel in accordance with Specification **A392**, select Class 1 or Class 2 coating.

6.1.2.2 Aluminum Coated Steel in accordance with Specification **A491**.

6.1.2.3 Zinc-5% Aluminum-Mischmetal Alloy-Coated Steel in accordance with Specification **F1345**, Class 2.

6.1.2.4 Polyvinyl Chloride (PVC) and other Organic Polymer-Coated Steel in accordance with Specification **F668**, Class 2b. Select the color as listed in Specification **F934**.

#### 6.2 Fence Framework:

6.2.1 *Line Posts*—Fences designed to provide increased security levels are generally of greater heights and utilize smaller mesh sizes, both of these factors result in added wind load resistance. Line post selection and the spacing of the posts should be designed to meet the anticipated wind loads based on the site geographical location and weather conditions. Increased post sizes or specific post spacing may be required to compensate for wind loading or increased security. The Chain Link Fence Manufacturers Institute's, Guide for the Selection of Line Posts and their Spacing, WLG 2445, guides the designer through the process to select the post size and post spacing. After calculating the post spacing and post dimensions select the post specification and protective coating from