

~~ISO/TC 86~~

Date: ~~2021-01-04~~2024-05-16

ISO/~~DIS~~FDIS 24664:2024(E)

ISO/TC 86

Secretariat: ANSI

**Refrigerating systems and heat pumps — Pressure relief devices and their associated piping — Methods for calculation**

*Kälteanlagen und Wärmepumpen — Druckentlastungseinrichtungen und zugehörige Leitungen — Berechnungsverfahren*

*Systèmes de réfrigération et pompes à chaleur — Dispositifs de surpression et tuyauteries associées — Méthodes de calcul*

ICS:

Descriptors:

iTeh Standards  
(<https://standards.itih.ai>)  
Document Preview

ISO/FDIS 24664

<https://standards.itih.ai/catalog/standards/iso/ba716ec7-01a0-4502-bf94-feca685c0366/iso-fdis-24664>

Document type:  
Document subtype:  
Document stage: Formal vote

Document language:

ISO/FDIS 24664:2024(E)

© ISO 2024

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO Copyright Office

CP 401 • CH-1214 Vernier, Geneva

Phone: + 41 22 749 01 11

Email: [copyright@iso.org](mailto:copyright@iso.org)

Website: [www.iso.org](http://www.iso.org)

Published in Switzerland.

# iTeh Standards (<https://standards.iteh.ai>) Document Preview

ISO/FDIS 24664

<https://standards.iteh.ai/catalog/standards/iso/ba716ec7-01a0-4502-bf94-feca685c0366/iso-fdis-24664>

Contents

Page

Foreword.....	5
Introduction .....	6
<b>1 Scope.....</b>	<b>8</b>
<b>2 Normative references .....</b>	<b>8</b>
<b>3 Terms and definitions.....</b>	<b>8</b>
<b>4 Symbols.....</b>	<b>10</b>
<b>5 General.....</b>	<b>12</b>
<b>6 Minimum required discharge capacity for protection of parts of a refrigerating system .....</b>	<b>13</b>
<b>6.1 General.....</b>	<b>13</b>
<b>6.2 Excessive pressure caused by heat sources .....</b>	<b>14</b>
<b>6.2.1 External heat sources.....</b>	<b>14</b>
<b>6.2.2 Internal heat sources .....</b>	<b>15</b>
<b>6.3 Excessive pressure caused by compressors .....</b>	<b>15</b>
<b>6.4 Excessive pressure caused by expansion of trapped liquid.....</b>	<b>16</b>
<b>7 Discharge capacity of pressure relief devices .....</b>	<b>16</b>
<b>7.1 General.....</b>	<b>16</b>
<b>7.2 Discharge capacity of pressure relief valves .....</b>	<b>17</b>
<b>7.3 Discharge capacity of bursting discs .....</b>	<b>18</b>
<b>8 Pressure loss in inlet and outlet lines.....</b>	<b>18</b>
<b>8.1 General.....</b>	<b>18</b>
<b>8.2 Pressure loss in inlet line.....</b>	<b>19</b>
<b>8.3 Pressure loss in outlet line .....</b>	<b>20</b>
<b>8.4 Total pressure loss.....</b>	<b>21</b>
<b>8.5 Connection of outlets from several pressure relief valves to a common outlet line.....</b>	<b>21</b>
Annex A (normative) Values of factors and properties of refrigerants .....	232
Annex B (informative) Calculation of flow areas for non-flashing and flashing liquids.....	9
B.1 Calculation of the flow area of a pressure relief valve for non- flashing liquids .....	9
B.2 Calculation of the flow area of a pressure relief valve for flashing liquids.....	12
Annex C (informative) Example calculation for sizing pressure relief devices with corresponding pipes <b>and fittings</b> .....	13
C.1 Refrigerant properties used in the examples.....	13
C.2 Selection of pressure relief valve for single vessel.....	13
C.2.1 General information .....	13
C.2.2 Assumptions for the calculation example .....	14
C.2.3 Calculation of the required minimum discharge capacity at standard heat flow rate.....	14
C.2.4 Calculation of the required minimum discharge capacity at reduced heat flow rate .....	15
C.2.5 Selection of pressure relief valve .....	16
C.2.6 Pressure loss in inlet line (from vessel to pressure relief valve).....	16
C.2.7 Pressure loss in outlet line (from pressure relief valve to atmosphere) .....	17
C.3 Example with two vessels .....	19

Field Code Changed

Field Code Changed

Field Code Changed

Field Code Changed

Field Code Changed

Field Code Changed

Field Code Changed

Field Code Changed

Field Code Changed

Field Code Changed

Field Code Changed

Field Code Changed

Field Code Changed

Field Code Changed

ISO/FDIS 24664:2024(E)

C.3.1	General information .....	19
C.3.2	Common outlet line .....	21
C.3.3	Inlet lines .....	22
C.3.4	Outlet lines .....	222
<b>Annex D (normative) Relief valve outlet line when velocity is higher than speed of sound .....</b>		
D.1	Background information .....	24
D.2	Example with one relief valve .....	26
<b>Annex ZA (informative) Relationship between this International Standard and the essential requirements of Directive 2014/68/EU (Pressure equipment Directive) aimed to be covered.....</b>		
		31
Bibliography.....		333

Field Code Changed

Field Code Changed

Field Code Changed

Field Code Changed

iTeh Standards  
(<https://standards.iteh.ai>)  
Document Preview

ISO/FDIS 24664

<https://standards.iteh.ai/catalog/standards/iso/ba716ec7-01a0-4502-bf94-feca685c0366/iso-fdis-24664>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO ~~documents~~document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

~~Attention is drawn~~ISO draws attention to the possibility that ~~some of the elements~~implementation of this document may ~~be involve~~ the ~~subject~~use of (a) patent(s). ISO takes no position concerning the ~~evidence, validity or applicability~~ of any claimed patent rights ~~in respect thereof~~. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at [www.iso.org/patents](http://www.iso.org/patents). ISO shall not be held responsible for identifying any or all such patent rights. ~~Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).~~

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by the European Committee for Standardization (CEN) Technical Committee CEN/TC 182, *Refrigerating systems, safety and environmental requirements*, in collaboration with ISO Technical Committee ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 1, *Safety and environmental requirements for refrigerating systems*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at [www.iso.org/members.html](http://www.iso.org/members.html).

ISO/FDIS 24664:2024(E)

## Introduction

This document is based on EN 13136:2013+A1:2018, ~~which has been technically revised.~~

# iTeh Standards (<https://standards.itih.ai>) Document Preview

ISO/FDIS 24664

<https://standards.itih.ai/catalog/standards/iso/ba716ec7-01a0-4502-bf94-feca685c0366/iso-fdis-24664>

**and Introduction**

~~This document is based on~~ applicable parts of ISO 4126-1:2013, ISO 4126-2:2018 and ISO 21922:2021. It is suited to the specific requirements, and includes the data, of refrigerating systems. It provides means of satisfying the pressure relief devices requirements of EN 378-2:2016 and ISO 5149-2:2014.

iTeh Standards  
(<https://standards.iteh.ai>)  
Document Preview

ISO/FDIS 24664

<https://standards.iteh.ai/catalog/standards/iso/ba716ec7-01a0-4502-bf94-feca685c0366/iso-fdis-24664>

## Refrigerating systems and heat pumps — Pressure relief devices and their associated piping — Methods for calculation

### 1 Scope

This document describes the calculation of:

- mass flow for sizing pressure relief devices for parts of refrigerating systems;
- discharge capacities for pressure relief valves and other pressure relief devices in refrigerating systems including the necessary data for sizing these when relieving to atmosphere or to part of the refrigerating system at lower pressure;
- the pressure loss in the inlet and outlet lines of pressure relief valves and other pressure relief devices and includes the necessary data

This document specifies the requirements for selection of pressure relief devices to prevent excessive pressure due to internal and external heat sources, the sources of increasing pressure (e.g. compressor, heaters, etc.) and thermal expansion of trapped liquid.

NOTE The term "refrigerating system" used in this document includes heat pumps.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 4126-1:2013+Amd 1:2016, *Safety devices for protection against excessive pressure*— Part-1: *Safety valves*

ISO 4126-2:2018, *Safety devices for protection against excessive pressure*— Part-2: *Bursting disc safety devices*

ISO 21922:2021, *Refrigerating systems and heat pumps*— Valves— *Requirements, testing and marking*

EN-13501-1:2018+A1, *Fire classification of construction products and building elements*— Part-1: *Classification using data from reaction to fire tests*

### 4.3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 21922:2021, ISO 4126-1:2013/Amd 1:2016, and ISO 4126-2:2018 and the following apply.

ISO and IEC maintain ~~terminological~~ terminology databases for use in standardization at the following addresses:

~~Edited DIS~~  
~~MUST BE USED~~  
~~FOR FINAL~~  
~~DRAFT~~



- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

### 3.1

#### refrigerant

fluid used for heat transfer in a refrigerating system, which absorbs heat at a low temperature and a low pressure of the fluid and rejects it at a higher temperature and a higher pressure of the fluid usually involving changes of the phase of the fluid

[SOURCE: ISO 817:2014, 3.1.35]

### 3.2

#### part of the refrigerating system

several components assembled together and exposed to the same pressure in operation or pressure source, respectively, as determined by the manufacturer

### 3.3

#### pressure relief device

pressure relief valve or bursting disc device designed to relieve excessive pressure automatically

### 3.4

#### pressure relief valve

pressure actuated valve held shut by a spring or other means and designed to relieve excessive pressure automatically by starting to open at a set pressure and re-closing after the pressure has fallen below the set pressure

Note 1 to entry: For the purposes of this document, the definition of a safety valve as given in ISO 4126-1:2013 is regarded equivalent to a pressure relief valve.

### 3.5

#### pressure vessel

any refrigerant-containing component of a refrigerating system other than:

- coils (including their headers) consisting of pipes with air as secondary fluid;
- piping and its valves, joints and fittings;
- control devices;
- pressure switches, gauges, liquid indicators;
- safety valves, fusible plugs, bursting discs;
- equipment comprising casings or machinery where the dimensioning, choice of material and manufacturing rules are based primarily on requirements for sufficient strength, rigidity and stability to meet the static and dynamic operational effects or other operational characteristics and for which pressure is not a significant design factor. Such equipment may include: pumps and compressors.

Note 1 to entry: The semi-hermetic and open type compressors used in refrigerating systems may be subject to the exclusion article 1.2.j of the EU Directive 2014/68/EU by referring to the working party group guidelines WPG A-11, A-12 and B-34. The compressor manufacturer has to decide on the basis of a case by case assessment, if the exclusion article 1.2.j of the EU Directive 2014/68/EU is applicable.

~~Edited DIS~~  
**MUST BE USED**  
~~FOR FINAL~~  
**DRAFT**

**ISO/DIS 24664:2021 (E)**

Note 2 to entry: This definition is aligned to EU Directive 2014/68/EU.

**3.6 nominal size**

*DN*  
alphanumeric designation of size for components of a pipework system, which is used for reference purposes comprising the letters *DN* followed by a dimensionless whole number which is indirectly related to the physical size, in millimetres, of the bore or outside diameter of the end connections

Note 1 to entry: The number following the letters *DN* does not represent a measurable value and should not be used for calculation purposes except where specified in this document.

Note 2 to entry: Where the nominal size is not specified, for the purpose of this document it is assumed to be the internal diameter of the pipe or component in mm (*DN/ID*).

Note 3 to entry: Nominal size is not the same as port size which is commonly used for the size of the valve seat opening.

[SOURCE: ISO 6708:1995, 2.1, modified — Note 2 and 3 to entry added.]

**5.4 Symbols**

Symbol	Designation	Unit
$A_{\text{actual}}$	Actual flow area of the pressure relief device. The flow area at the most narrow cross section when the pressure relief device is fully open	mm <sup>2</sup>
$A_{\text{effective}}$	Effective area of the pressure relief device	mm <sup>2</sup>
$A_{\text{liq}}$	Calculated flow area of liquid after expansion	mm <sup>2</sup>
$A_{\text{R}}$	Inside area of tube	mm <sup>2</sup>
$A_{\text{surf}}$	External surface area of the vessel	m <sup>2</sup>
$A_{\text{vap}}$	Calculated flow area of vapour after expansion	mm <sup>2</sup>
<i>DN</i>	Nominal size	-
<i>d</i>	Actual most narrow flow diameter of the pressure relief device	mm
$d_{\text{R}}$	Inside diameter of tube	mm
<i>f</i>	Darcy friction factor	-
$\Delta h_{\text{vap}}$	Heat of vaporisation	kJ/kg
$K_{\text{cap}}$	Capacity correction factor	-
$K_{\text{d}}$	Certified coefficient of discharge considering the backpressure ratio $p_b/p_0$ and the possible reduced stroke of the pressure relief valve	-
$K_{\text{dr}}$	De-rated coefficient of discharge	-
$K_{\text{drl}}$	De-rated coefficient of discharge for liquid	-
$K_{\text{vs}}$	Valve constant (the rate of water flow for a pressure loss of 1 bar at the rated full opening)	m <sup>3</sup> /h
$K_{\text{visc}}$	Viscosity correction factor	-
$K_{\text{volume}}$	Trapped liquid factor	mm <sup>3</sup> /mm <sup>2</sup> ·l
<i>L</i>	Length of pipe	mm

~~Edited DIS -~~  
~~MUST BE USED~~  
~~FOR FINAL~~  
~~DRAFT~~

Symbol	Designation	Unit
$m$	mass	kg
$n$	Rotational frequency	$\text{min}^{-1}$
$p_{\text{atm}}$	Atmospheric pressure (1,01325-013 25 bar)	bar
$p_{\text{b}}$	Back pressure at outlet of pressure relief device, absolute	bar
$p_{\text{c}}$	Critical absolute pressure	bar
$p_{\text{connection}}$	Pressure in connection point	bar
$p_{\text{r,choked}}$	Choked pressure ratio	-
$p_{\text{set}}$	Set pressure, gauge (the pre-determined pressure at which a pressure relief device under operation starts to open)	bar
$\Delta p$	Pressure loss	bar
$\Delta p_{\text{common}}$	Pressure loss in common outlet line	bar
$\Delta p_{\text{in}}$	Pressure loss in the inlet line to the pressure relief device	bar
$\Delta p_{\text{out}}$	Pressure loss in the outlet line from the pressure relief device	bar
$p_0$	Actual absolute relieving pressure	bar
$p_1$	Absolute pressure at the inlet to the outlet line of the pressure relief device	bar
$Q_{\text{h}}$	Rate of heat production, internal heat source	kW
$Q_{\text{m,adjusted}}$	Adjusted discharge capacity, of the pressure relief device. Used for pressure drop calculation in piping	kg/h
$Q_{\text{m,common}}$	Mass flow in common outlet line	kg/h
$Q_{\text{m,liq}}$	Flow of liquid after expansion	kg/h
$Q_{\text{m,relief}}$	Calculated refrigerant mass flow rate of the pressure relief device	kg/h
$Q_{\text{m,required}}$	Minimum required discharge capacity, of refrigerant, of the pressure relief device	kg/h
$Q_{\text{m,vap}}$	Flow of vapour after expansion	kg/h
$q_{\text{m}}$	Theoretical discharge capacity	$\text{kg/h} \cdot \text{mm}^2$
$q'_{\text{m}}$	Actual discharge capacity determined by tests	$\text{kg/h} \cdot \text{mm}^2$
$R$	Bending radius of bend	mm
$Re$	Reynolds number	-
$s$	Thickness of insulation	m
$u$	Velocity in line	m/s
$V$	Theoretical displacement (volume)	$\text{m}^3$
$v$	Specific volume of vapour or liquid	$\text{m}^3/\text{kg}$
$v_0$	Specific volume of vapour in inlet line	$\text{m}^3/\text{kg}$
$v_1$	Specific volume at the inlet to the outlet line of the pressure relief device	$\text{m}^3/\text{kg}$
$w_0$	Actual flow speed of liquid in the smallest section of pressure relief valve	m/s
$w_1$	Speed at the inlet into the outlet line	m/s
$x$	Vapour fraction of refrigerant at $p_{\text{b}}$	-

~~Edited DIS~~  
~~MUST BE USED~~  
~~FOR FINAL~~  
~~DRAFT~~

ISO/DIS 24664:2021 (E)

Symbol	Designation	Unit
$\alpha$	Flush connection angle	°
$\gamma$	Heat capacity ratio	–
$\epsilon_{R,ER}$	Pipe roughness	mm
$\zeta$	Pressure loss coefficient	–
$\zeta_{DN, DN}$	Pressure loss coefficient related to <i>DN</i>	–
$\zeta_{fittings, fitting}$	Pressure loss coefficient of fittings	–
$\zeta_{pipes, pipes}$	Pressure loss coefficient of pipes in outlet line	–
$\zeta_{total, total}$	Total pressure loss coefficient in outlet line	–
$\eta_v$	Volumetric efficiency estimated at suction pressure and discharge pressure equivalent to the pressure relief device setting	–
$\nu$	Kinematic viscosity	m <sup>2</sup> /s
$\rho$	Density of vapour or liquid	kg/m <sup>3</sup>
$\rho_0$	Density of vapour in inlet line	kg/m <sup>3</sup>
$\rho_{10}$	Vapour density at refrigerant saturation pressure/dew point at 10 °C	kg/m <sup>3</sup>
$\phi$	Density of heat flow rate	kW/m <sup>2</sup>
$\phi_{red, \phi_{red}}$	Reduced density of heat flow rate	kW/m <sup>2</sup>

NOTE: 1 bar = 0,1 MPa = 10<sup>5</sup> Pa; 1 MPa = 1 N/mm<sup>2</sup>.

6.5 General

This document describes the calculation of:

— The required discharge capacity of a pressure relief device.

— The actual capacity of a pressure relief device.

— Pressure losses in inlet and outlet lines from the pressure relief device.

The capacity of the pressure relief device (calculated in Clause 7), shall be larger than the required capacity (calculated in Clause 6), and the pressure losses (calculated in Clause 8) shall be within given limits for the pressure relief device to operate correctly.

The Formulae in Clause 7 are only valid for discharge of refrigerant gas or vapour.

NOTE 1 Calculations of flow areas for pressure relief devices for non-flashing and flashing liquids are given in Annex B. Example calculations with corresponding piping are given in Annex C.

NOTE 2 Requirements for protection against excessive pressure in refrigerating systems and heat pumps are given in EN 378-2 and ISO 5149-2.

For design and manufacturing of bodies, bonnets and bolts for pressure relief devices (safety valves and bursting discs) specification of strength pressure test, ISO 21922:2021 applies.

For other aspects, the requirements of ISO 4126-1:2013, and ISO 4126-2:2018, Clause 5, Clause 7, and Clause 10, and ISO 4126-2:2018, Clause 17, apply.

The actual absolute relieving pressure of a pressure relief device is calculated as:

~~Edited DIS~~  
**MUST BE USED**  
**FOR FINAL**  
**DRAFT**

$$p_0 = 1,1 \cdot p_{\text{set}} + p_{\text{atm}} \quad (1)$$

For calculation of the required discharge capacity of a pressure relief device, knowledge of the heat of vaporisation  $\Delta h_{\text{vap}}$  of the refrigerant is required.

For calculation of the actual discharge capacity of a pressure relief device, knowledge of the density  $\rho_0$  (or specific volume  $v_0$ ) and the heat capacity ratio  $\gamma$  of the refrigerant is required.

For calculation of pressure losses in inlet and outlet lines, knowledge of the density  $\rho_0$  (or specific volume  $v_0$ ) is required.

The values are found at the following conditions:

a) If the pressure  $p_0$  is less than the critical pressure of the refrigerant:

— If the saturated gas temperature corresponding to  $p_0$  is higher than the critical temperature minus 5 K, then  $\rho_0$ ,  $v_0$  and  $\Delta h_{\text{vap}}$  are found at saturated gas at critical temperature minus 5 K.

— Else  $\rho_0$ ,  $v_0$  and  $\Delta h_{\text{vap}}$  are found at saturated gas at pressure  $p_0$ . If the inlet temperature is given (superheated gas), then  $\rho_0$ ,  $v_0$  and  $\Delta h_{\text{vap}}$  are found at pressure  $p_0$  and the inlet temperature.

b) If the pressure  $p_0$  is higher than the critical pressure of the refrigerant, then  $\rho_0$ ,  $v_0$  and  $\Delta h_{\text{vap}}$  are found at saturated gas at critical temperature minus 5 K.

The value of the heat capacity ratio  $\gamma$  shall be found at 25 °C and 1,013-25-bar. Values of  $\gamma$  for different refrigerants can be found in Table A.1.

To check if the velocity in the outlet line is larger than the speed of sound, the density and the speed of sound of the refrigerant at the outlet of the outlet line is needed. The refrigerant properties at the outlet of the outlet line is found assuming isenthalpic expansion from the relieving condition ( $p_0$ ,  $v_0$ ) to the pressure at the outlet of the outlet line. If the isenthalpic expansion results in either a mixture of gas and liquid or a mixture of gas and solid, then the density and speed of sound of saturated gas at the pressure at the outlet of the outlet line is used.

## 7.6 Minimum required discharge capacity for protection of parts of a refrigerating system

### 7.6.1 General

Calculations are based on known or assumed processes, which result in an increase in pressure. All foreseeable processes shall be considered. The commonly relevant processes are covered in 6.2, 6.3 and 6.4.

NOTE Information about necessary protection measures against excessive pressure can be found in system safety standards such as ISO 5149-2 and EN 378-2. For instance due to standstill pressure, pressure to internal or external heat sources, or trapped fluid.

In case of supercritical pressure, the pressure relief valve shall be suitable for both gas and liquid.

In case of relieving CO<sub>2</sub> to a pressure below the triple point (e.g. atmospheric pressure), there is a possibility to create solid CO<sub>2</sub>. Necessary precautions shall be taken to ensure safe operation.

Even if a vessel contains only gas, it might in some situations contain liquid and should therefore for the purpose of this standard be treated as a vessel containing both liquid and gas.

**Edited DIS  
MUST BE USED  
FOR FINAL  
DRAFT**

**7.2.6.2 Excessive pressure caused by heat sources**

**7.2.6.2.1 External heat sources**

The minimum required discharge capacity of the pressure relief device for pressure vessels is calculated as in Formula (2):

$$Q_{m,required} = \frac{3600 \cdot \phi \cdot A_{surf}}{\Delta h_{vap}} \quad (2)$$

For pressure vessels in this document, the density of heat flow rate  $\phi$  is assumed to be 10 kW/m<sup>2</sup>·m<sup>2</sup>, but a higher value shall be used if necessary.

When the thickness (s) of the insulation of the pressure vessel is higher than 0,04 m and the insulation is tested for reaction to fire according to EN 13501-1:2018 and classified better than class C, a reduced density of heat flow rate shall be used as a minimum value:

$$\phi_{red} = \phi \cdot \frac{0,04}{s} \quad (3)$$

For pressure vessels the total external surface area of the vessel is calculated depending on geometry.




Figure 1 — Plate heat exchanger (PHE)




Figure 2 — Plate and shell heat exchanger (PSHE)

**Edited DIS**  
**MUST BE USED**  
**FOR FINAL**  
**DRAFT**