

FINAL  
DRAFT

INTERNATIONAL  
STANDARD

ISO/FDIS  
50006

ISO/TC 301

Secretariat: ANSI

Voting begins on:  
2023-02-08

Voting terminates on:  
2023-04-05

---

---

**Energy management systems —  
Evaluating energy performance using  
energy performance indicators and  
energy baselines**

iTeh STANDARD PREVIEW  
(standards.iteh.ai)

ISO/FDIS 50006

<https://standards.iteh.ai/catalog/standards/sist/a20f6ab7-5e8e-4f5e-bc3a-2bdda723d80e/iso-fdis-50006>

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.



Reference number  
ISO/FDIS 50006:2023(E)

© ISO 2023

iTeh STANDARD PREVIEW  
(standards.iteh.ai)

ISO/FDIS 50006

<https://standards.iteh.ai/catalog/standards/sist/a20f6ab7-5e8e-4f5e-bc3a-2bdda723d80e/iso-fdis-50006>



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2023

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
CP 401 • Ch. de Blandonnet 8  
CH-1214 Vernier, Geneva  
Phone: +41 22 749 01 11  
Email: [copyright@iso.org](mailto:copyright@iso.org)  
Website: [www.iso.org](http://www.iso.org)

Published in Switzerland

# Contents

	Page
Foreword.....	v
Introduction.....	vi
<b>1 Scope.....</b>	<b>1</b>
<b>2 Normative references.....</b>	<b>1</b>
<b>3 Terms, definitions and abbreviated terms.....</b>	<b>1</b>
3.1 Terms and definitions.....	1
3.2 Abbreviated terms.....	4
<b>4 Overview of EnPIs, EnBs and energy performance.....</b>	<b>4</b>
<b>5 Obtaining relevant energy performance information.....</b>	<b>5</b>
5.1 Initial-energy-performance-related information.....	5
5.2 Determining users of energy performance indicators.....	5
5.3 Defining the energy performance indicator boundaries.....	6
5.4 Defining and quantifying energy flows.....	7
5.5 Defining and quantifying variables related to energy performance.....	8
5.6 Collecting data.....	9
5.6.1 Data collection.....	9
5.6.2 Data quality.....	9
5.6.3 Measurement.....	10
5.6.4 Data collection frequency.....	10
5.6.5 Identifying and analysing outliers.....	10
<b>6 Determining energy performance indicators.....</b>	<b>11</b>
6.1 General.....	11
6.2 Expressing energy performance indicators.....	11
6.2.1 Statistical model.....	11
6.2.2 Aggregated models.....	13
6.2.3 Engineering model.....	13
<b>7 Establishing energy baselines.....</b>	<b>14</b>
7.1 Concept of EnB.....	14
7.2 Determining baseline period.....	14
<b>8 Normalization.....</b>	<b>15</b>
8.1 Concept of normalization.....	15
8.2 Uncertainty of model.....	15
<b>9 Maintaining energy performance indicators and energy baselines.....</b>	<b>15</b>
9.1 General.....	15
9.2 Static factor changes.....	16
<b>10 Monitoring and reporting of energy performance and demonstrating energy performance improvement.....</b>	<b>17</b>
10.1 General.....	17
10.2 Monitoring and reporting.....	17
10.3 Demonstrating energy performance improvement.....	17
<b>Annex A (informative) EnPI and EnB planning process.....</b>	<b>19</b>
<b>Annex B (informative) Examples of EnPI boundaries.....</b>	<b>21</b>
<b>Annex C (informative) Examples of energy performance indicators.....</b>	<b>22</b>
<b>Annex D (informative) Example of normalization stepwise process.....</b>	<b>26</b>
<b>Annex E (informative) Example of normalization.....</b>	<b>28</b>
<b>Annex F (informative) Example of normalization — Multivariate-analysis.....</b>	<b>32</b>
<b>Annex G (informative) Reporting aggregated information.....</b>	<b>36</b>

iTeh STANDARD PREVIEW  
(standards.iteh.ai)

ISO/FDIS 50006

<https://standards.iteh.ai/catalog/standards/sist/a20f6ab7-5e8e-4f5e-bc3a-2bdda723d80e/iso-fdis-50006>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by Technical Committee ISO/TC 301, *Energy management and energy savings*.

This second edition cancels and replaces the first edition (ISO 50006:2014), which has been technically revised.

The main changes are as follows:

- concepts and technical aspects have been harmonized with the latest edition of ISO 50001:2018;
- definitions in [Clause 3](#) have been updated in accordance with the latest edition of ISO 50001:2018 and considering a new approach for general harmonization under ISO/TC 301;
- upgrades have been made related to the normalization of energy performance indicators (EnPIs) and corresponding energy baselines (EnBs);
- upgrades and new considerations have been made related to the new definition and requirement to demonstrate energy performance improvement.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at [www.iso.org/members.html](http://www.iso.org/members.html).

## Introduction

### 0.1 Background

Energy performance evaluation is a tool which applies to all types of organizations and can be used to evaluate the results of its efforts in energy management. Relevant variables affect the energy consumption and energy efficiency of organizations. To effectively evaluate energy performance under equivalent conditions, the effects of relevant variables should be taken into account by using the process of normalization.

Measuring and monitoring of energy performance and demonstration of energy performance improvement can be challenging because of the complexity of determining energy performance indicators (EnPIs) and corresponding energy baselines (EnBs) appropriate for an organization to better understand the energy consumed within the facilities, equipment, systems or energy-using processes.

Improving energy performance helps organizations to become more competitive by reducing their energy costs. In addition, improving energy performance can help organizations to reduce their energy-related greenhouse gas emissions. Climate change and the need for decarbonization are major global concerns. Reducing greenhouse gas emissions associated with energy consumption is a significant tool in tackling climate change. Methods for monitoring and measuring energy performance to ensure appropriate results are key aspects of this activity.

In those activities or processes in which no energy performance improvement has been planned, benefits can also be obtained by using EnPIs and EnBs to manage operational control, identify maintenance needs or identify significant deviations in energy performance.

Communicating the energy performance of the organization and its processes to appropriate person(s) in the organization is a key element for success. It is also a key to building ongoing commitment and engagement of top management to allocate resources for energy management including the effective establishment of EnPIs and EnBs.

#### ISO/FDIS 50006

The technical information in this document enables an organization to meet the requirements of ISO 50001 including using normalization in measuring, monitoring, analysing and evaluating its energy performance and energy performance improvement. In this way, it can demonstrate continual improvement in energy performance using EnPIs and corresponding EnBs.

### 0.2 Overview of contents

This document provides an organization with practical guidance related to managing energy performance, including its evaluation, control and continual improvement through the establishment, use and maintenance of EnPIs and the corresponding EnBs.

This document gives guidance on the selection of appropriate EnPIs according to the objectives of the organizations which can achieve significant benefits by implementing them.

This document is intended to guide an organization in establishing, using and maintaining EnPIs and EnBs in accordance with the requirements in ISO 50001.

The process described in this document can provide benefits to any organization, including those that do not have an EnMS. Nevertheless, more benefits can be obtained if this process is embedded within an EnMS in accordance with ISO 50001.

# Energy management systems — Evaluating energy performance using energy performance indicators and energy baselines

## 1 Scope

This document gives guidance on how to establish, use and maintain energy performance indicators (EnPIs) and energy baselines (EnBs) to evaluate energy performance in any organization including those using ISO 50001. Additional guidance is given on how to measure and monitor energy performance and demonstrate energy performance improvement.

This document is applicable to any organization, regardless of its type, size, complexity, geographical location, organizational culture, the products and services it provides or its level of maturity in the field of energy management.

## 2 Normative references

There are no normative references in this document.

## 3 Terms, definitions and abbreviated terms

### 3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

#### 3.1.1

##### **baseline period**

period of time used for comparison with *reporting period* (3.1.16)

Note 1 to entry: The purpose of the comparison can be monitoring of performance, evaluation of performance improvement or determination of energy savings.

#### 3.1.2

##### **boundary**

physical, virtual and/or organizational limits as defined by the entity for a stated purpose

Note 1 to entry: The entity may be an *organization* (3.1.14), group of organizations, region(s), subset of an organization or other depending on the application.

Note 2 to entry: Physical can be equipment, systems, a building, a process, a group of processes, a site, or multiple sites, under the control of an organization.

#### 3.1.3

##### **energy**

electricity, fuels, steam, heat, compressed air and other similar media

Note 1 to entry: For the purposes of this document, energy refers to the various types of energy, including renewable, which can be purchased, stored, treated, used in equipment or in a process, or recovered.

[SOURCE: ISO 50001:2018, 3.5.1]

### 3.1.4

#### energy baseline

##### EnB

value providing a basis for comparison of *energy performance* (3.1.9)

Note 1 to entry: The data and method used to determine the EnB shall be retained as documented information.

Note 2 to entry: If the process for determination of the EnB uses *relevant variables* (3.1.15) for *normalization* (3.1.13) or if the EnB is adjusted for changes in *static factors* (3.1.18), the information shall be retained as documented information.

### 3.1.5

#### energy consumption

quantity of *energy* (3.1.3) applied

Note 1 to entry: Energy consumption can be represented in volume (e.g. litres of fuel), mass, weight units or energy units (e.g. GJ, kWh).

[SOURCE: ISO 50001:2018, 3.5.2, modified — Note 1 to entry added.]

### 3.1.6

#### energy efficiency

ratio or other quantitative relationship between an output of process and an input of *energy* (3.1.3)

EXAMPLE Conversion efficiency, energy required/energy used, output/input, theoretical energy used to operate/energy used to operate.

Note 1 to entry: The output of a process can be products, services, or energy.

Note 2 to entry: Both input and output should be clearly specified in terms of quantity and quality, and should be measurable.

### 3.1.7

#### energy use

energy end-use

application of *energy* (3.1.3)

EXAMPLE Ventilation, lighting, heating, cooling, transportation, processes, data storage.

Note 1 to entry: Energy use is based on “what the energy is used for” as compared to *energy consumption* (3.1.5) which is based on “how much energy is used”.

Note 2 to entry: This application can be from any energy type including renewables.

### 3.1.8

#### energy model

mathematical representation based on a data set describing the relationship between *relevant variables* (3.1.15) and *energy consumption* (3.1.5) or *energy efficiency* (3.1.6) over a specified period of time

Note 1 to entry: The specified period of time can represent different perspectives of time such as *baseline period* (3.1.1), *reporting period* (3.1.16), or period that reflects standard conditions.

### 3.1.9

#### energy performance

measurable result(s) related to *energy efficiency* (3.1.6), *energy use* (3.1.7) and *energy consumption* (3.1.5)



**3.1.10**  
**energy performance indicator**  
**EnPI**

measure used to quantify *energy performance* (3.1.9)

Note 1 to entry: If the EnPI is used for the demonstration of *energy performance improvement* (3.1.11) it refers to *energy efficiency* (3.1.6) or *energy consumption* (3.1.5).

Note 2 to entry: The EnPI is defined by the *organization* (3.1.14).

Note 3 to entry: EnPI(s) can be calculated by using an *energy model* (3.1.8).

**3.1.11**  
**energy performance improvement**

improvement in measurable results of *energy efficiency* (3.1.6) or *energy consumption* (3.1.5) related to *energy use* (3.1.7), compared to the *energy baseline* (3.1.4)

**3.1.12**  
**energy target**

quantifiable objective of *energy performance improvement* (3.1.11)

Note 1 to entry: An energy target can be included within an objective.

[SOURCE: ISO 50001:2018, 3.4.15]

**3.1.13**  
**normalization**

process to enable analysis under equivalent or standard conditions

Note 1 to entry: Normalization can be used for the purpose of comparison of *energy performance* (3.1.9) or *energy performance improvement* (3.1.11), which accounts for the changes in *relevant variables* (3.1.15).

**3.1.14**

**organization**

person or group of people that has its own functions with responsibilities, authorities and relationships to achieve its objectives

Note 1 to entry: The concept of organization includes, but is not limited to, sole-trader, company, corporation, firm, enterprise, authority, partnership, charity or institution, or part or combination thereof, whether incorporated or not, public or private.

**3.1.15**  
**relevant variable**

quantifiable factor that significantly impacts *energy performance* (3.1.9) and routinely changes

Note 1 to entry: Significance criteria are determined by the *organization* (3.1.14).

Note 2 to entry: In a statistical approach, relevant variables are identified from independent variables by using significance criteria.

EXAMPLE Weather conditions, operating conditions (indoor temperature, light level), working hours, production output.

**3.1.16**  
**reporting period**

defined period of time selected for evaluating *energy performance* (3.1.9) and *energy performance improvement* (3.1.11)

Note 1 to entry: In this document, the concept of reporting period includes the concept of monitoring period.

**3.1.17**  
**significant energy use**  
**SEU**

energy use (3.1.7) accounting for substantial energy consumption (3.1.5) and/or offering considerable potential for energy performance improvement (3.1.11)

Note 1 to entry: Significance criteria are determined by the organization (3.1.14).

Note 2 to entry: SEUs can be related to facilities, systems, processes or equipment.

[SOURCE: ISO 50001:2018, 3.5.6]

**3.1.18**  
**static factor**

identified factor that significantly impacts energy performance (3.1.9) and does not routinely change

Note 1 to entry: Significance criteria are determined by the organization.

EXAMPLE Facility size, design of installed equipment, number of weekly shifts, range of products.

[SOURCE: ISO 50001:2018, 3.4.8]

**3.2 Abbreviated terms**

EnB energy baseline

EnMS energy management system

EnPI energy performance indicator

SEC specific energy consumption

SEU significant energy use

**4 Overview of EnPIs, EnBs and energy performance**

An organization establishes EnPIs and EnBs to measure and monitor energy performance and demonstrate energy performance improvement.

EnPIs provide relevant energy performance information to interested parties (e.g. internal users, supply chain), to understand energy performance and take actions to control and improve energy performance.

EnPI values quantify the energy performance of the whole organization or its various parts (e.g. facilities, equipment, systems or energy using processes). Potential EnPIs need to be analysed to decide if they are appropriate before being selected. EnPIs can be expressed using an energy model and can be reported in units of energy consumption (e.g. GJ, kWh) or energy efficiency (e.g. km/l).


Energy consumption of an organization can be significantly affected by relevant variables such as weather, production, etc. If the organization has data which indicates that relevant variables significantly affect energy performance, normalization should be carried out to enable comparison of energy performance. Normalization is used to account for the changes in the relevant variables to monitor and evaluate energy performance, and evaluate and demonstrate energy performance improvement.

Energy targets are set by the organization and may be based on identified and planned energy performance improvement opportunities.

Figure 1 illustrates an example of the relationship between energy performance improvement, EnPIs, EnBs, EnPI values and energy targets. Figure 1 also illustrates how energy performance improvement

is achieved when an EnPI value improves compared with the EnB, whether or not energy targets are met.

The process to develop, use and update EnPIs and EnBs is described in detail in [Clauses 5 to 10](#). This process helps the organization to monitor and evaluate energy performance and demonstrate energy performance improvement. The processes within the EnPI and EnB planning are presented in [Annex A](#).



#### Key

X time [standards.iteh.ai/catalog/standards/sist/a20f6ab7-5e8e-4f5e-bc3a-2bdda723d80e/iso-fdis-50006](https://standards.iteh.ai/catalog/standards/sist/a20f6ab7-5e8e-4f5e-bc3a-2bdda723d80e/iso-fdis-50006)  
 Y energy consumption

NOTE The trend of changing energy consumption indicates that there is (are) relevant variable(s) and normalization is required.

**Figure 1 — Example of conceptual relationship between energy performance, EnPIs, EnBs, EnPI values and energy targets**

## 5 Obtaining relevant energy performance information

### 5.1 Initial-energy-performance-related information

Organizations should identify current types of energy uses and evaluate current and past energy consumption and energy efficiency based on measurement and other data. Significant energy uses (SEUs) are identified by analysing this information together with factors that affect energy performance.

This process helps to identify the SEUs and prioritize opportunities for energy performance improvement.

NOTE This process is defined in ISO 50001:2018, 6.3 as “energy review”.

### 5.2 Determining users of energy performance indicators

EnPIs should be developed to meet the needs and expectations of different users and should be easily understandable.

Multiple EnPIs can be required to meet user needs. Aligning the EnPI boundaries with functional roles can ensure that the EnPIs meet user needs and that responsibility for managing the EnPI can be effectively assigned.

EnPIs can be developed for internal or external users. Internal users can use EnPIs for a wide variety of purposes such as, but not limited to, maintenance, operation and energy performance evaluation. External users typically use EnPIs to meet information requirements derived from legal requirements and other requirements (e.g. sustainability reports).

NOTE EnPIs and EnBs required for external purposes, such as those for government reporting, are not always sufficient for managing energy performance improvement under ISO 50001 or for organizations wishing to understand their actual energy performance improvement.

Table 1 describes some common EnPI users.

**Table 1 — EnPI users**

Types of EnPI users	Typical needs
Top management	Top management need information from EnPIs to understand the energy performance of the organization and to support energy performance improvement actions.
Energy management team	Group who supports the organization, including top management in: a) setting up an EnPI, b) maintaining an EnPI, c) monitoring EnBs, current EnPI values, values of all relevant variables in predetermined intervals, d) setting energy targets and calculating extent of achievement of energy target, e) conducting normalization and comparison of current EnPI values with EnBs and energy target, f) reporting of EnPI values and deviations, and g) interpreting the results.
Plant or facility management	Typically controls resources within the plant or facility and is responsible for results. The plant or facility manager should understand both planned energy performance and investigate and respond to significant deviations of energy performance and in financial terms. Plant or facility managers may use all of the EnPIs in their plant or facility including the EnPI regarding its SEU, and comparable EnPIs from other sites for benchmarking purposes.
Operation and maintenance personnel	Responsible for using EnPIs to control and ensure efficient operation by taking actions for significant deviations in energy performance, eliminating energy waste and undertaking preventive maintenance. Operation and maintenance personnel may use the EnPIs relevant to the process or equipment for which they have responsibility.
Engineers	Plan, execute and evaluate an energy performance improvement action using suitable EnPIs for the action including the method(s) used to evaluate energy performance improvement.
External users	External users such as regulatory bodies, professional and sector associations, EnMS auditors, customers or other organizations can need information from EnPIs to feed into their relevant processes.
EnPI owner	Person who is responsible for monitoring, analysing and reporting an EnPI and its values.

### 5.3 Defining the energy performance indicator boundaries

To measure energy performance, suitable measurement boundaries for each EnPI should be specified. When specifying an EnPI boundary the organization should consider the user needs (see 5.2) and also:

- organizational responsibilities in relation to energy management, including the level of control and/or influence which the organization has over its energy performance;
- the SEUs;
- facilities, equipment, system or energy-using processes that the organization wishes to isolate and manage;

- the ease of isolating the EnPI boundary by measuring energy consumption and relevant variables;
- the EnMS boundary;
- available data for energy consumption and relevant variables.

The three primary EnPI boundary levels are individual, system and organizational as described in [Table 2](#).

Additional information on EnPI boundaries can be found in [Annex B](#).

**Table 2 — The three EnPI boundary levels**

EnPI boundary levels	Description and examples
Individual (facility/equipment/energy-using process)	The EnPI boundary can be defined around the physical perimeter of a facility, equipment or energy-using process which the organization wishes to isolate and manage.  EXAMPLE 1 The energy use of steam production equipment separate from other energy uses.
System	The EnPI boundary can be defined around the physical perimeter of a group of facilities/equipment/energy-using processes interacting with each other that the organization wants to control and improve.  EXAMPLE 2 The steam production and the steam using equipment, such as a dryer.
Organizational	The EnPI boundary can be defined around the organization also taking into account the responsibility in energy management of individuals, teams, groups or business units as designated by the organization.  EXAMPLE 3 Steam purchased for a factory(ies), or a department of the organization.

#### 5.4 Defining and quantifying energy flows

The organization should identify energy flows across the boundary. The organization can use a diagram (e.g. see [Figure 2](#)) to determine the energy information required to establish EnPIs. The diagram shows energy flows within and across the EnPI boundaries. They can also include additional information, such as metering points and product flow which are important for energy analysis and establishment of EnPIs.

The organization should measure energy flows across each EnPI boundary. This includes delivered and on-site generated energy. Consideration should be given to energy which crosses the EnPI boundary and is stored.