



**SLOVENSKI STANDARD**  
**SIST EN 12155:2001**  
**01-september-2001**

---

CVYyYbY'ZJgUXY!'BYdfYdi gHbcghnUj cXc!'@UvcfUrcf]tg\_]dfYg\_i g'df]gHh] bYa  
hU\_i

Curtain walling - Watertightness - Laboratory test under static pressure

Vorhangfassaden - Schlagregendichtheit - Laborprüfung unter Aufbringung von  
statischem Druck

Façades rideaux - Détermination de l'étanchéité à l'eau - Essai de laboratoire sous  
pression statique

**iTeh STANDARD PREVIEW**  
(standards.itteh.ai)

[SIST EN 12155:2001](https://standards.itteh.ai/catalog/standards/sist/d9387c57-9c22-4c94-95c7-c9c5daz7ddae/sist-en-12155-2001)

Ta slovenski standard je istoveten z: **EN 12155:2000**

---

**ICS:**

91.060.10	Stene. Predelne stene. Fasade	Walls. Partitions. Facades
-----------	----------------------------------	----------------------------

**SIST EN 12155:2001**

**en**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 12155:2001

<https://standards.iteh.ai/catalog/standards/sist/d9387c57-9c22-4c94-95c7-c9c3da27ddae/sist-en-12155-2001>

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

EN 12155

June 2000

ICS 91.060.10

English version

## Curtain walling - Watertightness - Laboratory test under static pressure

Façades rideaux - Détermination de l'étanchéité à l'eau -  
Essai de laboratoire sous pression statique

Vorhangfassaden - Schlagregendichtheit - Laborprüfung  
unter Aufbringung von statischem Druck

This European Standard was approved by CEN on 6 October 1999.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

[SIST EN 12155:2001](https://standards.iteh.ai/catalog/standards/sist/d9387c57-9c22-4c94-95c7-c9c3da27ddae/sist-en-12155-2001)

<https://standards.iteh.ai/catalog/standards/sist/d9387c57-9c22-4c94-95c7-c9c3da27ddae/sist-en-12155-2001>



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

Central Secretariat: rue de Stassart, 36 B-1050 Brussels

**Contents**

Foreword .....	3
1 Scope .....	4
2 Normative references .....	4
3 Definitions.....	4
4 Principle.....	5
5 Apparatus .....	5
6 Test specimen .....	6
7 Test preparation .....	6
8 Test procedure .....	6
9 Results.....	7
10 Test Report.....	7
Bibliography .....	12

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 12155:2001

<https://standards.iteh.ai/catalog/standards/sist/d9387c57-9c22-4c94-95c7-c9c3da27ddae/sist-en-12155-2001>

## Foreword

This European Standard has been prepared by Technical Committee CEN/TC 33 "Doors, windows, shutters, building hardware and curtain walling", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2000, and conflicting national standards shall be withdrawn at the latest by December 2000.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

This European Standard is part of a series of European standards dedicated to curtain walling products.

This European Standard forms part of a series of curtain walling performance requirements as defined in the product standard prEN 13830:2000.

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 12155:2001

<https://standards.iteh.ai/catalog/standards/sist/d9387c57-9c22-4c94-95c7-c9c3da27ddae/sist-en-12155-2001>

## 1 Scope

This standard defines the method for determining the watertightness of curtain walling, both its fixed and openable parts.

It describes how the outside face of the specimen should be subjected to a continuous film of water with a positive static air pressure.

NOTE This standard applies to curtain walling in accordance with prEN 13830: 2000.

## 2 Normative references

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate points in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these listed publications apply to this European Standard only when incorporated into it by amendment or revision. For undated references the latest edition of the publication referred to applies.

EN 12154:1999 Curtain walling - Watertightness - Performance requirements and classification

prEN 13119:1997 Curtain walling - Terminology.

## 3 Definitions

For the purposes of this standard, the definitions given in prEN 13119:1997, together with the following, apply:

### 3.1

#### **test pressure**

differential pressure between the two faces of the test specimen, expressed in Pascals (Pa).

### 3.2

#### **positive pressure**

when the outer face is subjected to higher pressure than inner face.

### 3.3

#### **watertightness**

ability of the curtain walling to resist water leakage.

### 3.4

#### **water leakage**

penetration of water that would continuously or repeatedly wet parts of:

- the inside face of the test specimen.
- any parts of the specimen intended to remain dry, not being part of the water drainage system to the outside.

### 3.5

#### limit of watertightness

maximum test pressure for which the specimen remains watertight for the specified time (see Table 1, EN 12154:1999).

## 4 Principle

Application of a constant and specified quantity of water in a continuous film over the outside surface of the specimen with increments of positive static test pressures applied at set time intervals. The test operator shall note when and where any water leakage has occurred.

## 5 Apparatus

5.1 A chamber with an opening into which the test specimen can be fitted. This chamber shall be of sufficient strength and rigidity to withstand the test pressures likely to be imposed during the tests. It shall not deflect under test pressure to any extent which would affect the performance of the test specimen (figure 1).

Adequately representative structural supports shall be provided to which the specimen shall be attached in accordance with the conditions of use in the works (see also clause 6).

The chamber shall be constructed so that the air permeability through it, at pressures up to the maximum test pressure, does not exceed the permissible air permeability through the specimen at the same pressure.

5.2 A means for applying controlled positive test pressures to the test specimen.

5.3 A means by which rapidly controlled changes of positive test pressures may be produced within defined limits.

5.4 A means of measuring the positive test pressure, steady or fluctuating, calibrated within an accuracy of  $\pm 5\%$ .

5.5 An adjustable device for spraying water at  $2\text{ l/m}^2\cdot\text{min}$  so that a constant and continuous film is applied to the outside surface of the specimen.

The water spraying device shall have nozzles spaced on a regular grid and at a uniform distance from the outside surface of the specimen (figure 2 and figure 3).

The local mains water supply will be an acceptable source providing it is clean enough to allow the spray nozzles to function properly throughout the test.

The nozzles shall include the following features:

- circular full cone spray;
- spray angle minimum  $90^\circ$  to maximum  $120^\circ$ ;
- working pressure range 2 to 3 bars according to the manufacturer's specification.

5.6 A means of measuring the total amount of water supplied within an accuracy of 10%.

5.7 A drain for the sprayed water which will not interfere with the drainage of the specimen frame.

## 6 Test specimen

The specimen shall be submitted in a fully operable condition, ready for use. It shall be supplied in a suitable manner for fixing onto a test chamber. The test specimen shall not be less than two typical units wide and shall be sufficient to provide full loading on at least one typical vertical joint or framing member or both. The specimen shall not obtain additional stiffness from the test chamber. The height shall not be less than the full distance between the curtain wall's point of connection to the building structure.

For custom designed curtain walls or special elements, the specimen shall be a size which is adequate to demonstrate its compliance with the specified requirements.

All parts of the specimen shall be full size, using the same materials, details, methods of construction and fixing as intended for use in the works. Conditions for connection to the structural support shall simulate those in the works as accurately as possible (see also 5.1).

This standard does not apply to the perimeter joints between the curtain walling and the test chamber, or to the joints between the curtain walling and the building construction.

**iTeh STANDARD PREVIEW**

## 7 Test preparation (standards.iteh.ai)

As this test follows that for air permeability then no further preparatory actions are required.

<https://standards.iteh.ai/catalog/standards/sist/d9387c57-9c22-4c94-95c7->

NOTE The sequence of tests as specified in prEN 13830:2000 should be followed.

## 8 Test procedure

Select the maximum test pressure ( $P_{\max}$ ) for classification according to EN 12154: 1999.

Apply 3 pulses of positive pressure equal to 500 Pa or 10% greater than the maximum test pressure ( $p_{\max}$ ) whichever is greater. The maximum pressure for each pulse should be reached in not less than 1 s and it should be maintained for not less than 3 s.

Operate the water sprays with 0 Pa test pressure and adjust the total flow to provide 2 l/m<sup>2</sup>.m calculated from the area of the specimen under test.

After 15 minutes of spraying apply test pressure in the appropriate sequence specified in EN 12154:1999, Table 1, up to the selected maximum test pressure ( $P_{\max}$ ).

Constantly inspect the inside surfaces of the specimen for water leakage throughout the spraying period and record the test pressure, time and location of any leaks that are observed (figure 4).



## 9 Results

If water leakage is observed before the required maximum test pressure ( $P_{max}$ ) has been applied for the specified time, record the test pressure and time for which it has been applied, when the leak is first observed.

Location of leaks (with identifying numbers, if there are more than one) shall be marked on an elevational scaled drawing of the specimen.

## 10 Test Report

Prepare a report to positively identify the specimen/s and record all parameters checked.

The report shall include the following details:

- Reference to this standard.
- Name of the testing institute.
- Persons or persons requesting the test.
- Details of test specimen/s as follows:
  - Type/s of construction;
  - Profile references ;
  - Origin of materials: SIST EN 12155:2001  
<https://standards.iteh.ai/catalog/standards/sist/d9387c57-9c22-4c94-95c7-c9c3da27ddae/sist-en-12155-2001>
  - Type/s of materials;
  - Date/s of manufacture, (if known).
- Dimensioned drawings of specimen/s;
- The results of the test;
- Product designation from manufacturer's literature;
- Observations as to the condition of the specimen/s;
- Date of test;
- Date of calibration of test chamber and equipment;
- Date of report;
- Signature of person preparing the report.