



SLOVENSKI STANDARD
SIST EN 419-1:1999/A1:2002
01-april-2002

**Stropna plinska sevala z zgorevanjem na površini za nestanovanjske prostore – 1.
del: Varnost - Dopolnilo A1**

Non-domestic gas-fired overhead luminous radiant heaters - Part 1: Safety

Gasgeräte-Heizstrahler - Hellstrahler mit Brenner ohne Gebläse für gewerbliche und industrielle Anwendung - Teil 1: Sicherheit

Appareils surélevés de chauffage à rayonnement lumineux au gaz à usage non-domestique - Partie 1: Sécurité
(standards.iteh.ai)

Ta slovenski standard je istoveten z: EN 419-1:1999/A1:2000
SIST EN 419-1:1999/A1:2002
https://standards.iteh.ai/catalog/standards/sist/701c0911-7c1c-4c3c-bdf-d13d8b2847f2/sist-en-419-1-1999-a1-2002

ICS:

97.100.20

SIST EN 419-1:1999/A1:2002

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 419-1:1999/A1:2002

<https://standards.iteh.ai/catalog/standards/sist/7b1e0911-7efe-4e3e-b9f-d13d8b2847f2/sist-en-419-1-1999-a1-2002>

ICS 97.100.20

English version

Non-domestic gas-fired overhead luminous radiant heaters - Part 1: Safety

Appareils surélevés de chauffage à rayonnement lumineux
au gaz à usage non-domestique - Partie 1: Sécurité

Gasgeräte-Heizstrahler - Hellstrahler mit Brenner ohne
Gebläse für gewerbliche und industrielle Anwendung - Teil
1: Sicherheit

This amendment A1 modifies the European Standard EN 419-1:1999; it was approved by CEN on 28 April 2000.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for inclusion of this amendment into the relevant national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

iTeh STANDARD PREVIEW
(standards.itech.ai)

[SIST EN 419-1:1999/A1:2002](https://standards.itech.ai/catalog/standards/sist/711e0911-7efe-4e3e-bf9f-d13d8b2847f2/sist-en-419-1-1999-a1-2002)

<https://standards.itech.ai/catalog/standards/sist/711e0911-7efe-4e3e-bf9f-d13d8b2847f2/sist-en-419-1-1999-a1-2002>



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Foreword

This Amendment EN 419-1:1999/A1:2000 to EN 419-1:1999 has been prepared by Technical Committee CEN/TC 180 "Non-domestic gas-fired overhead radiant heaters", the secretariat of which is held by BSI.

This Amendment to the European Standard EN 419-1:1999 shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2001, and conflicting national standards shall be withdrawn at the latest by April 2001.

This Amendment to the European Standard EN 419-1:1999 has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 419-1:1999/A1:2002

<https://standards.iteh.ai/catalog/standards/sist/7b1e0911-7efe-4e3e-bf9f-d13d8b2847f2/sist-en-419-1-1999-a1-2002>

Contents list

In the list, delete 'Annex F (informative) Bibliography' and insert the following:

'Annex F (informative) Example of calculation of the weighting factors for an appliance with several rates

Annex G (informative) Calculation of conversions of NO_x'

In the list, after 'Annex ZA (informative) Clauses of this European Standard addressing essential requirements or other provisions of EU Directives' insert the following:

'Bibliography'

2 Normative references

Add the following reference:

'CR 1404: 1994 Determination of emissions from appliances burning gaseous fuels during type-testing'

6 Operating Requirements

Add 6.9 as follows:

'6.9 Measurement of oxides of Nitrogen, NO_x

The manufacturer shall declare the NO_x class in Table 9 that is applicable to the appliance.

When measured in accordance with the method of test given in 7.3.1, the NO_x concentration(s) in the dry, air free products of combustion shall be such that the weighted NO_x value, determined as appropriate in accordance with 7.3.2, does not exceed the maximum NO_x class declared by the manufacturer.'

iTeh STANDARD PREVIEW
Table 9 - NO_x classes
(standards.iteh.ai)

NO _x Classes	Maximum NO _x concentration mg/kWh
1	260
2	200
3	150
4	100

7 Test Methods

Add 7.3 as follows:

7.3 Other pollutants

7.3.1 General

The appliance is installed as specified in 7.1.6 and connected to a flue as described in 7.1.6.2.

For appliances intended to use second family gases, the tests are carried out using test gas G 20, if the appliance category is such that this test gas is used as a reference gas. If G 20 is not used as a reference gas, the tests are carried out using G 25 exclusively.

For appliances intended to use all gases of the third family, the tests are carried out with reference gas G 30 and the maximum NO_x concentration (see Table 9) is multiplied by a factor of 1,30.

For appliances intended to use propane only, the tests are carried out with reference gas G 31 and the maximum NO_x concentration is multiplied by a factor of 1,20.

The appliance is adjusted to its nominal heat input.

The NO_x measurements are carried out when the appliance is at thermal equilibrium, conforming to details given in CR 1404:1994.

No wet meters are used.

The reference conditions for the combustion air are:

- temperature: 20 °C;
- relative humidity H_0 : 10 g(H₂O)/kg(air).

If the test conditions are different to these reference conditions, it is necessary to correct the NO_x values as specified below.

$$NO_{x,reference} = NO_{x,m} + \frac{0,02 NO_{x,m} - 0,34}{1 - 0,02 (h_m - 10)} (h_m - 10) + 0,85 (20 - T_m)$$

where:

$NO_{x,reference}$ is the value of NO_x corrected to the reference conditions expressed in milligram per kilowatthour (mg/kWh);

$NO_{x,m}$ is the NO_x measured at h_m and T_m expressed in milligram per kilowatthour (mg/kWh) in the range 50 mg/kWh to 300 mg/kWh;

NOTE. Where NO_x is measured in ppm, convert it to mg/kWh in accordance with Annex G.

h_m is the humidity during the measurement of $NO_{x,m}$ expressed in gram per kilogram (g/kg) in the range 5 g/kg to 15 g/kg;

T_m is the ambient temperature during the measurement of $NO_{x,m}$ expressed in degrees Celsius ($^{\circ}C$) in the range $15^{\circ}C$ to $25^{\circ}C$.

The measured NO_x values are weighted in accordance with 7.3.2.

It is checked that the weighted NO_x values comply with the values of Table 9, depending on the NO_x class chosen.

7.3.2 Weighting

7.3.2.1 General

The weighting of the NO_x measured values shall be calculated as described in 7.3.2.2 to 7.3.2.5, on the basis of the values in Table 10.

Table 10 - Weighting factors

Partial heat input $Q_{pi,\%}$ as % of Q_n	70	60	40	20
Weighting factor F_{pi}	0,15	0,25	0,30	0,30

(standards.itech.ai)

For range rated appliances Q_n is replaced by Q_a , the arithmetic mean of the maximum and the minimum heat input of the range, as stated by the manufacturer.

<https://standards.itech.ai/catalog/standards/sist/7b1e0911-7efe-4e3e-bf9f-d13d8b2847f2/sist-en-419-1-1999-a1-2002>

7.3.2.2 On/off appliances

The NO_x concentration is measured (and possibly corrected as specified in 7.3.1) at the nominal heat input, Q_n .

7.3.2.3 Appliances with several rates

The NO_x concentration is measured (and possibly corrected as specified in 7.3.1) at the partial heat input corresponding to each of the rates and weighted in accordance with Table 10.

If necessary, the weighting factor specified in Table 10 is recalculated for each rate as specified below.

If the heat inputs of two rates are between the partial heat inputs specified in Table 10, it is necessary to apportion the weighting factor between the heat inputs of the higher and lower rates, as follows:

$$F_{p, \text{high rate}} = F_{pi} \cdot \frac{Q_{pi, \%} - Q_{\text{low rate}, \%}}{Q_{\text{high rate}, \%} - Q_{\text{low rate}, \%}} \cdot \frac{Q_{\text{high rate}, \%}}{Q_{pi, \%}}$$

$$F_{p, \text{low rate}} = F_{pi} - F_{p, \text{high rate}}$$

If the heat inputs of two rates cover more than one partial heat input specified in Table 10, then it is necessary to apportion each weighting factor between the heat inputs of the higher and lower rate as indicated above.

The weighted NO_x value, NO_{x,pond}, is then equal to the sum of the products of the measured NO_x values at the different rates, multiplied by their weighting factor, calculated as specified below:

$$NO_{x, \text{pond}} = \sum (NO_{x, \text{mes high}} \cdot F_{p, \text{high rate}})$$

(See calculation example in Annex F and calculation of conversions of NO_x in Annex G.)

7.3.2.4 Modulating appliances in which the minimum modulating heat input is no greater than 0,20 Q_n

The NO_x concentration is measured (and possibly corrected as specified in 7.3.1) at the partial heat inputs specified in Table 10.

The weighted NO_x value, NO_{x,pond}, is determined as specified below:

$$NO_{x, \text{pond}} = 0,15 \times NO_{x, \text{mes}(70)} + 0,25 \times NO_{x, \text{mes}(60)} + 0,3 \times NO_{x, \text{mes}(40)} + 0,3 \times NO_{x, \text{mes}(20)}$$

7.3.2.5 Modulating appliances in which the minimum modulating heat input is greater than 0,20 Q_n

The NO_x concentration is measured (and possibly corrected as specified in 7.3.1) at the minimum modulating rate and at the partial heat inputs Q_{pi, %}, specified in Table 10, which are greater than the minimum modulation rate.

The weighting factors for the partial heat inputs in Table 10, which are no greater than the minimum modulation rate are added and multiplied by this heat input.

The weighted NO_x value, NO_{x,pond}, is therefore determined as follows:

$$NO_{x,pond} = NO_{x,mes,Qmin} \cdot \sum F_{pi} (Q \leq Q_{min}) + \sum (NO_{x,mes} \cdot F_{pi})$$

where:

Q_{min} is the minimum modulating heat input, expressed in kilowatt (kW);

Q_n is the nominal heat input, expressed in kilowatt (kW);

Q_a is the arithmetic mean heat input of Q_n and Q_{min} , expressed in kilowatt (kW);

$Q_{pi,\%}$ is the partial heat input for weighting, expressed in percent of Q_n ;

F_{pi} is the weighting factor corresponding to the partial heat input $Q_{pi,\%}$;

$NO_{x,mes}$ is the measured (and possibly corrected) value expressed in milligram per kilowatthour (mg/kWh):

- at the partial heat input : $NO_{x,mes(70)}$, $NO_{x,mes(60)}$, ... ;

- at the minimum heat input (modulating appliances): $NO_{x,mes,Qmin}$;

- at the heat input corresponding to a single rate : $NO_{x,mes(rate)}$;

$Q_{high\ rate,\%}$ is the heat input rate greater than $Q_{pi,\%}$;

$Q_{low\ rate,\%}$ is the heat input rate less than $Q_{pi,\%}$;

$F_{p,high\ rate}$ is the apportioned weighting factor, high rate;

$F_{p,low\ rate}$ is the apportioned weighting factor, low rate.

ITEH STANDARD PREVIEW
(standards.iteh.ai)

Clause 8.1.1 Data plate

Add the following indent:

[SIST EN 419-1:1999/A1:2002](https://standards.iteh.ai/catalog/standards/sist/7b1e0911-7efe-4e3e-bf9f-d13d8b2847f2/sist-en-419-1-1999-a1-2002)

<https://standards.iteh.ai/catalog/standards/sist/7b1e0911-7efe-4e3e-bf9f-d13d8b2847f2/sist-en-419-1-1999-a1-2002>

'k) the NO_x class of the appliance.'

Annex F (informative) Bibliography

Reposition 'Bibliography', and existing references, after Annex ZA, under the following heading:

'Bibliography'