

Second edition  
2009-03-15

AMENDMENT 2

2021-09

---

---

**Plastics piping systems for hot and  
cold water installations — Chlorinated  
poly(vinyl chloride) (PVC-C) —**

**Part 3:  
Fittings**

**AMENDMENT 2**  
**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

*Systemes de canalisations en plastique pour les installations d'eau  
chaude et froide — Poly(chlorure de vinyle) chloré (PVC-C) —*

*ISO 15877-3:2009/Amd 2:2021*

*Partie 3: Raccords*

<https://standards.iteh.ai/catalog/standards/sist/d6f0742f-c1ea-475f-90d4-48babd141111/iso-15877-3-2009-amd-2-2021>

**AMENDMENT 2**



Reference number  
ISO 15877-3:2009/Amd.2:2021(E)

© ISO 2021

## iTeh STANDARD PREVIEW (standards.iteh.ai)

ISO 15877-3:2009/Amd 2:2021  
<https://standards.iteh.ai/catalog/standards/sist/d6f0742f-c1ea-475f-90d4-48babd1a7e3d/iso-15877-3-2009-amd-2-2021>



### **COPYRIGHT PROTECTED DOCUMENT**

© ISO 2021

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
CP 401 • Ch. de Blandonnet 8  
CH-1214 Vernier, Geneva  
Phone: +41 22 749 01 11  
Email: [copyright@iso.org](mailto:copyright@iso.org)  
Website: [www.iso.org](http://www.iso.org)

Published in Switzerland

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html) (standards.iteh.ai)

This document was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fittings and valves for the transport of fluids*, Subcommittee SC 2, *Plastics pipes and fittings for water supplies*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 155, *Plastics piping systems and ducting systems*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

A list of all parts in the ISO 15877 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at [www.iso.org/members.html](http://www.iso.org/members.html).

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[ISO 15877-3:2009/Amd 2:2021](https://standards.iteh.ai/catalog/standards/sist/d6f0742f-c1ea-475f-90d4-48babd1a7e3d/iso-15877-3-2009-amd-2-2021)

<https://standards.iteh.ai/catalog/standards/sist/d6f0742f-c1ea-475f-90d4-48babd1a7e3d/iso-15877-3-2009-amd-2-2021>

# Plastics piping systems for hot and cold water installations — Chlorinated poly(vinyl chloride) (PVC-C) —

## Part 3: Fittings

### AMENDMENT 2

#### *Normative references*

Add the following normative references:

ISO 2768-1, *General tolerances — Part 1: Tolerances for linear and angular dimensions without individual tolerance indications*

ISO 6506-1, *Metallic materials — Brinell hardness test — Part 1: Test method*

ISO 6509-1, *Corrosion of metals and alloys — Determination of dezincification resistance of copper alloys with zinc — Part 1: Test method*

ISO 6957, *Copper alloys — Ammonia test for stress corrosion resistance*

ISO 22081, *Geometrical product specifications (GPS) — Geometrical tolerancing — General geometrical specifications and general size specifications*  
standards/sist/d6f0742f-c1ea-475f-90d4-48babd1a7e3d/iso-15877-3-2009-amd-2-2021

Delete the following normative reference:

EN 1254-3, *Copper and copper alloys — Plumbing fittings — Part 3: Fittings with compression ends for use with plastics pipes*

#### 3.1.2.1

Replace the existing definition 3.1.2.1 with the following:

##### **3.1.2.1 compression fitting**

fitting with internal support in which the joint is made by screwing a union nut along a thread to compress a ring on the outside wall of the pipe and finally to cause a clamping of the pipe between the ring and the inner support of the fitting

Note 1 to entry: The fitting may be with or without sealing element.

4.2

Replace the existing title of subclause 4.2 with the following:

**4.2 Plastics fitting material**

4.4, Table 1

Insert the following table footnote <sup>d</sup> to Vicat softening temperature (VST):

<sup>d</sup> Test samples may be annealed prior to testing at conditions recommended by the manufacturer.

4.4, Table 2

Insert the following table footnote <sup>d</sup> to Vicat softening temperature (VST):

<sup>d</sup> Test samples may be annealed prior to testing at conditions recommended by the manufacturer.

4.5

Replace the existing subclause 4.5 with the following:

**4.5 Metallic fitting material**

Metallic materials for fittings intended to be used with components conforming to ISO 15877 shall be either copper alloys or stainless steel alloys. The alloys shall be defined according to a standard or regulatory document.

NOTE Examples for such standards and regulatory documents are listed in the Bibliography.

For copper alloys, the fittings made thereof shall conform with the corrosion resistance requirements according to 7.4.

5.1

Replace the existing subclause 5.1 with the following:

**5.1 Appearance**

**5.1.1 Appearance of plastic fittings**

When viewed without magnification, the internal and external surfaces of fittings shall be smooth, clean and free from scoring, cavities and other surface defects to an extent that would prevent conformance with this document. The material shall not contain visible impurities. Slight variations in appearance of the colour shall be permitted. Each end of a fitting shall be perpendicular to its longitudinal axis.

**5.1.2 Appearance of metal fittings**

When viewed without magnification, the internal and external surfaces of fittings shall be clean, free from any residues from the production (e.g. free from cast sand, grease or release agent) and shall have no sharp edges or cracks.

5.2

Replace the existing title of subclause 5.2 with the following:

**5.2 Opacity of plastic fittings**

*6.1, first sentence*

Replace the existing first sentence of subclause 6.1 with the following two sentences:

Dimensions of plastic fittings shall be measured in accordance with ISO 3126.

Dimensions of metal fittings shall be measured in accordance with ISO 2768-1 and/or ISO 22081.

6.2

Replace the existing title of subclause 6.2 with the following:

**6.2 Dimensions of plastic fittings**

**iTeh STANDARD PREVIEW  
(standards.iteh.ai)**

[ISO 15877-3:2009/Amd 2:2021](https://standards.iteh.ai/catalog/standards/sist/d6f0742f-c1ea-475f-90d4-48babd1a7e3d/iso-15877-3-2009-amd-2-2021)

<https://standards.iteh.ai/catalog/standards/sist/d6f0742f-c1ea-475f-90d4-48babd1a7e3d/iso-15877-3-2009-amd-2-2021>

6.2.2, Table 3

Replace the existing Table 3 with the following new Table 3. Larger dimensions (180 mm to 250 mm) have been added. The dimensions of 12 mm to 160 mm remain unchanged from the ISO 15877-3:2009 version.

**Table 3 — Wall thicknesses of fitting bodies**

Nominal diameter $d_n$	Pipe series		
	S 6,3	S 5	S 4
	Minimum wall thickness <sup>a</sup>		
	$e_{min}$		
12	1,9	1,9	1,9
14	1,9	1,9	2,2
16	1,9	2,1	2,5
20	2,1	2,6	3,2
25	2,6	3,2	3,8
32	3,3	4,0	4,9
40	4,1	5,0	6,1
50	5,0	6,3	7,6
63	6,4	7,9	9,6
75	7,6	9,2	11,4
90	9,1	11,1	13,7
110	11,0	13,5	16,7
125	12,5	15,4	18,9
140	14,0	17,2	21,2
160	16,0	19,8	24,2
180	18,0	22,2	27,2
200	19,9	24,6	30,3
225	22,5	27,7	34,1
250	24,9	30,7	37,7

<sup>a</sup> The values are rounded up to the first place of the decimals (i.e. the nearest higher 0,1 mm).



6.2.5, Table 4

Replace the existing Table 4 with the following new Table 4. Larger dimensions (180 mm to 250 mm) have been added. The dimensions of 12 mm to 160 mm remain unchanged from the ISO 15877-3:2009 version.

**Table 4 — Calculated laying lengths (Z-lengths) and related tolerances of elbows, tees and couplers (double-sockets)**

Dimensions in millimetres

Nominal diameter $d_n$	Type of fitting					
	90° elbow	45° elbow	90° tee	45° tee		Double-socket
	Calculated Z-length and recommended deviations					
	Z	Z	Z	Z	Z <sub>1</sub>	Z
12	7 ± 1	3,5 ± 1	7 ± 1	--	--	3 ± 1
14	8 ± 1	4 ± 1	8 ± 1	--	--	3 ± 1
16	9 ± 1	4,5 ± 1	9 ± 1	--	--	3 ± 1
20	11 ± 1	5 ± 1	11 ± 1	27 ± 3	6 <sup>+2</sup> <sub>-1</sub>	3 ± 1
25	13,5 <sup>+1,2</sup> <sub>-1</sub>	6 <sup>+1,2</sup> <sub>-1</sub>	13,5 <sup>+1,2</sup> <sub>-1</sub>	33 ± 3	7 <sup>+2</sup> <sub>-1</sub>	3 <sup>+1,2</sup> <sub>-1</sub>
32	17 <sup>+1,6</sup> <sub>-1</sub>	7,5 <sup>+1,6</sup> <sub>-1</sub>	17 <sup>+1,6</sup> <sub>-1</sub>	42 <sup>+4</sup> <sub>-3</sub>	8 <sup>+2</sup> <sub>-1</sub>	3 <sup>+1,6</sup> <sub>-1</sub>
40	21 <sup>+2</sup> <sub>-1</sub>	9,5 <sup>+2</sup> <sub>-1</sub>	21 <sup>+2</sup> <sub>-1</sub>	51 <sup>+5</sup> <sub>-3</sub>	10 <sup>+2</sup> <sub>-1</sub>	3 <sup>+2</sup> <sub>-1</sub>
50	26 <sup>+2,5</sup> <sub>-1</sub>	11,5 <sup>+2,5</sup> <sub>-1</sub>	26 <sup>+2,5</sup> <sub>-1</sub>	63 <sup>+6</sup> <sub>-3</sub>	12 <sup>+2</sup> <sub>-1</sub>	3 <sup>+2</sup> <sub>-1</sub>
63	32,5 <sup>+3,2</sup> <sub>-1</sub>	14 <sup>+3,2</sup> <sub>-1</sub>	32,5 <sup>+3,2</sup> <sub>-1</sub>	79 <sup>+7</sup> <sub>-3</sub>	14 <sup>+2</sup> <sub>-1</sub>	3 <sup>+2</sup> <sub>-1</sub>
75	38,5 <sup>+4</sup> <sub>-1</sub>	16,5 <sup>+4</sup> <sub>-1</sub>	38,5 <sup>+4</sup> <sub>-1</sub>	94 <sup>+9</sup> <sub>-3</sub>	17 <sup>+2</sup> <sub>-1</sub>	4 <sup>+2</sup> <sub>-1</sub>
90	46 <sup>+5</sup> <sub>-1</sub>	19,5 <sup>+5</sup> <sub>-1</sub>	46 <sup>+5</sup> <sub>-1</sub>	112 <sup>+11</sup> <sub>-3</sub>	20 <sup>+3</sup> <sub>-1</sub>	5 <sup>+2</sup> <sub>-1</sub>
110	56 <sup>+6</sup> <sub>-1</sub>	24 <sup>+6</sup> <sub>-1</sub>	56 <sup>+6</sup> <sub>-1</sub>	137 <sup>+13</sup> <sub>-4</sub>	24 <sup>+3</sup> <sub>-1</sub>	6 <sup>+3</sup> <sub>-1</sub>
125	63,5 <sup>+6</sup> <sub>-1</sub>	27 <sup>+6</sup> <sub>-1</sub>	63,5 <sup>+6</sup> <sub>-1</sub>	157 <sup>+15</sup> <sub>-4</sub>	27 <sup>+3</sup> <sub>-1</sub>	6 <sup>+3</sup> <sub>-1</sub>
140	71 <sup>+7</sup> <sub>-1</sub>	30 <sup>+7</sup> <sub>-1</sub>	71 <sup>+7</sup> <sub>-1</sub>	175 <sup>+17</sup> <sub>-5</sub>	30 <sup>+4</sup> <sub>-1</sub>	8 <sup>+3</sup> <sub>-1</sub>
160	81 <sup>+8</sup> <sub>-1</sub>	34 <sup>+8</sup> <sub>-1</sub>	81 <sup>+8</sup> <sub>-1</sub>	200 <sup>+20</sup> <sub>-6</sub>	35 <sup>+4</sup> <sub>-1</sub>	8 <sup>+4</sup> <sub>-1</sub>
180	91 <sup>+8</sup> <sub>-1</sub>	39 <sup>+8</sup> <sub>-1</sub>	91 <sup>+8</sup> <sub>-1</sub>	224 <sup>+24</sup> <sub>-8</sub>	39 <sup>+8</sup> <sub>-1</sub>	8 <sup>+4</sup> <sub>-1</sub>
200	101 <sup>+9</sup> <sub>-1</sub>	43 <sup>+9</sup> <sub>-1</sub>	101 <sup>+9</sup> <sub>-1</sub>	249 <sup>+25</sup> <sub>-8</sub>	43 <sup>+9</sup> <sub>-1</sub>	8 <sup>+5</sup> <sub>-1</sub>
225	114 <sup>+10</sup> <sub>-1</sub>	48 <sup>+10</sup> <sub>-1</sub>	114 <sup>+10</sup> <sub>-1</sub>	280 <sup>+28</sup> <sub>-9</sub>	48 <sup>+10</sup> <sub>-1</sub>	10 <sup>+5</sup> <sub>-1</sub>
250	126 <sup>+10</sup> <sub>-1</sub>	53 <sup>+10</sup> <sub>-1</sub>	126 <sup>+10</sup> <sub>-1</sub>	310 <sup>+31</sup> <sub>-10</sub>	53 <sup>+10</sup> <sub>-1</sub>	12 <sup>+5</sup> <sub>-2</sub>

6.2.5, Table 7

Replace the existing Table 7 with the following new Table 7. Larger dimensions (180 mm to 250 mm) have been added. The dimensions of 14 mm to 160 mm remain unchanged from the ISO 15877-3:2009 version.

**Table 7 — Calculated laying lengths (Z-lengths) and related tolerances of reducing bushes, long type, with cylindrical sockets**

Dimensions in millimetres

Nominal diameter of the socket $d_1$	Nominal diameter of the spigot, $d_2$															
	20	25	32	40	50	63	75	90	110	125	140	160	180	200	225	250
	±1			±1,5				±2								
14	21	25	30	-	-	-	-	-	-	-	-	-	-	-	-	-
16	21	25	30	36	-	-	-	-	-	-	-	-	-	-	-	-
20	-	25	30	36	44	-	-	-	-	-	-	-	-	-	-	-
25	-	-	30	36	44	54	-	-	-	-	-	-	-	-	-	-
32	-	-	-	36	44	54	62	-	-	-	-	-	-	-	-	-
40	-	-	-	-	44	54	62	74	-	-	-	-	-	-	-	-
50	-	-	-	-	-	54	62	74	88	-	-	-	-	-	-	-
63	-	-	-	-	-	-	62	74	88	100	-	-	-	-	-	-
75	-	-	-	-	-	-	-	74	88	100	111	-	-	-	-	-
90	-	-	-	-	-	-	-	-	88	100	111	126	-	-	-	-
110	-	-	-	-	-	-	-	-	-	100	111	126	141	-	-	-
125	-	-	-	-	-	-	-	-	-	-	111	126	141	156	-	-
140	-	-	-	-	-	-	-	-	-	-	-	126	141	156	175	-
160	-	-	-	-	-	-	-	-	-	-	-	-	141	156	175	194
180	-	-	-	-	-	-	-	-	-	-	-	-	-	156	175	194
200	-	-	-	-	-	-	-	-	-	-	-	-	-	-	175	194
225	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	194

6.2.5, Table 9

Replace the existing Table 9 with the following new Table 9. Larger dimensions (180 mm to 250 mm) have been added. The dimensions of 14 mm to 160 mm have been unchanged from the ISO 15877-3:2009 version.

**Table 9 — Calculated laying lengths (Z-lengths) and related tolerances of reducing bushes, short type, with cylindrical sockets**

Dimensions in millimetres

Nominal diameter of the socket $d_1$	Nominal diameter of the spigot, $d_2$																	
	16	20	25	32	40	50	63	75	90	110	125	140	160	180	200	225	250	
	Calculated laying length, Z, and related tolerances $\pm 1$																	
14	1	3	5,5	9	-	-	-	-	-	-	-	-	-	-	-	-	-	
16	-	2	4,5	8	12	-	-	-	-	-	-	-	-	-	-	-	-	
20	-	-	2,5	6	10	15	-	-	-	-	-	-	-	-	-	-	-	
25	-	-	-	3,5	7,5	12,5	19	-	-	-	-	-	-	-	-	-	-	
32	-	-	-	-	4	9	15,5	21,5	-	-	-	-	-	-	-	-	-	
40	-	-	-	-	-	5	11,5	17,5	25	-	-	-	-	-	-	-	-	
50	-	-	-	-	-	-	6,5	12,5	20	30	-	-	-	-	-	-	-	
63	-	-	-	-	-	-	-	-	6	13,5	23,5	31	-	-	-	-	-	
75	-	-	-	-	-	-	-	-	-	7,5	17,5	25	32,5	-	-	-	-	
90	-	-	-	-	-	-	-	-	-	-	10	17,5	25	35	-	-	-	
110	-	-	-	-	-	-	-	-	-	-	-	7,5	15	25	35	-	-	
125	-	-	-	-	-	-	-	-	-	-	-	-	7,5	17,5	27,5	37,5	-	
140	-	-	-	-	-	-	-	-	-	-	-	-	-	10	20	30	42,5	
160	-	-	-	-	-	-	-	-	-	-	-	-	-	-	10	20	32,5	45
180	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	10	22,5	35
200	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	12,5	25
225	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	12,5