



Standard Practice for Specimen Preparation and Mounting of Site-Fabricated Stretch Systems to Assess Surface Burning Characteristics¹

This standard is issued under the fixed designation E2573; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice describes procedures for specimen preparation and mounting when testing a site-fabricated stretch system to assess flame spread and smoke developed as surface-burning characteristics using Test Method E84.

1.2 Testing is conducted with Test Method E84.

1.3 This practice does not provide pass/fail criteria that can be used as a regulatory tool.

1.4 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard. See IEEE/ASTM SI-10 for further details.

1.5 This fire standard cannot be used to provide quantitative measures.

1.6 Fire testing of products and materials is inherently hazardous, and adequate safeguards for personnel and property shall be employed in conducting these tests. Fire testing involves hazardous materials, operations, and equipment. This standard gives instructions on specimen preparation and mounting, but the fire-test-response method is given in Test Method E84. See also Section 10.

1.7 This practice shall not apply to vinyl stretch ceiling materials, which are covered by Practice E2599.

1.8 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

1.9 The text of this standard references notes and footnotes which provide explanatory material. These notes and footnotes shall not be considered requirements of the standard.

¹ This practice is under the jurisdiction of ASTM Committee E05 on Fire Standards and is the direct responsibility of Subcommittee E05.22 on Surface Burning.

Current edition approved Feb. 1, 2012. Published March 2012. Originally approved in 2007. Last previous edition approved in 2007 as E2573–07a. DOI: 10.1520/E2573-12.

2. Referenced Documents

2.1 *ASTM Standards*:²

E84 Test Method for Surface Burning Characteristics of Building Materials

E176 Terminology of Fire Standards

E2599 Practice for Specimen Preparation and Mounting of Reflective Insulation, Radiant Barrier and Vinyl Stretch Ceiling Materials for Building Applications to Assess Surface Burning Characteristics

IEEE/ASTM SI-10 International System of Units (SI): The Modern Metric System

3. Terminology

3.1 *Definitions*—For definitions of terms used in this practice refer to Terminology E176.

3.2 *Definitions of Terms Specific to This Standard*:

3.2.1 *frame, n*—an item (plastic extrusion, wood, metal or other material) that is mounted to an existing substrate via mechanical fasteners or adhesive, that has a mechanism for holding an outer layer (fabric or vinyl) by tension.

3.2.2 *joining material, n*—the frame piece used to join two or more site fabricated stretch panels together, to create a midseam.

3.2.3 *longitudinal midseam, n*—a seam made from the joining material used in the stretch system, which is centered on the test specimen and runs the entire length of the test specimen.

3.2.4 *self-supporting specimen, n*—a specimen that remains in place by its own structural characteristics both before and during the fire test or is burnt or pyrolyzed prior to falling away from its original position.

3.2.5 *site-fabricated stretch system, n*—a system, fabricated on site and intended for acoustical, tackable or aesthetic purposes, that is comprised of three elements: (a) a frame (constructed of plastic, wood, metal or other material) used to hold fabric in place, (b) a core material (infill, with the correct

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.