# TECHNICAL SPECIFICATION

ISO/TS 17755-2

First edition 2020-08

Fire safety — Statistical data collection —

Part 2: **Vocabulary** 

iTeh Standards (https://standards.iteh.ai) Document Preview

ISO/TS 17755-2:2020

https://standards.iteh.ai/catalog/standards/iso/c9b1f01b-2a24-468f-bc33-ae2c0d7a72c6/iso-ts-17755-2-2020



# iTeh Standards (https://standards.iteh.ai) Document Preview

ISO/TS 17755-2:2020

https://standards.iteh.ai/catalog/standards/iso/c9b1f01b-2a24-468f-bc33-ae2c0d7a72c6/iso-ts-17755-2-2020



#### **COPYRIGHT PROTECTED DOCUMENT**

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office CP 401 • Ch. de Blandonnet 8 CH-1214 Vernier, Geneva Phone: +41 22 749 01 11 Email: copyright@iso.org Website: www.iso.org

Published in Switzerland

Con	tents	Page
Forev	vord	iv
Intro	Introduction	
1	Scope	1
2	Normative references	1
3	Terms and definitions	1
Bibliography		12
Alnha	Alphahetical index	

## iTeh Standards (https://standards.iteh.ai) Document Preview

ISO/TS 17755-2:2020

https://standards.iteh.ai/catalog/standards/iso/c9b1f01b-2a24-468f-bc33-ae2c0d/a/2c6/iso-ts-1//55-2-2020

#### **Foreword**

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see <a href="www.iso.org/directives">www.iso.org/directives</a>).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see <a href="https://www.iso.org/patents">www.iso.org/patents</a>).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see <a href="https://www.iso.org/iso/foreword.html">www.iso.org/iso/foreword.html</a>.

This document was prepared by Technical Committee ISO/TC 92, Fire safety.

A list of all parts in the ISO 17755 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at <a href="https://www.iso.org/members.html">www.iso.org/members.html</a>.

#### Introduction

ISO/TR 17755:2014 has shown that experts involved in fire safety who work on international and national fire statistics databases face three main issues:

- 1) a lack of common terminology (many terms have different definitions),
- 2) a lack of common methodology,
- 3) some weaknesses in the training and qualification of fire investigators.

In order to harmonize the existing definitions within ISO, this document is a tool for use in proposing a common methodology for collecting fire statistics. It was decided to harmonize the definitions of certain terms commonly used in fire statistical data within the framework of ISO and to collect them in this document which is the only terminology guide used for this series of International Standards. This document supplements ISO 13943 for application to fire statistics.

The methodology for collecting fire statistics will be the focus of a future part in this series.

## iTeh Standards (https://standards.iteh.ai) Document Preview

ISO/TS 17755-2:2020

https://standards.iteh.ai/catalog/standards/iso/c9b1f01b-2a24-468f-bc33-ae2c0d7a72c6/iso-ts-17755-2-2020

# iTeh Standards (https://standards.iteh.ai) Document Preview

ISO/TS 17755-2:2020

https://standards.iteh.ai/catalog/standards/iso/c9b1f01b-2a24-468f-bc33-ae2c0d7a72c6/iso-ts-17755-2-2020

## Fire safety — Statistical data collection —

### Part 2:

## **Vocabulary**

#### 1 Scope

Data collection is of prime importance in fire safety, for several reasons: assessing the effect of any regulation, providing probability and gravity data to fire risk analysis, and the selection of scenarios for examples in fire safety engineering. Statistical data collection of fires is nevertheless collected and analysed from local or national perspectives at the time of publication of this document, making any comparison difficult. A first step identified in the need for harmonization is the issue of terminology.

This document defines terminology relating to fire statistical data, in order to supplement ISO 13943 for this specific field of application.

#### 2 Normative references

There are no normative references in this document.

## 3 Terms and definitions://standards.iteh.ai)

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <a href="https://www.iso.org/obp">https://www.iso.org/obp</a>
- IEC Electropedia: available at <a href="http://www.electropedia.org/">http://www.electropedia.org/</a>

#### 3.1

#### accelerant

*fuel* (3.51) or oxidizer, often an ignitable liquid, solid or gas (LGP/NP) intentionally used to initiate a fire or increase the rate of growth or spread of fire

#### 3.2

#### accidental fire

fire for which the cause does not involve an intentional human act to ignite or spread the fire into an area where the fire should not be

#### 3.3

#### age group of victims

categorization by age of the *victims* (3.15) of fire

Note 1 to entry: this categorization may differ locally. This document proposes the following categories:

- Newborn (child under 28 days of age)
- Child (person whose age is between 28 days (included) and 9 years (included))
- Youth (person whose age is between 10 years (included) and 17 years (included))
- Adult (person whose age is between 18 years (included) and 64 years (included))
- Elderly (person who is aged 65 or more).

#### ISO/TS 17755-2:2020(E)

#### 3.4

#### alarm

time to notification to fire service or other local service

Note 1 to entry: This definition differs from alarm time defined in ISO 13943:2017, 3.16 which corresponds to the time interval between ignition of a fire and activation of an alarm to notify occupants.

#### 3.5

#### area of origin of the fire

general localized area within the location where the fire started

Note 1 to entry: See also, location of the fire (3.58) and point of origin of the fire (3.64).

#### 3.6

act of intentionally and maliciously starting a fire or causing an explosion

#### 3.7

#### arsonist

person who commits arson (3.6)

#### auto-ignition

#### self-ignition

initiation of combustion by heat but without a spark or flame

### 3.9

## backdraft

rapid flaming combustion caused by the sudden introduction of air into a confined oxygen-deficient space that contains gaseous *fuel* (3.51) or hot products of incomplete combustion

Note 1 to entry: In some cases, these conditions can result in an explosion.

#### 3.10

#### building

permanent or semi-permanent walled and roofed structure that stands alone and separately from other structures, including those under construction, or any comparable structure

Note 1 to entry: See also built environment, ISO 13943:2017, 3.32.

Note 2 to entry: When buildings are used for automatic operations, this shall be specified.

#### 3.11

#### building fire

fire involving any kind of building (3.10) such as residential, commercial, public building

#### 3.12

#### building status

status of the *building* (3.10) in terms of occupancy or construction

Occupied, vacant or permanently unoccupied, under construction, under demolition **EXAMPLE** 

#### 3.13

#### building under construction

*building* (3.10) for which construction is in progress

#### 3.14

#### building under demolition

building (3.10) for which demolition is in progress

#### 3.15

#### casualty

#### victim

person killed or injured

#### 3.16

#### cause of a fire

predefined categorical class of the primary cause of the fire

Note 1 to entry: See also, source of the fire (3.74), material first ignited (3.59), classification of the primary cause of a fire (3.20) and circumstances of the fire (3.19).

#### 3.17

#### cause of unacceptable fire (and smoke) propagation

reason of fire (and smoke) spread

Note 1 to entry: This should be prevented by fire protection measures.

Note 2 to entry: Note to entry 1: Typical causes are, amongst other things, use of unsuitable building materials, defects in fire detection, insufficient supply of extinguishing water, and inadmissible shutdown of automatic fire extinguishing systems.

#### 3.18

#### cause of casualty

phenomenon causing death of a person in a fire

EXAMPLE Smoke inhalation (heat gases and toxic gases including oxygen depletion), burn, physical injury.

#### 3.19

#### circumstance of the fire

element (including events, factors, behaviours, characteristics, coincidences) that contributed to ignition and development of a fire the contributed to the contribu

Note 1 to entry: See also, source of the fire (3.74), material first ignited (3.59), cause of a fire (3.16) and classification of the primary cause of a fire (3.20).

## atandards.iteh.ai/catalog/standards/iso/c9b1f01b-2a24-468f-bc33-ae2c0d7a72c6/iso-ts-17755-2-2020

#### classification of the primary cause of a fire

predefined categorical classes of the primary *cause of a fire* (3.16)

Note 1 to entry: This classification is composed of the following items:

- Undetermined
- Natural, for example caused by lightning, volcanoes, etc.
- Caused by human actions
  - Unintentional
  - Intentional (arson [3.6], suicide fire [3.71])
  - Unknown intent
- Technological
  - Electrical, e.g. short-circuit, overload and overheating
  - Fuel (3.51) leak or gas leak
  - Thermal, e.g. heater, flame
  - Explosion, e.g. bomb
  - Spontaneous ignition

#### ISO/TS 17755-2:2020(E)

Note 2 to entry: See also source of the fire (3.74), material first ignited (3.59), cause of a fire (3.16) and circumstances of the fire (3.20).

#### 3.21

#### condition of casualty

predefined categorical classes of the circumstances of casualty

EXAMPLE Asleep at time of fire; bedridden or other physical handicap; defenestration; impairment by alcohol; impairment by drugs; impairment by medication; blinded or partially sighted; deafness; mental impairment; *senility* (3.72); awake and no physical or mental impairment at the time of fire; under restraint or detention; too young to react to fire emergency; child left unattended; unclassified.

#### 3.22

#### commercial and industry fire

fire on the premises of a commercial or industrial enterprise

Note 1 to entry: Note to entry 1: Commercial and industrial fires can reach, depending on operational processes and materials, a considerable extent, which can only be supressed effectively with special extinguishing agents and a long onset time of fire brigade.

#### 3.23

#### damages

total loss caused by fire, including *direct property damages* (3.25) and *indirect losses* (3.54) such as business interruption, loss of future production and including loss of wildlife or watershed values in wildland fires

Note 1 to entry: Damages may be categorized as economic loss, physical loss, and environmental loss.

#### 3.24

deliberate fire incendiary fire intentional fire voluntary fire

# (https://standards.iteh.ai) Document Preview

fire intentionally ignited under circumstances in which the person knows that the fire should not be ignited  $\frac{\text{ISO/TS }17755-2:2020}{\text{ISO/TS }17755-2:2020}$ 

Note 1 to entry: They are composed of *arson* (3.6) and suicides by fires.

#### 3.25

#### direct property damages

damages (3.23) excluding indirect losses (3.54)

Note 1 to entry: See also, damages (3.23) and indirect losses (3.54).

#### 3.26

#### dwelling fire

#### home fire

#### residential fire

fire which occurs in a property that is also a place of residence, excluding hotels, hostels and residential institutions

#### 3.27

#### ethnicity

group of people classified together on the basis of physical characteristics transmitted genetically or of common nationality or geographical or historical location

Note 1 to entry: Some countries provide fire statistical data related to ethnicity, whereas in some other countries this is prohibited for ethical reasons.