

# INTERNATIONAL STANDARD

ISO  
**19880-8**

First edition  
2019-10

**AMENDMENT 1**  
2021-08

---

---

## Gaseous hydrogen — Fuelling stations —

### Part 8: **Fuel quality control**

AMENDMENT 1: Alignment with Grade D

iTEH Standards

(<https://standards.iteh.ai>)

*Hydrogène gazeux — Stations de remplissage —*

*Partie 8: Contrôle qualité du carburant*

**Document Preview**

*AMENDEMENT 1: Alignement avec le Grade D de l'ISO 14687*

[ISO 19880-8:2019/Amd 1:2021](https://standards.iteh.ai/catalog/standards/iso/bb1db472-4309-4682-8204-07d1cc04a4a7/iso-19880-8-2019-amd-1-2021)

<https://standards.iteh.ai/catalog/standards/iso/bb1db472-4309-4682-8204-07d1cc04a4a7/iso-19880-8-2019-amd-1-2021>



Reference number  
ISO 19880-8:2019/Amd.1:2021(E)

© ISO 2021

iTeh Standards  
(<https://standards.iteh.ai>)  
Document Preview

[ISO 19880-8:2019/Amd 1:2021](#)

<https://standards.iteh.ai/catalog/standards/iso/bb1db472-4309-4682-8204-07d1cc04a4a7/iso-19880-8-2019-amd-1-2021>



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2021

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
CP 401 • Ch. de Blandonnet 8  
CH-1214 Vernier, Geneva  
Phone: +41 22 749 01 11  
Email: [copyright@iso.org](mailto:copyright@iso.org)  
Website: [www.iso.org](http://www.iso.org)

Published in Switzerland

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by Technical Committee TC 197, *Hydrogen technologies*.

A list of all parts in the ISO 19880 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at [www.iso.org/members.html](http://www.iso.org/members.html).



# Gaseous hydrogen — Fuelling stations —

## Part 8: Fuel quality control

### AMENDMENT 1: Alignment with Grade D of ISO 14687

*Clause 5, first paragraph*

Replace the paragraph with the following:

The quality requirements of hydrogen fuel dispensed to PEM fuel cells for road vehicles are listed in Grade D of ISO 14687.

*8.4, first paragraph*

Replace the paragraph with the following:

It is necessary to evaluate the possible consequences on a fuel cell vehicle if any impurity exceeds the threshold value of ISO 14687 Grade D.

## Document Preview

*8.4, second paragraph*

Replace the paragraph with the following:

An estimation of the concentration above the ISO 14687 Grade D threshold values at which the severity increases (if applicable) is named “Level 1” and is given in column 5 for each impurity where the “severity class” is not already 4.

*Table 4*

Replace Table 4 with the following table:

**Table 4 — Impact of impurities on fuel cell powertrain**

<b>Impurity</b>		<b>ISO 14687 Grade D threshold value<sup>a</sup></b> [µmol/mol]	<b>Severity class (from ISO 14687 Grade D threshold value to Level 1)</b>	<b>Level 1 value</b> [µmol/mol]	<b>Severity class (greater than Level 1 threshold)</b>
Total non-H <sub>2</sub> gases		300	UD <sup>b</sup>	UD <sup>b</sup>	4
Helium	He	300	UD <sup>b</sup>	UD <sup>b</sup>	4
Nitrogen	N <sub>2</sub>	300	UD <sup>b</sup>	UD <sup>b</sup>	4
Argon	Ar	300	UD <sup>b</sup>	UD <sup>b</sup>	4
Oxygen	O <sub>2</sub>	5	UD <sup>c</sup>	UD <sup>c</sup>	4
Carbon dioxide	CO <sub>2</sub>	2	1	3	4
Carbon monoxide	CO	0,2	2-3 <sup>d</sup>	1	4
Methane	CH <sub>4</sub>	100	1	300	4
Water	H <sub>2</sub> O	5	4	N/A	4
Total sulphur compounds	H <sub>2</sub> S basis	0,004	4	N/A	4
Ammonia	NH <sub>3</sub>	0,1	4	N/A	4
Total hydrocarbons except methane	CH <sub>4</sub> basis	2	1-4 <sup>d</sup>	N/A	4
Formaldehyde	HCHO	0,2	2-3 <sup>d</sup>	1	4
Formic acid	HCOOH	0,2	2-3 <sup>d</sup>	1	4
Halogens		0,05	4	N/A	4
Maximum particulate concentration (liquid and solid) <sup>e</sup>		1 mg/kg	4	N/A	4

**Key**[ISO 19880-8:2019/Amd 1:2021](https://standards.iteh.ai/catalog/standards/iso/bb1db472-4309-4682-8204-07d1cc04a4a7/iso-19880-8-2019/amd-1-2021)

UD: undetermined

N/A: not applicable

<sup>a</sup> The threshold value is according to hydrogen specification of Grade D of ISO 14687.<sup>b</sup> The severity class (from ISO 14687 Grade D threshold value to Level 1) and Level 1 value for this impurity is undetermined because no specific study has been conducted yet in alignment with the new threshold value. It needs to be covered in the next edition of this document.<sup>c</sup> The severity class (from ISO 14687 Grade D threshold value to Level 1) and Level 1 value for oxygen are undetermined because data are lacking to confirm those values. It needs to be covered in the next edition of this document.<sup>d</sup> A higher value is to be considered for risk assessment approach until more specific data is available.<sup>e</sup> Particulates are based upon mass density mg/kg.*A.15 first paragraph*

Replace “ISO 14687-2” with “Grade D of ISO 14687” in the second last sentence.

*Table B.1*

Replace Table B.1 with the following table:

**Table B.1 — Probability of occurrence for off-site SMR**

Impurity	Threshold μmol/mol	Possible causes For the source studied		Typical barriers employed in this process	Probability with barriers
Inert gas <b>N<sub>2</sub></b>	300	Present in natural gas and syngas PSA malfunction	— PSA — Double analysis PSA outlet <100 μmol/mol		UD <sup>a</sup>
Inert gas <b>Ar</b>	300	Only ATR and POx present in O <sub>2</sub> typical 0,6 % in syngas from ATR	— PSA. Not sized to remove Ar. Ar content may be higher if H <sub>2</sub> comes from ATR, POx or feeds with high Ar content		UD <sup>a</sup>
<b>O<sub>2</sub></b>	5	Not present in syngas. O <sub>2</sub> is unstable in the condition of reforming and shift reactions. Combines with H <sub>2</sub> , CO, and CH <sub>4</sub>	— PSA cannot be used with significant O <sub>2</sub> content for safety reasons — 0		0
<b>CO<sub>2</sub></b>	2	Present in syngas (%)	— PSA adsorption strength of MS, activated carbon, silicagel higher for CO <sub>2</sub> than CO. A CO content lower than 10 μmol/mol insures a CO <sub>2</sub> content lower than 2 μmol/mol		0
<b>CO</b>	0,2	Normal operation below threshold. Occasional peaks at μmol/mol level	— Double analysis at the PSA outlet + trip if the CO>1-10 μmol/mol at PSA outlet		4
<b>CH<sub>4</sub></b>	100	Present in syngas at % level	— In most cases CO is sizing the PSA, therefore CO<10 μmol/mol => CH <sub>4</sub> <100 μmol/mol — depending on users' specification (Europe pipeline 2 μmol/mol).		2
<b>H<sub>2</sub>O</b>	5	Syngas saturated in H <sub>2</sub> O	— PSA adsorbed in alumina and MS adsorption strength higher than CO <sub>2</sub> . A CO content lower than 10 μmol/mol insures a H <sub>2</sub> O content lower than 5 μmol/mol.		0

**Key**

UD: undetermined

<sup>a</sup> The probability of occurrence for this impurity is undetermined because no specific study has been conducted yet.

Table B.1 (continued)

Impurity	Threshold μmol/mol	Possible causes For the source studied	Typical barriers employed in this process	Probability with barriers
TS	0,004	TS from natural gas	<ul style="list-style-type: none"> <li>— Desulphuration upstream reformer (typical values: normal &lt; 10 ppb, maximum &lt; 20 ppb, guarantee &lt; 50 ppb)</li> <li>— Typical dilution factor 2,5 (1 mole natural gas produces 2,5 mole H<sub>2</sub>)</li> <li>— Pre-reformer catalyst poisoning by sulphur is irreversible. Sulphur trapped at this stage.</li> <li>— In case of breakthrough, process condition cannot be achieved</li> <li>— Reformer catalyst poisoning by sulphur is irreversible. Sulphur trapped at this stage.</li> <li>— In case of breakthrough, process condition cannot be achieved</li> <li>— Shift catalyst poisoning by sulphur is irreversible. Sulphur trapped at this stage.</li> <li>— In case of breakthrough, process condition cannot be achieved</li> <li>— PSA adsorption of H<sub>2</sub>S before CO, CO<sub>2</sub>, species</li> <li>— H<sub>2</sub>S adsorption in pipe and vessels. Strong affinity with steel</li> </ul>	0
NH <sub>3</sub>	0,1	Traces present in syngas	<ul style="list-style-type: none"> <li>— PSA adsorption strength of alumina and molecular sieve higher than CO. A CO content lower than 10 μmol/mol insures a NH<sub>3</sub> content lower than 0,1 μmol/mol</li> </ul>	0
THC	2	Traces of C2+ after reforming reaction	<ul style="list-style-type: none"> <li>— PSA C2, C3, C4, C5+adsorbed by activated carbon layer. A CO content lower than 10 μmol/mol insures a THC (C<sub>2</sub>H<sub>4</sub> excluded) content lower than 2 μmol/mol</li> </ul>	0
HCHO	0,2	May be present in syngas, essentially liquid	<ul style="list-style-type: none"> <li>— PSA. Formaldehyde adsorption strength of alumina and molecular sieve higher than CO. A CO content lower than 10 μmol/mol insures a HCHO content lower than 0,1 μmol/mol. To guarantee 0,01 μmol/mol would require more experience of measuring at those levels</li> </ul>	UD <sup>a</sup>
HCOOH	0,2	May be present in syngas, essentially liquid	<ul style="list-style-type: none"> <li>— PSA. Formic adsorption strength of alumina and molecular sieve higher than CO. A CO content lower than 10 μmol/mol insures a HCOOH content lower than 0,2 μmol/mol</li> </ul>	0

**Key**

UD: undetermined

<sup>a</sup> The probability of occurrence for this impurity is undetermined because no specific study has been conducted yet.

**Table B.1** (*continued*)

Impurity	Threshold µmol/mol	Possible causes For the source studied	Typical barriers employed in this process	Probability with barriers
Halogens	0,05	Present in natural gas	<ul style="list-style-type: none"> <li>— Any Cl present in natural gas would be stopped by HDS</li> <li>— Pre-reformer catalyst poisoning by Cl irreversible. Cl trapped at this stage. If breakthrough, process condition cannot be achieved</li> <li>— Reformer catalyst poisoning by Cl irreversible. Cl trapped at this stage I breakthrough, process condition cannot be achieved</li> <li>— Shift catalyst poisoning by Cl irreversible. Cl trapped at this stage. I break through, process condition cannot be achieved</li> <li>— PSA adsorption of Cl before CO<sub>2</sub>, CO<sub>2</sub>, species</li> </ul>	0
He	300	Not present in natural gas in N Europe (<10 µmol/mol). Passes through the whole process. Dilution factor 2,5		0

**Key**

UD: undetermined

<sup>a</sup> The probability of occurrence for this impurity is undetermined because no specific study has been conducted yet.

Table B.2

Replace Table B.2 with the following table:

**Table B.2 — Probability of occurrence for pipeline**

<b>Impurity</b>	<b>Threshold µmol/mol</b>	<b>Causes possible For the item studied</b>	<b>Typical barriers employed in this process</b>	<b>Probability with barriers</b>
<b>Inert gas N<sub>2</sub></b>	300	Air intake if some areas are at negative pressure From seal gas or purge gas Wrong purging after maintenance	Inlet pressure PSL trip on compressors	UD <sup>a</sup>
<b>Inert gas Ar</b>	300	No potential	1 % Ar in the air. 100 µmol/mol would mean 1 % air in the pipe Never been observed	UD <sup>a</sup>
<b>O<sub>2</sub></b>	5	Air intake if some areas are at negative pressure	Inlet pressure PSL trip on compressors	1
<b>CO<sub>2</sub></b>	2	From Air: CO <sub>2</sub> at 400 µmol/mol in the air	2 µmol/mol of C O <sub>2</sub> would mean 0,5 % air in the pipe Never been observed	0
<b>CO</b>	0,2	No potential		0
<b>CH<sub>4</sub></b>	100	No potential		0
<b>H<sub>2</sub>O</b>	5	Wrong drying after pressure hydraulic test	H <sub>2</sub> > 40 bar ==> leak from H <sub>2</sub> O to H <sub>2</sub> unlikely during operation.	0
<b>TS</b>	0,004	No potential		0
<b>NH<sub>3</sub></b>	0,1	No potential		0
<b>THC</b>	2	No potential		0
<b>HCHO</b>	0,2	No potential		UD <sup>a</sup>
<b>HCOOH</b>	0,2	No potential		0
<b>Halogens</b>	0,05	From cleaning material after maintenance		1
<b>He</b>	300	No potential		0

**Key**

UD: undetermined

<sup>a</sup> The probability of occurrence for this impurity is undetermined because no specific study has been conducted yet. It needs to be covered in the next edition of this document.