



**International
Standard**

ISO 4917-1

**Design of nuclear power plants
against seismic events —**

**Part 1:
Principles**

Conception parasismique des installations nucléaires —

Partie 1: Principes

**First edition
2024-02**

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 4917-1:2024](https://standards.iteh.ai/catalog/standards/iso/1ed7969c-429e-471a-9b4b-55a1a9f6727f/iso-4917-1-2024)

<https://standards.iteh.ai/catalog/standards/iso/1ed7969c-429e-471a-9b4b-55a1a9f6727f/iso-4917-1-2024>

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 4917-1:2024](https://standards.iteh.ai/catalog/standards/iso/1ed7969c-429e-471a-9b4b-55a1a9f6727f/iso-4917-1-2024)

<https://standards.iteh.ai/catalog/standards/iso/1ed7969c-429e-471a-9b4b-55a1a9f6727f/iso-4917-1-2024>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2024

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 General seismic design concept	6
5 Determining the design basis earthquake	7
5.1 General requirements.....	7
5.2 Deterministic determination of the design basis earthquake.....	7
5.3 Probabilistic determination of the design basis earthquake.....	8
5.4 Specification of the design basis earthquake.....	8
5.5 Seismic-engineering parameters of the design basis earthquake.....	8
6 General design requirements	10
6.1 Design basis.....	10
6.1.1 Classification.....	10
6.1.2 Verification of design basis earthquake safety.....	10
6.2 Combinations of seismic action with other actions.....	11
6.3 Verification procedures.....	11
6.3.1 General requirements.....	11
6.3.2 Modeling.....	11
6.3.3 Acceleration time histories.....	12
6.3.4 Analysis methods.....	13
7 Seismic instrumentation and inspection level	13
8 Post seismic measures	13
9 Secondary seismic effects and ground displacements	13
10 Considerations for beyond design basis events	13
Annex A (informative) Recommendations with comments	14
Bibliography	17

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had/had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 85, *Nuclear energy, nuclear technologies, and radiological protection*, Subcommittee SC 6, *Reactor technology*.

A list of all parts in the ISO 4917 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

<https://standards.iteh.ai/catalog/standards/iso/1ed7969c-429e-471a-9b4b-55a1a9f6727f/iso-4917-1-2024>

Introduction

In accordance with IAEA Safety Standards Series No. SSR-2/1, protective measures against seismic events are required, provided earthquakes are taken into consideration.

Earthquakes comprise that group of design basis external events that requires taking preventive plant engineering measures against damage and which are relevant with respect to radiological effects on the environment.

This document will be applied under the presumption that the geology and tectonics of the plant site have been investigated with special emphasis on the existence of active geological faults and lasting geological ground displacements, and that the site has been deemed suitable for a nuclear installation.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 4917-1:2024](https://standards.iteh.ai/catalog/standards/iso/1ed7969c-429e-471a-9b4b-55a1a9f6727f/iso-4917-1-2024)

<https://standards.iteh.ai/catalog/standards/iso/1ed7969c-429e-471a-9b4b-55a1a9f6727f/iso-4917-1-2024>

Design of nuclear power plants against seismic events —

Part 1: Principles

1 Scope

This document applies to nuclear power plants with water cooled reactors and, in particular, to the design of components and civil structures against seismic events in order to meet the safety objectives. For other nuclear facilities the applicability of the document is checked in advance, before it might be applied correspondingly. Seismic isolation is not addressed in the series of ISO 4917.

The following safety objectives are defined in order to ensure the protection of people and the environment against radiation risks:

- a) controlling reactivity;
- b) cooling fuel assemblies;
- c) confining radioactive substances;
- d) limiting radiation exposure.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

<https://standards.iteh.ai/catalog/standards/iso/1ed/969c-429e-471a-9b4b-55a1a9f6727f/iso-4917-1-2024>
IAEA Safety Standards Series No., SSG-67, *Seismic Design for Nuclear Installations*, INTERNATIONAL ATOMIC ENERGY AGENCY VIENNA, (2021)

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 action

impact of an external force (e.g. seismic action)

3.2 action effect

internal force inside a structure (e.g. force, moment)

3.3

active geological fault

fault showing evidence of past movements (e.g. recent seismicity or geological evidence) within such a period that it is reasonable to assume that further movements can occur

Note 1 to entry: For areas of low seismicity evidence of last movements in the Quaternary (until $\approx 2,6 \cdot 10^6$ a) or including Pliocene (until $\approx 5,3 \cdot 10^6$ a) can be appropriate to consider. For higher seismic areas shorter periods can be considered.

Note 2 to entry: A geological fault need also to be considered active if a structural relationship with a known active geological fault is demonstrated or likely. In this case the movement of one fault can cause the movement of the other.

Note 3 to entry: The definition is equivalent to “capable fault” in IAEA Glossary (2018)^[5].

3.4

beyond design basis earthquake

decisive level of ground motion which exceeds the design basis earthquake

3.5

civil structure

building structure that is connected to the ground and consists of structural and non-structural elements (building materials and structural members)

Note 1 to entry: It may be necessary to perform the verification of earthquake safety for “civil structures” in their entirety as well as for the individual parts (“structural members”).

3.6

complete quadratic combination

CQC

stochastically based superposition relationship for oscillating systems in order to take account of the coupling of eigenmodes in modal analyses

3.7

component

electrical, instrumentation and control, and mechanical equipment that ensures the operation of the nuclear facility, including distribution systems and their support structures

Note 1 to entry: This definition is necessary for the differentiation between “plant component” and “civil structures (3.5) or building structures”. In mechanical engineering, a component is one that is manufactured from product forms and represents the smallest part of a subassembly.

3.8

correlation coefficient

ρ_{xy}

coefficient of two seismic time histories, $x(t)$ and $y(t)$, defined by the covariance σ_{xy} of $x(t)$ and $y(t)$ divided by the product of the related standard deviations s_x and s_y of the two time histories

3.9

damping ratio

D

dimensionless characteristic value of a (velocity proportional) damped oscillating single-degree-of-freedom system, in percentage of critical damping

3.10

deaggregation

quantification of the relative contributions from earthquakes of different sizes and at different distances to the seismic hazard at a site

Note 1 to entry: Usually calculated for discrete ground motion levels from the probabilistic seismic hazard analysis (PSHA) and for intervals of *magnitude* (3.24) and distance or for seismic sources.

3.11

design basis earthquake

decisive level of ground motion for the design against seismic events

Note 1 to entry: The design basis earthquake (DBE) is equivalent to SL-2 earthquake as per IAEA SSG-67 or safe shutdown earthquake (SSE) in some national guidelines. It represents the seismic impact at the site, at least expressed in terms of *ground acceleration response spectra* (3.17) and *strong motion duration* (3.38).

3.12

epistemic uncertainty

aleatoric variability

epistemic uncertainty, based on uncertainty of the state of knowledge, (e.g. regarding models or parameters) and aleatoric variability, inherently connected with stochastic phenomena or processes (e.g. decrease of acceleration amplitudes with increasing distance)

Note 1 to entry: Epistemic uncertainties can be reduced by additional data, information or improved modeling (e.g. uncertainty in specifying the source region). Aleatoric variabilities usually cannot be reduced.

Note 2 to entry: Epistemic uncertainty and aleatoric variability is equivalent to “Epistemic uncertainty” and “aleatoric uncertainty” in IAEA Glossary (2018)^[5].

3.13

external event

event unconnected with the operation of a facility or the conduct of an activity that could have an effect on the safety of the facility or activity

Note 1 to entry: These events having either natural causes (e.g. high water, earthquake) or civilizational causes (e.g. aircraft crash, pressure wave from explosions).

3.14

focal depth

depth of the hypocenter beneath the surface of the earth

3.15

free field

location at or near the surface, where vibratory ground motion is not affected by structures and facilities

3.16 [s://standards.iteh.ai/catalog/standards/iso/1ed7969c-429e-471a-9b4b-55a1a9f6727f/iso-4917-1-2024](https://standards.iteh.ai/catalog/standards/iso/1ed7969c-429e-471a-9b4b-55a1a9f6727f/iso-4917-1-2024)

functionality

ability of a system or *component* (3.7) to fulfill its designated safety functions during and after the seismic event

Note 1 to entry: This definition is specific to components. In the case of *civil structures* (3.5), the adequate term would be “serviceability”.

3.17

ground acceleration response spectrum

response spectrum derived from a ground motion related to *free field* (3.15) or a reference horizon at depth

3.18

ground motion prediction equation

GMPE

function (typically empirical) for the prediction of ground motion

Note 1 to entry: Input parameters are *magnitude* (3.24), source to site distance, local site conditions and other parameters.

3.19

inspection level earthquake

level of ground motion that, if exceeded, causes a plant inspection

3.20

integrity

ability of a plant *component* (3.7) to fulfill its functions with regard to leak tightness or deformation restrictions

3.21

(macroseismic) intensity

classification of the strength of ground motion, based on the observed effects within a limited area, e.g. a village

Note 1 to entry: Basis for determining the intensity are phenomenological descriptions of the effects on humans, objects, buildings and the earth's surface. The intensity is a robust measure for strength classification; the corresponding macroseismic classification scales (e.g. EMS 98^[11]) define twelve intensity levels.

3.22

internal event

event or group of events that result from failures of systems, structures or *components* (3.7) (SSC) or human failures originating within a nuclear power plant that cause an initiating event directly or indirectly and may challenge safety functions to achieve its safety objectives

Note 1 to entry: These are exceptional events caused by plant internal incidents (e.g. differential pressures, jet impingement and reaction forces, plant internal flooding due to breakage or leakage of pressurized components, load crash)

3.23

load-bearing capacity

ability of *components* (3.7) and *civil structures* (3.5), based on their material strength, stability and secure positioning, to withstand the impact from events

3.24

magnitude

measure of the size of an earthquake, approximately related to the energy released in the form of seismic waves

Note 1 to entry: The classic definition of seismic magnitude is the logarithm of the maximum amplitude of recorded seismograms taking the distance to the hypocenter (seismic focus center) into account. Different types of seismic magnitudes are, e.g. local magnitude, body wave magnitude, surface wave magnitude and moment magnitude.

3.25

operating basis earthquake

decisive level of ground motion that is likely to occur and affect the plant during its operating lifetime

3.26

paleoseismology

method used to search for indications of prehistoric earthquakes in geological sediments and rock formations and includes estimation of their *magnitude* (3.24) and of the age of the deformations due to earthquakes

Note 1 to entry: Paleoseismology serves to extend earthquake findings into the younger geological times. Paleoseismology is generally restricted to geological terrains of continuous sedimentation of the past ten thousands of years.

3.27

peak ground acceleration

maximum amplitude (absolute value) of the horizontal or vertical ground acceleration *components* (3.7) of the earthquake time history (accelerogram)

Note 1 to entry: It corresponds to the rigid-body acceleration of the *ground acceleration response spectrum* (3.17).