



## Standard Classification for Serviceability of an Office Facility for Manageability<sup>1,2</sup>

This standard is issued under the fixed designation E1701; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

### 1. Scope

1.1 This classification covers pairs of scales (see Figs. 1-8) for classifying an aspect of the serviceability of an office facility, that is, the capability of an office facility to meet certain possible requirements for manageability.

1.2 Within that aspect of serviceability, each pair of scales (see Figs. 1-8) are for classifying one topic of serviceability. Each paragraph in an Occupant Requirement Scale summarizes one level of serviceability on that topic, which occupants might require. The matching entry in the facility rating scale is a translation of the requirement into a description of certain features of a facility which, taken in combination, indicate that the facility is likely to meet that level of required serviceability.

1.3 The entries in the Facility Rating Scale (see Figs. 1-8) are indicative and not comprehensive. They are for quick scanning, to estimate approximately, quickly, and economically, how well an office facility is likely to meet the needs of one or another type of occupant group, over time. The entries are not for measuring, knowing, or evaluating how an office facility is performing.

1.4 This classification can be used to estimate the level of serviceability of an existing facility. It can also be used to estimate the serviceability of a facility that has been planned but not yet built, such as one for which single-line drawings and outline specifications have been prepared.

1.5 This classification indicates what would cause a facility to be rated at a certain level of serviceability, but does not state how to conduct a serviceability rating nor how to assign a serviceability score. That information is found in Practice E1334. The scales in Figs. 1-8 are complimentary to and compatible with Practice E1334. Each requires the other.

<sup>1</sup> This classification is under the jurisdiction of ASTM Committee E06 on Performance of Buildings and is the direct responsibility of Subcommittee E06.25 on Whole Buildings and Facilities.

Current edition approved April 1, 2012. Published May 2012. Originally approved in 1995. Last previous edition approved in 2005 as E1701 – 95 (2005). DOI: 10.1520/E1701-95R12.

<sup>2</sup> Portions of this document are based on material originally prepared by the International Centre for Facilities (ICF) and © 1993 by ICF and Minister of Public Works and Government Services Canada. Their cooperation in the development of this standard is acknowledged.

### 2. Referenced Documents

#### 2.1 ASTM Standards:<sup>3</sup>

E631 Terminology of Building Constructions

E1334 Practice for Rating the Serviceability of a Building or Building-Related Facility (Withdrawn 2013)<sup>4</sup>

E1679 Practice for Setting the Requirements for the Serviceability of a Building or Building-Related Facility, and for Determining What Serviceability is Provided or Proposed

#### 2.2 ISO Documents:<sup>5</sup>

ISO 6240 International Standard, Performance Standards in Building—Contents and Presentation

ISO/DIS 7162 Draft International Standard, Performance Standards in Building—Contents and Format of Standards for Evaluation of Performance

ISO/DIS 7164 Draft International Standard, Performance Standards in Building—Definitions and Means of Expression for the Performance of a Whole Building

### 3. Terminology

#### 3.1 Definitions:

3.1.1 *facility, n*—a physical setting used to serve a specific purpose.

3.1.1.1 *Discussion*—A facility may be within a building, or a whole building, or a building with its site and surrounding environment; or it may be a construction that is not a building. The term encompasses both the physical object and its use.

3.1.2 *facility serviceability*—the capability of a facility to perform the function(s) for which it is designed, used, or required to be used.

3.1.2.1 *Discussion*—The scope of this performance is of the facility as a system, including its subsystems, components, and materials and their interactions, such as acoustical, hydrothermal, air purity, and economic; and of the relative importance of each performance requirement.

<sup>3</sup> For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For Annual Book of ASTM Standards volume information, refer to the standard's Document Summary page on the ASTM website.

<sup>4</sup> The last approved version of this historical standard is referenced on www.astm.org.

<sup>5</sup> Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, http://www.ansi.org.

**B.2. Manageability**

**Scale B.2.1. Reliability of external supply**


Facility Management Requirement Scale	Facility Rating Scale
<p><input type="checkbox"/> <b>9</b> ○ <b>FREQUENCY OF POWER OUTAGES:</b> Required levels are: electrical power out not more than once, for less than 3 hours, in a 3 year period. ○ <b>FREQUENCY OF LOSS OF LISTED SERVICES:</b> Required levels are: no loss of building services (see Table B2-A.) in a 12 month period, or backup services available. ○ <b>WORK DURATION DURING LOSS OF SERVICES:</b> Required levels are: staff able to work for up to one day with loss of two building services, e.g. windows open, sufficient daylight for almost all people, or enough standby power to continue essential operations. ○ <b>NEED FOR EVACUATION:</b> Required levels are: no evacuations.</p>	<p><input type="checkbox"/> <b>9</b> ○ <b>Electrical power supply:</b> There were no electrical power outages in the last 12 months. Electrical power (utility supply or on-site distribution) was out not more than once, for less than 3 hours, in the last 3 years. ○ <b>Building services (except power):</b> From the list in Table B2-A. there was no loss of service in the last 12 months, or, there are backup services for continued operations.</p>
<p><input type="checkbox"/> <b>7</b> ○ <b>FREQUENCY OF POWER OUTAGES:</b> Required levels are, for a 12 month period: electrical power out 1 or 2 times, each lasting less than half a day, or 3 times, each lasting less than 20 minutes. ○ <b>FREQUENCY OF LOSS OF LISTED SERVICES:</b> Required levels are, for a 12 month period: loss of building services (see Table B2-A.) 1 or 2 times, each lasting less than half a day, or 3 times, each lasting less than 30 minutes. ○ <b>WORK DURATION DURING LOSS OF SERVICES:</b> Required levels are, for a 12 month period: staff able to work for up to half a day with loss of two building services, e.g. sufficient daylight for most people, and windows open. ○ <b>NEED FOR EVACUATION:</b> Required levels are, for a 12 month period: no evacuations.</p>	<p><input type="checkbox"/> <b>7</b> ○ <b>Electrical power supply:</b> Electrical power (utility supply or on-site distribution) was out 1 or 2 times in the last 12 months, with each occasion less than half a day. ○ <b>Building services (except power):</b> From the list in Table B2-A. loss of service in the last 12 months was 1 or 2 outages, each less than half a day.</p>
<p><input type="checkbox"/> <b>5</b> ○ <b>FREQUENCY OF POWER OUTAGES:</b> Acceptable levels are, for a 12 month period: electrical power out 1 or 2 times, each lasting less than half a day, or 3 times, each lasting less than 30 minutes. ○ <b>FREQUENCY OF LOSS OF LISTED SERVICES:</b> Acceptable levels are, for a 12 month period: loss of building services (see Table B2-A.) 2 or 3 times, each lasting less than half a day, or 5 times, each lasting less than 30 minutes. ○ <b>WORK DURATION DURING LOSS OF SERVICES:</b> Acceptable levels are, for a 12 month period: staff able to work for up to half a day with loss of one building service, e.g. sufficient daylight for most people, but windows do not open. ○ <b>NEED FOR EVACUATION:</b> Acceptable levels are, for a 12 month period: no evacuations.</p>	<p><input type="checkbox"/> <b>5</b> ○ <b>Electrical power supply:</b> Electrical power (utility supply or on-site distribution) was out 2 or 3 times in the last 12 months, with one occasion more than half a day. ○ <b>Building services (except power):</b> From the list in Table B2-A. loss of service in the last 12 months was 2 or 3 outages, each less than half a day.</p>
<p><input type="checkbox"/> <b>4</b></p>	<p><input type="checkbox"/> <b>4</b></p>

Scale B.2.1. continued on next page

FIG. 1 Scale B.2.1 for Reliability of External Supply

B.2. Manageability

Scale B.2.1. Reliability of external supply (continued)



2

Exceptionally important.  Important.  Minor Importance.

Minimum **I** threshold level =  NA  NR  Zero  DP

**NOTES** Space for handwritten notes on Requirements or Ratings

FIG. 1 Scale B.2.1 for Reliability of External Supply (continued)

3.1.3 *office*—a place, such as a room, suite, or building, in which business, clerical, or professional activities are conducted.

3.1.4 For standard definitions of additional terms applicable to this classification, as well as those in 3.1.1 – 3.1.3, see Terminology E631.

**4. Significance and Use**

4.1 Each facility rating scale in this classification (see Figs. 1-8) provides a means to estimate the level of serviceability of a building or facility for one topic of serviceability, and to compare that level against the level of any other building or facility.

**B.2. Manageability**

**Scale B.2.2. Anticipated remaining service life**

Facility Management Requirement Scale		Facility Rating Scale
<p><input type="checkbox"/> <b>9</b> <b>○ REMAINING SERVICE LIFE OF BUILDING COMPONENTS AND SYSTEMS:</b> The acceptable level is a total of 26 or more points from Table B2-B. with remedial action budgeted or approved on remaining items.</p>	<b>9</b> <input type="checkbox"/>	<p><input type="checkbox"/> <b>9</b> <b>○ Major building components:</b> A total of 26 or more points are scored from Table B2-B., with remedial action budgeted and approved on the remaining items.</p>
<p><input type="checkbox"/> <b>7</b> <b>○ REMAINING SERVICE LIFE OF BUILDING COMPONENTS AND SYSTEMS:</b> The acceptable level is a total of 22 to 25 points from Table B2-B.</p>	<b>8</b> <input type="checkbox"/>	<p><input type="checkbox"/> <b>7</b> <b>○ Major building components:</b> A total of 22-25 points are scored from Table B2-B.</p>
<p><input type="checkbox"/> <b>5</b> <b>○ REMAINING SERVICE LIFE OF BUILDING COMPONENTS AND SYSTEMS:</b> The acceptable level is a total of 16 to 21 points from Table B2-B.</p>	<b>6</b> <input type="checkbox"/>	<p><input type="checkbox"/> <b>5</b> <b>○ Major building components:</b> A total of 16-21 points are scored from Table B2-B.</p>
<p><input type="checkbox"/> <b>3</b> <b>○ REMAINING SERVICE LIFE OF BUILDING COMPONENTS AND SYSTEMS:</b> The acceptable level is a total of 11 to 15 points from Table B2-B.</p>	<b>4</b> <input type="checkbox"/>	<p><input type="checkbox"/> <b>3</b> <b>○ Major building components:</b> A total of 11-15 points are scored from Table B2-B.</p>
<p><input type="checkbox"/> <b>1</b> <b>○ REMAINING SERVICE LIFE OF BUILDING COMPONENTS AND SYSTEMS:</b> The acceptable level is less than 10 points from Table B2-B.</p>	<b>2</b> <input type="checkbox"/>	<p><input type="checkbox"/> <b>1</b> <b>○ Major building components:</b> Less than 10 points are scored from Table B2-B.</p>

<input type="checkbox"/> Exceptionally important. <input type="checkbox"/> Important. <input type="checkbox"/> Minor Importance.	
Minimum Threshold level =	<input type="checkbox"/> NA <input type="checkbox"/> NR <input type="checkbox"/> Zero <input type="checkbox"/> DP

**NOTES** *Space for handwritten notes on Requirements or Ratings*

FIG. 2 Scale B.2.2 for Anticipated Remaining Service Life

4.2 This classification can be used for comparing how well different buildings or facilities meet a particular requirement for serviceability. It is applicable despite differences such as location, structure, mechanical systems, age, and building shape.

4.3 This classification can be used to estimate the amount of variance of serviceability from target or from requirement, for a single office facility, or within a group of office facilities.

4.4 This classification can be used to estimate the following:

4.4.1 Serviceability of an existing facility for uses other than its present use.

4.4.2 Serviceability (potential) of a facility that has been planned but not yet built.

4.4.3 Serviceability (potential) of a facility for which a remodeling has been planned.

4.5 Use of this classification does not result in building evaluation or diagnosis. Building evaluation or diagnosis generally requires a special expertise in building engineering or technology, and the use of instruments, tools, or measurements.

4.6 This classification applies only to facilities that are building constructions, or parts thereof. (While this classification may be useful in rating the serviceability of facilities that are not building constructions, such facilities are outside the scope of this classification.)

## B.2. Manageability

### Scale B.2.3. Ease of operation

Facility Management Requirement Scale	Facility Rating Scale
<p><b>9</b> <input type="checkbox"/> <b>STOREROOM FOR BUILDING OPERATIONS:</b> Require well located, well ventilated storeroom for supplies and parts for building operations.</p> <p><b>SPACE FOR BUILDING OPERATION PERSONNEL:</b> Require space for building operation personnel that is quiet, convenient, and well ventilated.</p>	<p><b>9</b> <input type="checkbox"/> <b>Storeroom:</b> A good size storeroom for supplies and small consumables for building operations is provided. It is well located, with good humidity control and air quality.</p> <p><b>Space for building operation personnel:</b> The operator’s office and locker space are well ventilated, and quiet, with a convenient location.</p> <p><b>Operating instructions for services and equipment:</b> Operating instructions are complete and up-to-date for instruction and verification.</p>
<p><b>7</b> <input type="checkbox"/> <b>STOREROOM FOR BUILDING OPERATIONS:</b> Require well located, well ventilated storeroom for supplies for building operations.</p> <p><b>SPACE FOR BUILDING OPERATION PERSONNEL:</b> Require space for building operation personnel that is quiet, convenient, and well ventilated.</p>	<p><b>7</b> <input type="checkbox"/> <b>Storeroom:</b> An adequate storeroom for supplies and small consumables for building operations is provided.</p> <p><b>Space for building operation personnel:</b> The operator’s office, adjacent to the mechanical room, is well ventilated, and quiet. There are lockers in the corridor.</p> <p><b>Operating instructions for services and equipment:</b> Operating manuals are up-to-date, and adequate for instruction and verification.</p>
<p><b>5</b> <input type="checkbox"/> <b>STOREROOM FOR BUILDING OPERATIONS:</b> Basic storeroom for building operations is needed.</p> <p><b>SPACE FOR BUILDING OPERATION PERSONNEL:</b> Size and condition of space for building operator’s office are not important.</p>	<p><b>5</b> <input type="checkbox"/> <b>Storeroom:</b> A barely adequate storeroom for supplies and small consumables for building operations is provided.</p> <p><b>Space for building operation personnel:</b> The operator’s office is just adequate, e.g. noisy, small, ventilation just adequate. There are lockers in the corridor.</p> <p><b>Operating instructions for services and equipment:</b> Operating manuals are just adequate, e.g. mostly up-to-date.</p>
<p><b>3</b> <input type="checkbox"/> <b>STOREROOM FOR BUILDING OPERATIONS:</b> No need for a building operations storeroom on-site.</p>	<p><b>3</b> <input type="checkbox"/> <b>Storeroom:</b> There is no building operations storeroom on-site, but shelving and storage lockers are provided in shops and mechanical spaces.</p> <p><b>Space for building operation personnel:</b> The operator’s area is inadequate, e.g. operator’s desk and lockers are in the mechanical room or passage.</p> <p><b>Operating instructions for services and equipment:</b> Operating manuals are poor, e.g. incomplete operating instructions.</p>
<p><b>1</b> <input type="checkbox"/> <b>STOREROOM FOR BUILDING OPERATIONS:</b> No need for a building operations storeroom on-site.</p>	<p><b>1</b> <input type="checkbox"/> <b>Storeroom:</b> There is no building operations storeroom on-site.</p> <p><b>Space for building operation personnel:</b> There is no allocated space for the operator.</p> <p><b>Operating instructions for services and equipment:</b> Manuals are mostly missing, or non-existent.</p>

Exceptionally important.  Important.  Minor Importance.

Minimum Threshold level =  NA  NR  Zero  DP

**NOTES** Space for handwritten notes on Requirements or Ratings

FIG. 3 Scale B.2.3 for Ease of Operation

**B.2. Manageability**

**Scale B.2.4. Ease of maintenance**

<b>Facility Management Requirement Scale</b>	
<p><b>9</b> <input type="checkbox"/> <b>REQUIRED LEVEL OF MAINTENANCE:</b> Building operations require that there be no delays due to failure of the ventilating, heating or cooling systems.</p> <p><b>STORAGE AND WORKSHOP:</b> An ample storeroom for tools and spares, and a well equipped workshop</p> <p><b>ACCESS TO CONTRACTORS AND PARTS:</b> Easy access to maintenance contractors, and same-day access to replacement parts/equipment.</p> <p><b>DATA FOR INVENTORY AND MAINTENANCE PROGRAM:</b> Complete data for an inventory and maintenance program.</p> <p><b>EASE OF MAINTENANCE AND REPAIRS OF SURFACES AND MATERIALS:</b> Surfaces and materials need to be very easy to maintain and repair.</p>	<p><b>9</b> <input type="checkbox"/></p>
<p><b>7</b> <input type="checkbox"/> <b>REQUIRED LEVEL OF MAINTENANCE:</b> Building operations require an above average level of maintenance.</p> <p><b>STORAGE AND WORKSHOP:</b> An adequate storeroom for tools and a minimum of spares, and a basic workshop.</p> <p><b>ACCESS TO CONTRACTORS AND PARTS:</b> Access to maintenance contractors, and same-day access to replacement parts/equipment.</p> <p><b>DATA FOR INVENTORY AND MAINTENANCE PROGRAM:</b> Adequate data for an inventory and maintenance program.</p> <p><b>EASE OF MAINTENANCE AND REPAIRS OF SURFACES AND MATERIALS:</b> Surfaces and materials that are easy to maintain and repair.</p>	<p><b>7</b> <input type="checkbox"/></p>
<p><b>5</b> <input type="checkbox"/> <b>REQUIRED LEVEL OF MAINTENANCE:</b> Building operations require an average level of maintenance.</p> <p><b>STORAGE AND WORKSHOP:</b> An adequate storeroom for tools and a minimum of spares, and a basic workshop.</p> <p><b>ACCESS TO CONTRACTORS AND PARTS:</b> Access to maintenance contractors, and access to replacement parts/equipment within 24 hours.</p> <p><b>DATA FOR INVENTORY AND MAINTENANCE PROGRAM:</b> Adequate data for an inventory and maintenance program.</p> <p><b>EASE OF MAINTENANCE AND REPAIRS OF SURFACES AND MATERIALS:</b> Surfaces and materials that are reasonably easy to maintain and repair.</p>	<p><b>5</b> <input type="checkbox"/></p>

<b>Facility Rating Scale</b>	
<p><b>9</b> <input type="checkbox"/> <b>Storeroom for maintenance:</b> The storeroom is generous for tools and spares, and conveniently located.</p> <p><b>Maintenance workshop:</b> A well-equipped workshop is on-site.</p> <p><b>Maintenance contractors:</b> To fix or replace key or major equipment in each of the main categories, there is a choice of competing maintenance contractors available locally to fix or replace key/major equipment.</p> <p><b>Availability of replacement parts:</b> Important replacement parts/equipment for all major units are available for same-day delivery or installation.</p> <p><b>Data for maintenance:</b> Complete data is available for inventory and maintenance program.</p> <p><b>Painting and repairs:</b> Surfaces and materials require little attention. Where required, they are very easy to paint or repair. Repairs require average skill.</p>	<p><b>9</b> <input type="checkbox"/></p>
<p><b>7</b> <input type="checkbox"/> <b>Storeroom for maintenance:</b> The storeroom is quite adequate for tools and minimum spares, and is conveniently located.</p> <p><b>Maintenance workshop:</b> A basic workshop is on-site.</p> <p><b>Maintenance contractors:</b> At least one firm of each type of maintenance contracting is locally available to fix or replace all categories of key or major equipment.</p> <p><b>Availability of replacement parts:</b> Important replacement parts/equipment for most key equipment are available for same-day delivery or installation.</p> <p><b>Data for maintenance:</b> Data is available for most parts of an inventory and maintenance program.</p> <p><b>Painting and repairs:</b> Surfaces and materials are easy to paint or repair. Repairs require average skill.</p>	<p><b>7</b> <input type="checkbox"/></p>
<p><b>5</b> <input type="checkbox"/> <b>Storeroom for maintenance:</b> The storeroom is adequate for tools and minimum spares, but not conveniently located.</p> <p><b>Maintenance workshop:</b> Workshop functions are carried out in a section of one of the mechanical rooms, or in part of a storeroom.</p> <p><b>Maintenance contractors:</b> At least one firm of each type of maintenance contracting is available either locally or within 24 hours to fix or replace key or major equipment.</p> <p><b>Availability of replacement parts:</b> Important replacement parts/equipment are available within 24 hours.</p> <p><b>Data for maintenance:</b> Basic data is available for the start of an inventory and maintenance program, but it is incomplete.</p> <p><b>Painting and repairs:</b> Surfaces and materials are reasonably easy to paint or repair. Repairs require average skill.</p>	<p><b>5</b> <input type="checkbox"/></p>

Scale B.2.4. continued on next page

FIG. 4 Scale B.2.4 Ease of Maintenance