

Designation: E1670 - 95a (Reapproved 2012)

An American National Standard

Standard Classification for Serviceability of an Office Facility for Management of Operations and Maintenance^{1,2}

This standard is issued under the fixed designation E1670; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope

- 1.1 This classification covers pairs of scales for classifying an aspect of the serviceability of an office facility, that is, the capability of an office facility to meet certain possible requirements for operations and maintenance.
- 1.2 Within that aspect of serviceability, each pair of scales, shown in Figs. 1-4, are for classifying one topic of serviceability. Each paragraph in an Occupant Requirement Scale (see Figs. 1-4) summarizes one level of serviceability on that topic, which occupants might require. The matching entry in the Facility Rating Scale (see Figs. 1-4) is a translation of the requirement into a description of certain features of a facility which, taken in combination, indicate that the facility is likely to meet that level of required serviceability.
- 1.3 The entries in the Facility Rating Scale (see Figs. 1-4) are indicative and not comprehensive. They are for quick scanning and rating a facility and not for evaluating or diagnosing it.
- 1.4 This classification can be used to estimate the level of serviceability of an existing facility. It can also be used to estimate the serviceability of a facility that has been planned but not yet built, such as one for which single-line drawings and outline specifications have been prepared.
- 1.5 This classification indicates what would cause a facility to be rated at a certain level of serviceability but does not state how to conduct a serviceability rating nor how to assign a serviceability score. That information is found in Practice E1334. The scales in this classification are complimentary to and compatible with Practice E1334. Each requires the other.

2. Referenced Documents

2.1 ASTM Standards:³

E631 Terminology of Building Constructions

E1334 Practice for Rating the Serviceability of a Building or Building-Related Facility (Withdrawn 2013)⁴

E1679 Practice for Setting the Requirements for the Serviceability of a Building or Building-Related Facility, and for Determining What Serviceability is Provided or Proposed 2.2 ISO Document:⁵

ISO 6240 International Standard, Performance Standards in Building—Contents and Presentation

3. Terminology

- 3.1 Definitions:
- 3.1.1 *facility*—a physical setting used to serve a specific purpose. **E631**
- 3.1.1.1 *Discussion* A facility may be within a building, a whole building, or a building with its site and surrounding environment; or it may be a construction that is not a building. The term encompasses both the physical object and its use.
- 3.1.2 facility serviceability—the capability of a facility to perform the function(s) for which it is designed, used, or required to be used.

 E631
- 3.1.2.1 *Discussion*—The scope of this performance is of the facility as a system, including its subsystems, components and materials and their interactions, such as acoustical, hydrothermal, air purity, and economic; and of the relative importance of each performance requirement.
- 3.1.3 *office*—a place, such as a room, suite, or building, in which business, clerical or professional activities are conducted. **E631**
- 3.1.4 For standard definitions of additional terms applicable to this classification, see Terminology E631.

¹ This classification is under the jurisdiction of ASTM Committee E06 on Performance of Buildings and is the direct responsibility of Subcommittee E06.25 on Whole Buildings and Facilities.

Current edition approved April 1, 2012. Published May 2012. Originally approved in 1995. Last previous edition approved in 2005E1670 – 95a (2005). DOI: 10.1520/E1670-95AR12.

² Portions of this document are based on material originally prepared by the International Centre for Facilities (ICF) and © 1993 by ICF and Minister of Public Works and Government Services Canada. Their cooperation in the development of this standard is acknowledged.

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

⁴The last approved version of this historical standard is referenced on www.astm.org.

⁵ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, http://www.ansi.org.

Scale B.3.1. Strategy and program for operations and maintenance

Facility Management Facility Rating Scale Requirement Scale O LEVEL OF MAINTENANCE AND O Strategy and program: Clearly documented O&M strategy to go **OPERATION:** Require buildings to be beyond simple maintenance to make the building(s) as comfortable maintained and operated at a high level, and flexible as is cost-effective in response to changing occupant helping occupants to be fully productive needs, e.g. cooling, ventilating and power. Explicit objectives and criteria are adopted for performance measurement. within their work environment. O TOLERANCE FOR OCCUPANT O Adequacy of budget: Budget is appropriate to carry out strategy LOSS OF PRODUCTIVITY: Any loss of and program. productivity due to breakdown of O <u>Human resources</u>: One maintenance person per 40,000 gross sq 8 building services cannot be tolerated. ft. About 25% of their time is spent on preventative maintenance. **O AVAILABILITY OF SUPPORT** O Availability of replacement parts: All parts are readily available **SERVICES:** Need highly organized and responsive support service available to maintenance contractors: Outside resources are readily available supplement in-house staff. and retained by firm contractual agreements. 7 O LEVEL OF MAINTENANCE AND O Strategy and program: Well documented O&M strategy to go **OPERATION:** Require buildings to be beyond simple maintenance to make the building(s) as comfortable operated and maintained at a higher and flexible within set-point ranges optimized for operating than average level. economy. Some objectives and criteria for performance O TOLERANCE FOR OCCUPANT measurement. LOSS OF PRODUCTIVITY: O Adequacy of budget: Budget is lean, but adequate to carry out Breakdowns must be rare, having strategy and program. 6 negligible effect on productivity, and be O Human resources: One maintenance person per 50,000 gross sq repaired in hours, not days. ft. About 25% of their time is spent on preventative maintenance. O AVAILABILITY OF SUPPORT O Availability of replacement parts: Critical and routine **SERVICES:** Require readily available maintenance parts are readily available on-site. outside support services to support inmaintenance contractors: With some exceptions, outside support house maintenance staff. services are under firm contract. O LEVEL OF MAINTENANCE AND **5** O Strategy and program: Brief written O&M strategy for **OPERATION:** Require buildings to be responding to changing occupant needs, e.g. cooling, ventilating operated and maintained in a manner and power. acceptable to the typical occupant in that O Adequacy of budget: Budget is tight, barely sufficient for locality. carrying out strategy and program. O TOLERANCE FOR OCCUPANT 4 O Human resources: One maintenance person per 75,000 gross sq LOSS OF PRODUCTIVITY: Breakdown ft. Preventative maintenance budget is less than 10% of total of building services can be tolerated if maintenance budget. rarely occurring, having minor effect on O Availability of replacement parts: Ample supply of critical productivity, causing only minimal repair parts is available. Non-critical parts are available through disruption, and requiring same-day alternative sources, usually within 24 hours. repair. O Maintenance contractors: In-hours staff only adequate for basic **O AVAILABILITY OF SUPPORT** maintenance and tasks requiring basic skills. Contractors provide **SERVICES:** Require support services to maintenance requiring specialized skills, and extra staff at peak be available. workload times.

Scale B.3.1. continued on next page

FIG. 1 Scale B.3.1 for Strategy and Program for Operations and Maintenance

Scale B.3.1. Strategy and program for operations and maintenance (continued)

	Facility Management Requirement Scale			Facility Rating Scale			
3	O LEVEL OF MAINTENANCE AND OPERATION: Require minimal operation and maintenance. O TOLERANCE FOR OCCUPANT LOSS OF PRODUCTIVITY: Even lengthy or disruptive breakdown need not be costly for the organization.	2	3	O Strategy and program: Strategy is to be seen to answer complaints, but actually do minimum to get by. O Adequacy of budget: Budget is not adequate for a basic but effective O&M program. O Human resources: One maintenance person per 100,000 or more gross sq ft. No separate budget for preventative maintenance. O Availability of replacement parts: Few repair parts available. Critical parts usually available within 48 hours. O Maintenance contractors: Repair of breakdowns is staff's primary responsibility. Some service companies are under contract.			
1	O LEVEL OF MAINTENANCE AND OPERATION: Very few occupants. O TOLERANCE FOR OCCUPANT LOSS OF PRODUCTIVITY: Little consequence if frequent or major disruptions.	Feh ://st: cu m	Stan	O Strategy and program: No O&M strategy or program for responding to occupant complaints. O Adequacy of budget: O&M budget is negligible and does not permit an organized or planned O&M program. O Human resources: No maintenance staff. O Availability of replacement parts: No repair parts available onsite. Critical parts usually available within 48 hours. O Maintenance contractors: No firm contracts exist with outside contractors.			
□ Exceptionally important. □ Important. □ Minor Importance.							
Min	imum <u>T</u> hreshold level =	NA 🗆	NR.	□ Zero □ DP			

NOTES Space for handwritten notes on Requirements or Ratings

FIG. 1 Scale B.3.1 for Strategy and Program for Operations and Maintenance (continued)

Scale B.3.2. Competences of in-house staff

Facility Management Requirement Scale				Facility Rating Scale
9 🗖	O REQUIRED LEVEL OF TRAINING AND SKILLS: Require training and skill levels suitable for highly cost-effective and highly reliable operations and maintenance.	8 D	9	O Training: Staff are very knowledgeable about current trade practices and changes in relevant codes, as indicated by productive relations with trade suppliers and by reference, when needed for the job, to latest editions of codes and interim updates. Own staff can cover a wider range of O&M tasks than available from outside contractors within one-hour driving distance. O Cross-trade qualifications: Staff able to rotate assignments between buildings and roles within a team without notice. O Electrical systems: Staff able to install home-run circuits for lighting and 110 and 3-phase power, open and close breakers, replace small breakers, isolate defective circuits in power panels using signal-generating device, trouble-shoot circuits using power analyzers. O Electronic systems and controls: Staff able to read ladder diagrams, use true RMS meters effectively, isolate and jump-start troubled circuits. O HVAC equipment: Staff able to take primary readings, e.g. static pressure, cfm levels, visually trouble-shoot drive components and operation, balance air quantities and adjust thermal set-points. Able to start and stop equipment using direct digital controls. Certification in refrigerant recycling. O Piping systems and repair: Staff able to isolate damaged sections, make temporary and permanent repairs, and run new sections to points of use. O Minor carpentry: Staff able to make small cabinets, cut various stock materials to size, make crates.
7	O REQUIRED LEVEL OF TRAINING AND SKILLS: Require training and skill levels to be adequate for cost-effective and reliable operations and maintenance.	6.6)CI 7 • A	O Training: Staff are sufficiently knowledgeable about current trade practices and code changes, which are adequate for most routine O&M tasks. Only rely on outside contractors for certain specialist or journeyman level tasks. O Cross-trade qualifications: At least one-half of staff able to rotate assignments between buildings and roles within a team with little notice, and less than one shift of refresher training. O Electrical systems: Staff able to check home-run circuits for lighting and 110 and 3-phase power, open and close breakers, replace small breakers, test for defective circuits in power panels using signal-generating device, and trouble-shoot simple circuits using power analyzers. O Electronic systems and controls: Staff able to read simple ladder diagrams, work with true RMS meters, and isolate troubled circuits. O HVAC equipment: Staff able to take primary readings, e.g. static pressure, cfm levels, visually trouble-shoot drive components and operation, and adjust thermal set-points. Able to start and stop equipment using direct digital controls. O Piping systems and repair: Staff able to isolate damaged sections, make temporary repairs, and run new sections to points of use. O Minor carpentry: Staff able to cut various stock materials to size, and make crates.

Scale B.3.2. continued on next page

FIG. 2 Scale B.3.2 for Competences of In-house Staff

Scale B.3.2. Competences of in-house staff (continued)

	Facility Management Requirement Scale			Facility Rating Scale
5 🗆	O REQUIRED LEVEL OF TRAINING AND SKILLS: Require training and skill levels of own staff to be adequate for basic operation. Outside contractors are required for repair and specialized maintenance.	4 🗇	5 	O Training: Staff know the limits of their skills and knowledge, which are adequate for simple and repetitive O&M tasks. Rely on outside contractors for journeyman level tasks. O Cross-trade qualifications: At least one-quarter of staff able to rotate assignments between buildings and roles within a team, if there is at least one shift of refresher training. O Electrical systems: Staff able to check home-run circuits for lighting and 110 and 3-phase power, open and close breakers, and test for defective circuits in power panels using signal-generating device. O Electronic systems and controls: Staff able to read simple ladder diagrams, and isolate troubled circuits. O HVAC equipment: Staff able to take primary readings, e.g. static pressure, cfm levels, visually trouble-shoot drive components and operation, and adjust thermal set-points. At least one person on each shift able to start and stop equipment using direct digital controls. O Piping systems and repair: Staff able to isolate damaged sections, and make temporary repairs. O Minor carpentry: Staff able to cut various stock materials to size, and make simple crates.
3 - ps://s	O REQUIRED LEVEL OF TRAINING AND SKILLS: Do not require skilled operation. Equipment is no more complicated than that in an apartment building. Rely on outside contractors for any complex O&M task.	Do	A s/sist	O <u>Training</u> : Staff have limited skills and knowledge, adequate only for simple and repetitive O&M tasks. Rely on outside contractors for all skilled and specialized tasks. O <u>Cross-trade qualifications</u> : Most staff not able to rotate assignments between buildings or roles within a team. O <u>Electrical systems</u> : Staff able to check only simple circuits for lighting and 110 power, and to open and close breakers. O <u>Electronic systems and controls</u> : Staff able to read simple ladder diagrams. O <u>HVAC equipment</u> : Staff able to take primary readings, e.g. static pressure, cfm levels, and adjust thermal set-points. O <u>Piping systems and repair</u> : Staff able to isolate damaged sections. O <u>Minor carpentry</u> : Staff able to cut various stock materials to size.
1	O REQUIRED LEVEL OF TRAINING AND SKILLS: Only require the low level of O&M capability typical of a resident in a single-family house in a large city.		1	 Training: Staff have no skills or knowledge for O&M tasks. Rely on outside contractors for O&M. Cross-trade qualifications: No capability. Electrical systems: Staff only able to open and close breakers. Electronic systems and controls: No capability. Hvac equipment: Staff able to adjust thermal set-points. Piping systems and repair: No capability. Minor carpentry: No capability.

□ Exceptionally important. □ Important. □ Minor Importance.

Minimum Threshold level = □ NA □ NR □ Zero □ DP

NOTES Space for handwritten notes on Requirements or Ratings

FIG. 2 Scale B.3.2 for Competences of In-house Staff (continued)

Scale B.3.3. Occupant satisfaction

8

Facility Management Requirement Scale

O LEVEL OF SATISFACTION WITH
 O&M OPERATIONS: Most occupants, e.g. 85%, should be satisfied or very satisfied with O&M operations. Problem situations should be rare, and occupants should give facility managers the benefit of the doubt.

O MANAGEMENT SUPPORT OF O&M OPERATIONS: O&M managers should have the full confidence of senior management, who should rarely if ever be involved with problems. Budgets should be fully adequate for the O&M strategy.

O OUTSOURCING FOR O&M
OPERATIONS: If work is by in-house staff, then outsourcing as a means of improving O&M performance should never be seriously considered. If outsourced, should have no reason to consider a change.

7 O LEVEL OF SATISFACTION WITH O&M OPERATIONS: At least two thirds of occupants should be satisfied or very satisfied with O&M operations. Problem situations should be uncommon, and when they do arise occupants should consider O&M staff to be effective.

O MANAGEMENT SUPPORT OF O&M OPERATIONS: Senior management should generally accept the O&M strategy, and provide budgets adequate for it.

O OUTSOURCING FOR O&M
OPERATIONS: If work is by in-house staff, then outsourcing as a means of replacing O&M staff should never be seriously considered. If outsourced, then change should not be seriously considered.

Facility Rating Scale

- 9 O Actions to achieve confidence of occupant staff: When failure occurs, e.g. power outage, occupant staff are informed immediately of the cause, action being taken, and given an accurate estimate of time until restoration of service. Staff ask few questions and acknowledge the high effectiveness of O&M staff.
 - O Actions to achieve confidence of senior management:
 Management understands cost and productivity consequences
 of O&M strategy, and strongly supports that strategy. Few
 complaints reach management. Overall indicator is that
 management strongly supports O&M staff and O&M budget,
 and provides funding to limits compatible with corporate
 context.
 - O <u>Response to surveys</u>: Surveys of occupants are conducted at least annually (separately or as part of a corporate TQM program) and responses regarding O&M of facilities are consistently favourable (higher than 85% satisfied or very satisfied).
 - O <u>Outsourcing</u>: Satisfaction with current operations is so high that alternative services, e.g. outsourcing, are not considered.
- O Actions to achieve confidence of occupant staff: When failure occurs, e.g. power outage, occupant staff are informed promptly of the cause, action being taken, and likely time until restoration of service. Most staff acknowledge the effectiveness of O&M staff.
 - O <u>Actions to achieve confidence of senior management:</u>
 Management is informed about cost and productivity
 consequences of O&M strategy, and supports that strategy.
 Overall indicator is that management supports O&M staff,
 generally supports O&M budget, and provides adequate
 funding within limits compatible with corporate context.
 - O <u>Response to surveys</u>: Surveys of occupants are conducted at least annually (separately or as part of a corporate TQM program) and responses are consistently favourable (at least two thirds are satisfied or very satisfied).
 - **O <u>Outsourcing</u>:** Satisfaction with current operations is good, so that alternative services, e.g. outsourcing, are not imposed.

Scale B.3.3. continued on next page

6

FIG. 3 Scale B.3.3 for Occupant Satisfaction