



SLOVENSKI STANDARD
SIST EN 50164-4:2008
01-december-2008

9`Ya Ybhj`nU`nUj Jhc`dfYX`glfYc`f!@7L!` ("XY.`NU HJ Y`nUdf]lfXJ`bY`Y`Ya YbhY

Lightning Protection Components (LPC) -- Part 4: Requirements for conductor fasteners

Blitzschutzbauteile -- Teil 4: Anforderungen an Halter

Composants de protection contre la foudre (CPF) -- Partie 4: Prescriptions pour les fixations de conducteur

(standards.iteh.ai)

Ta slovenski standard je istoveten z: EN 50164-4:2008

<https://standards.iteh.ai/catalog/standards/sist/85e312ce-2b61-4127-9e24-5fcb7dc413f/sist-en-50164-4-2008>

ICS:

91.120.40 Zæ ää, !^åÁ d^[[Lightning protection

SIST EN 50164-4:2008

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 50164-4:2008

<https://standards.iteh.ai/catalog/standards/sist/85e312ce-2b61-4127-9e24-5fbb7dc413f/sist-en-50164-4-2008>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 50164-4

August 2008

ICS 91.120.40

English version

**Lightning Protection Components (LPC) -
Part 4: Requirements for conductor fasteners**

Composants de protection
contre la foudre (CPF) -
Partie 4: Prescriptions
pour les fixations de conducteur

Blitzschutzbauteile -
Teil 4: Anforderungen an Halter

This European Standard was approved by CENELEC on 2008-04-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This European Standard was prepared by the Technical Committee CENELEC TC 81X, Lightning protection.

The text of the draft was submitted to the Unique Acceptance procedure and was approved by CENELEC as EN 50164-4 on 2008-04-01.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2009-04-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2011-04-01

EN 50164 is a family standard and consists of the following parts under the generic title “*Lightning Protection Components (LPC)*”:

- Part 1 Requirements for connection components
- Part 2 Requirements for conductors and earth electrodes
- Part 3 Requirements for isolating spark gaps
- Part 4 Requirements for conductor fasteners
- Part 5 ¹⁾ Requirements for earth electrode inspection housings and earth electrode seals
- Part 6 ¹⁾ Requirements for lightning strike counters
- Part 7 Requirements for earthing enhancing compounds

<https://standards.iteh.ai/catalog/standards/sist/85e312ce-2b61-4127-9e24-5fbb7dc413f/sist-en-50164-4-2008>

¹⁾ In preparation.

Contents

1	Scope	4
2	Normative references	4
3	Definitions	4
4	Classification	4
	4.1 According to the material composition.....	4
	4.2 According to fixing arrangement of the conductor within the fastener.....	4
	4.3 According to conductor clamping arrangement.....	5
5	Requirements	5
	5.1 General.....	5
	5.2 Environmental requirements.....	5
	5.3 Mechanical strength.....	5
	5.4 Installation instructions.....	5
	5.5 Marking.....	6
6	Tests	6
	6.1 General test conditions.....	6
	6.2 Test preparation.....	6
	6.3 Environmental influence test.....	7
	6.4 Resistance to mechanical effects.....	8
	6.5 Installation instructions.....	9
	6.6 Marking test.....	9
	6.7 Construction.....	9
7	Electromagnetic compatibility (EMC)	9
8	Structure and content of the test report	9
	8.1 Report identification.....	10
	8.2 Specimen description.....	10
	8.3 Characterization and condition of the test sample and/or test assembly.....	10
	8.4 Conductor.....	10
	8.5 Standards and references.....	10
	8.6 Test procedure.....	11
	8.7 Testing equipment, description.....	11
	8.8 Measuring instruments description.....	11
	8.9 Results and parameters recorded.....	11
	Annex A (normative) Environmental test for metallic fasteners	15
	Annex B (normative) Environmental test for non-metallic conductor fasteners - Resistance to ultraviolet light	16
	Annex C (normative) Flow chart of tests	17
	Bibliography	18
	Figure 1 – Basic arrangement of specimens.....	12
	Figure 2 – Basic arrangement of lateral load test.....	13
	Figure 3 – Typical arrangement for axial movement test.....	13
	Figure 4 – Impact test apparatus.....	14

1 Scope

This European standard specifies requirements and tests for:

- metallic and non-metallic conductor fasteners that are used in conjunction with the air termination system and down conductors;
- fixing of fasteners to the fabric / membrane / gravel roofing of structures is not covered by this standard due to the vast number and types used in modern day construction.

LPC may also be suitable for use in hazardous atmospheres. Regard should then be taken of the extra requirements necessary for the components to be installed in such conditions.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 60068-2-52	1996	Environmental testing – Part 2: Tests - Test Kb: Salt mist, cyclic (sodium chloride solution) (IEC 60068-2-52:1996)
EN 62305-3	2006	Protection against lightning – Part 3: Physical damage to structures and life hazard (IEC 62305-3:2006, mod.)
EN ISO 4892-2	2006	Plastics – Methods of exposure to laboratory light sources – Part 2: Xenon-arc lamps (ISO 4892-2:2006)
EN ISO 6988	1994	Metallic and other non-organic coatings – Sulfur dioxide test with general condensation of moisture (ISO 6988:1985)
ISO 4892-4	2004	Plastics – Methods of Exposure to laboratory light sources – Part 4: Open-flame carbon-arc lamps
ISO 6957	1988	Copper alloys – Ammonia test for stress corrosion resistance

3 Definitions

For the purpose of this European Standard, the following definitions apply.

3.1

conductor fastener

a metallic, non-metallic or composite component designed to retain and support the air termination and down conductor, installed at intervals along the length of the conductors

NOTE The conductor fastener may be provided with a means of attachment to a mounting surface.

4 Classification

Conductor fasteners are classified:

4.1 According to the material composition

4.1.1 Metallic (e.g. hot dip galvanized steel, copper, aluminium, stainless steel)

4.1.2 Non-metallic (e.g. PVC, plastics)

4.1.3 Composite (combination of metal and plastic)

4.2 According to fixing arrangement of the conductor within the fastener

4.2.1 With screws

4.2.2 Without screws (e.g. clips, springs)

4.3 According to conductor clamping arrangement

4.3.1 Fasteners that are designed to clamp the conductor

4.3.2 Fasteners that are designed to allow axial movement of the conductor

5 Requirements

5.1 General

The conductor fastener shall carry out its function of clamping the conductor in an acceptable and safe manner when subjected to mechanical influences, lightning discharge stress and environmental influences.

Conductor fasteners shall be so designed and constructed that safe handling is ensured and that retention and support for the conductor is provided and that in normal use their performance is reliable and without danger to persons and the surrounding.

The material of the conductor fastener shall be compatible with the conductor it is fastening, and the surface material it is fastening on and comply with the tests given in Clause 6.

5.2 Environmental requirements

5.2.1 Corrosion resistance

Metallic or composite fasteners shall withstand corrosion effects.

Compliance is checked following the manufacturer's declaration for the classification of the fastener in accordance with Clause 4 and by test according to 6.3.1 and 6.3.3.

5.2.2 UV resistance

Non-metallic and composite fasteners shall withstand UV effects.

Compliance is checked following the manufacturer's declaration for the classification of the fastener in accordance with Clause 4 and by test according to 6.3.2 and 6.3.3.

5.3 Mechanical strength

5.3.1 Perpendicular and axial loads

The design of the conductor fastener shall be such that it carries the perpendicular loads caused by the weight of the conductor, snow, ice and wind and axial loads caused by the thermal expansion / contraction of the conductor and its weight.

Compliance is checked following the manufacturer's declaration for the classification of the fastener in accordance with Clause 4 and by test according to 6.4.1 and 6.4.2.

5.3.2 Impact tests

Conductor fasteners shall be so designed and constructed to withstand impact stresses caused accidentally.

Compliance is checked by test according to 6.4.3.

5.4 Installation instructions

The manufacturer or supplier of the conductor fastener shall provide adequate information in his literature to ensure that the installer can select and install the component in a suitable and safe manner, in accordance with EN 62305-3.

Compliance is checked by inspection in accordance with 6.5.

5.5 Marking

Each conductor fastener shall be marked with:

- the manufacturer's or responsible vendor's name or logo or trademark;
- the product identification or type.

Where it is not possible to make these marks directly onto the product, they shall be on the smallest supplied packaging.

NOTE Marking may be applied for example by moulding, pressing, engraving, printing adhesive labels or water slide transfers.

Compliance is checked in accordance with 6.6.

6 Tests

6.1 General test conditions

Tests according to this standard are type tests. These tests are of such a nature that, after they have been performed, they need not be repeated unless changes are made to the materials, design or type of manufacturing process, which might change the performance characteristics.

The standard cannot cover all possible types of fasteners and the way of fixing them on various surfaces of different materials. When required, for these applications, agreement should be obtained between the test engineer and manufacturer on the specific testing regime.

Unless otherwise specified, tests are carried out with the specimens assembled and installed as in normal use according to the manufacturer's or supplier's instructions, with the recommended conductor materials, sizes and the tightening torques.

The tests shall be carried out in the sequence given after environmental tests of the specimen in accordance with 6.3.

Unless otherwise specified, twelve metallic or eighteen composite / non metallic specimens are subjected to the tests and the requirements are satisfied if all the tests are met.

If only one of the specimens does not satisfy a test due to a manufacturing fault, that test and any preceding one which may have influenced the results of the test shall be repeated and also the tests which follow shall be made in the same required sequence on another full set of samples, all of which shall comply with the requirements.

Tests for non-metallic fasteners shall not commence earlier than 168 h from the time of their manufacturing.

Unless otherwise specified, the tests shall be carried out in a room whose ambient temperature ranges between +15 °C and +40 °C.

Unless otherwise specified, the tests shall be carried out in a room whose relative humidity ranges between 25 % and 75 %.

A torque meter shall be used for all tightening operations. It shall have a resolution at least of 0,5 Nm and an accuracy not above ± 4 %.

The applicable tolerance for any applied mechanical load shall be within ± 5 %.

NOTE The applicant, when submitting the first set of samples may also submit an additional set of samples that may be necessary should one sample fail. The test house shall then, without further request, test the additional set of samples, and shall only reject if a further failure occurs. If the additional set of samples is not submitted at the same time, a failure of one sample shall entail rejection.

6.2 Test preparation

6.2.1 Arrangement of the specimen

If not otherwise specified by the manufacturer the conductors and specimens shall be cleaned by using a suitable degreasing agent followed by cleaning in demineralised water and drying. They shall then be assembled in accordance with the manufacturer's installation instructions, e.g. with the recommended conductors and the tightening torques.

The tightening torque should be applied in a steady and uniform manner.

Any fastener accommodating conductors with differences in size equal to or less than 2 mm shall be tested on the minimum conductor size recommended. If the range is greater than 2 mm it shall be tested on the minimum and maximum of conductor size recommended.

If a fastener as recommended by the manufacturer's installation instructions, is classified in more than one classification as per Clause 4, then it shall be tested for each one of those.

When by the manufacturer's installation instructions a fastener is used for fastening conductors made of aluminium and/or copper, tests shall be carried out using aluminium and/or copper conductors selected from Table 2 of EN 50164-2.

For testing purposes all fasteners shall be mounted rigidly as shown in Figures 1, 2, 3 and 4. It is permitted to test more than one arrangement of the specimen in series simultaneously.

6.3 Environmental influence test

In order that a fastener meets the requirements of this standard, environmental tests shall be carried out as per Annex A and/or Annex B. The selection of the test to be performed is defined in 6.3.1, 6.3.2 or 6.3.3 and depends on the fasteners as classified in Clause 4, see flow chart in Annex C.

6.3.1 Metallic

Two sets, each one consisting of three arrangements, shall be assembled and mounted rigidly on an insulating plate (e.g. brick, Teflon) as shown in Figure 1 in accordance with the manufacturer's installation instructions, e.g. with the recommended conductors and the tightening torques for screwed fastening fasteners.

The arrangements of specimens shall be subjected to environmental influence tests consisting of a salt mist test as specified in A.1 followed by a humid sulphurous atmosphere test as specified in A.2. An additional test by an ammonia atmosphere shall be carried out for fasteners having parts made of copper alloy with a copper content less than 80 % as specified in A.3.

The specimens are deemed to have passed the tests if the base metal does not exhibit any corrosive deterioration visible to normal or corrected vision.

NOTE White rust is not considered as corrosive deterioration.

6.3.2 Non-metallic

Three sets, each one consisting of three arrangements, shall be assembled and mounted rigidly on an insulating plate (e.g. brick, Teflon) as shown in Figure 1 in accordance with the manufacturer's installation instructions, e.g. with the recommended conductors and the tightening torques for screwed fastening fasteners.

The arrangements of specimens shall be subjected to an environmental test consisting of an ultra violet light test as specified in Annex B.

The specimens are deemed to have passed this part of the test if there are no signs of disintegration and no cracks visible to normal or corrected vision.

NOTE Ensure that the surface of the mounting plate is suitable to resist UV radiation.

6.3.3 Composite

Three sets, each one consisting of three arrangements shall be assembled and mounted on a rigid surface (e.g., brick, Teflon etc) as shown in Figure 1 in accordance with the manufacturer's installation instructions, e.g. with the recommended conductors and the tightening torques for screwed fastening fasteners.

The arrangement of specimens shall be subjected to the environmental tests in the following sequence:

- test as per 6.3.2 and
- test as per 6.3.1.

The specimens are deemed to have passed this part of the test if the base metal of its metal parts does not exhibit any corrosive deterioration and if its plastic parts show no sign of disintegration and no cracks visible to normal or corrected vision.

NOTE 1 Ensure that the surface of the mounting plate is suitable to resist UV radiation.

NOTE 2 White rust is not considered as corrosive deterioration.

6.4 Resistance to mechanical effects

6.4.1 Lateral load test

After the test of 6.3 a first set of three arrangements of specimens are subjected to a load test of 200 N applied in the mid distance between the fasteners as illustrated in Figure 2.

For metallic fasteners, the full test load is applied for period of 5 min to 6 min and for composite and non-metallic fasteners, the full test load is applied for a minimum period of 60 min to 61 min.

All tests are carried out at the temperature of -10 °C ($\pm 1\text{ °C}$) and repeated at the temperature of $+40\text{ °C}$ ($\pm 4\text{ °C}$).

The specimens are deemed to have passed the tests provided the fasteners remain intact and the conductor is still located within the fasteners.

6.4.2 Axial load test

This test is applied only for fasteners classified according to 4.3.1.

After the test of 6.3 the second set of three arrangements are subjected to a load test of 50 N applied as shown in Figure 3.

For metallic fasteners, the full test load is applied for period of 5 min to 6 min and for composite and non-metallic fasteners, the full test load is applied for a minimum period of 60 min to 61 min.

All tests are carried out at the temperature of -10 °C ($\pm 1\text{ °C}$) and repeated at the temperature of $+40\text{ °C}$ ($\pm 4\text{ °C}$).

<https://standards.iteh.ai/catalog/standards/sist/85e312ce-2b61-4127-9e24-5fcb7dc413f/sist-en-50164-4-2008>

The specimens are deemed to have passed the tests provided the fasteners remain intact and the displacement of the conductor with the respect to the fasteners is not more than 3 mm.

6.4.3 Impact test

This test is carried out on non-metallic and composite fasteners.

After the test of 6.3 the third set of three arrangements are subjected to an impact test.

Each arrangement of specimens is mounted on an impact test apparatus according to Clause 4 of EN 60068-2-75:1997 as shown in Figure 4. The impact test apparatus is mounted on a solid wall or structure providing sufficient support.

The arrangement of specimens is placed in a cabinet at a temperature -5 °C . After 2 h, the arrangement is, in turn, removed from the cabinet and immediately placed in position in the impact test apparatus.

At $12\text{ s} \pm 2\text{ s}$ after the removal of the arrangement from the cabinet the hammer is allowed to fall (2 J, 0,5 kg, 400 mm) so that three impacts are applied as far as possible perpendicular to the length of the arrangement.

The first impact should be to the left fastener the second to the other fastener and the third to the middle length of the arrangement.

Instead of placing the arrangements in a cabinet and applying the impact at $12\text{ s} \pm 2\text{ s}$ after the removal of the sample from the cabinet, it is allowed to apply the impact in a climatic chamber at a temperature of -5 °C ($\pm 1\text{ °C}$) on samples placed at this temperature at least for 2 h. Compliance in the climatic chamber is sufficient.

After the test the specimens shall show no cracks or similar damage visible to normal or corrected vision without magnification and the conductor is still located within the fasteners.

6.5 Installation instructions

The manufacturer or responsible vendor shall provide in his literature:

- the classifications according to Clause 4,
- the maximum and minimum conductor diameter,
- materials of conductors to be used,
- the type of mounting surface to be fixed,
- the recommended method of assembly, installation and fixing to the mounting surface,
- the lateral load,
- the axial movement load.

Compliance is checked by inspection.

6.6 Marking test

Marking on the product shall be durable and easily legible.

Compliance is checked by inspection and by rubbing the marking by hand for 15 s with a piece of cloth soaked with water and again for 15 s with a piece of cloth soaked with white spirit.

Marking made by moulding, pressing or engraving is not subjected to this test.

The specimen is deemed to have passed the test if the marking remains legible.

NOTE Marking may be applied, for example, by moulding, pressing, engraving, printing, adhesive labels, etc.

6.7 Construction

The surface of the fastener shall be free from burrs from cutting process, flash, moulding joint deformation and similar inconsistencies which are likely to damage the conductors or inflict injury to the installer or user.

Compliance is checked by visual and manual inspection.

7 Electromagnetic compatibility (EMC)

Products covered by this standard are, in normal use, passive in respect of electromagnetic influences (emission and immunity).

8 Structure and content of the test report

The purpose of this instruction is to provide general requirements for laboratory test reports. This document is intended to promote clear, complete reporting procedures for laboratories submitting test reports.

The results of each test carried out by the laboratory shall be reported accurately, clearly, unambiguously and objectively, in accordance with any instructions in the test methods. The results shall be reported in a test report and shall include all the information necessary for the interpretation of the test results and all information required by the method used.

Particular care and attention shall be paid to the arrangement of the report, especially with regard to presentation of the test data and ease of assimilation by the reader. The format shall be carefully and specifically designed for each type of test carried out, but the headings shall be standardized as indicated herein.

The structure of each report shall include at least information according to 8.1 to 8.9.