



Designation: D5139 – 12

Standard Specification for Sample Preparation for Qualification Testing of Coatings to be Used in Nuclear Power Plants¹

This standard is issued under the fixed designation D5139; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This specification defines the size, composition, surface preparation, and coating application variables for preparing samples for evaluating coatings and linings over various substrates.

1.2 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:²

- [A36/A36M Specification for Carbon Structural Steel](#)
- [C33/C33M Specification for Concrete Aggregates](#)
- [C150/C150M Specification for Portland Cement](#)
- [C192/C192M Practice for Making and Curing Concrete Test Specimens in the Laboratory](#)
- [C260 Specification for Air-Entraining Admixtures for Concrete](#)
- [C494/C494M Specification for Chemical Admixtures for Concrete](#)
- [C618 Specification for Coal Fly Ash and Raw or Calcined Natural Pozzolan for Use in Concrete](#)
- [D3912 Test Method for Chemical Resistance of Coatings and Linings for Use in Nuclear Power Plants](#)
- [D4258 Practice for Surface Cleaning Concrete for Coating](#)
- [D4259 Practice for Abrading Concrete](#)

¹ This specification is under the jurisdiction of ASTM Committee D33 on Protective Coating and Lining Work for Power Generation Facilities and is the direct responsibility of Subcommittee D33.02 on Service and Material Parameters.

Current edition approved July 1, 2012. Published August 2012. Originally approved in 1990. Last previous edition approved in 2010 as D5139 – 10. DOI: 10.1520/D5139-12.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

- [D4260 Practice for Liquid and Gelled Acid Etching of Concrete](#)
- [D4538 Terminology Relating to Protective Coating and Lining Work for Power Generation Facilities](#)
- [D4541 Test Method for Pull-Off Strength of Coatings Using Portable Adhesion Testers](#)
- [D7234 Test Method for Pull-Off Adhesion Strength of Coatings on Concrete Using Portable Pull-Off Adhesion Testers](#)

2.2 American Concrete Institute:³

- [ACI 308 Guide to Curing Concrete](#)
- [ACI Cement and Concrete Terminology](#)

2.3 American National Standards Institute (ANSI):⁴

- [ANSI N5.12–1974 Protective Coatings \(Paints\) for the Nuclear Industry, paragraph 7.4.3](#)

3. Terminology

3.1 *Definitions*—Definitions for use with this standard are shown in Terminology D4538 or other applicable standards.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *bughole (surface air void), n*—a small regular or irregular cavity, usually not exceeding 1.5 mm in diameter, resulting from entrapment of air bubbles in the surface of formed concrete during placement and consolidation (ACI Cement and Concrete Terminology).

3.2.2 *curing compound, n*—a liquid that can be applied as a coating to the surface of newly placed concrete to retard the loss of water and, in the case of pigmented compounds, to reflect heat so as to provide an opportunity for the concrete to develop its properties in a favorable temperature and moisture environment (ACI Cement and Concrete Terminology).

4. Significance and Use

4.1 This specification provides uniform requirements for the preparation of test samples used for testing of coatings and linings to be used in nuclear power plants.

³ Available from American Concrete Institute (ACI), P.O. Box 9094, Farmington Hills, MI 48333-9094, <http://www.concrete.org>.

⁴ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.