



Designation: E482 – 11^{ε1}

Standard Guide for Application of Neutron Transport Methods for Reactor Vessel Surveillance, E706 (IID)¹

This standard is issued under the fixed designation E482; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reappraisal. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reappraisal.

^{ε1} NOTE—Missing references to Practice E693 were added to 3.2.1.6, 3.2.1.7 and 3.4.8.3 editorially in November 2012.

1. Scope

1.1 *Need for Neutronics Calculations*—An accurate calculation of the neutron fluence and fluence rate at several locations is essential for the analysis of integral dosimetry measurements and for predicting irradiation damage exposure parameter values in the pressure vessel. Exposure parameter values may be obtained directly from calculations or indirectly from calculations that are adjusted with dosimetry measurements; Guide E944 and Practice E853 define appropriate computational procedures.

1.2 *Methodology*—Neutronics calculations for application to reactor vessel surveillance encompass three essential areas: (1) validation of methods by comparison of calculations with dosimetry measurements in a benchmark experiment, (2) determination of the neutron source distribution in the reactor core, and (3) calculation of neutron fluence rate at the surveillance position and in the pressure vessel.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory requirements prior to use.*

2. Referenced Documents

2.1 ASTM Standards:²

E693 Practice for Characterizing Neutron Exposures in Iron and Low Alloy Steels in Terms of Displacements Per Atom (DPA), E 706(ID)

E706 Master Matrix for Light-Water Reactor Pressure Vessel

¹ This guide is under the jurisdiction of ASTM Committee E10 on Nuclear Technology and Applications and is the direct responsibility of Subcommittee E10.05 on Nuclear Radiation Metrology.

Current edition approved June 1, 2011. Published June 2011. Originally approved in 1976. Last previous edition approved in 2007 as E482 – 07 DOI: 10.1520/E0482-11E01.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

Surveillance Standards, E 706(0) (Withdrawn 2011)³
E844 Guide for Sensor Set Design and Irradiation for Reactor Surveillance, E 706 (IIC)
E853 Practice for Analysis and Interpretation of Light-Water Reactor Surveillance Results, E706(IA)
E944 Guide for Application of Neutron Spectrum Adjustment Methods in Reactor Surveillance, E 706 (IIA)
E1018 Guide for Application of ASTM Evaluated Cross Section Data File, Matrix E706 (IIB)
E2006 Guide for Benchmark Testing of Light Water Reactor Calculations

2.2 Nuclear Regulatory Documents:⁴

NUREG/CR-1861 LWR Pressure Vessel Surveillance Dosimetry Improvement Program: PCA Experiments and Blind Test

NUREG/CR-3318 LWR Pressure Vessel Surveillance Dosimetry Improvement Program: PCA Experiments, Blind Test, and Physics-Dosimetry Support for the PSF Experiments

NUREG/CR-3319 LWR Pressure Vessel Surveillance Dosimetry Improvement Program: LWR Power Reactor Surveillance Physics-Dosimetry Data Base Compendium

NUREG/CR-5049 Pressure Vessel Fluence Analysis and Neutron Dosimetry

3. Significance and Use

3.1 General:

3.1.1 The methodology recommended in this guide specifies criteria for validating computational methods and outlines procedures applicable to pressure vessel related neutronics calculations for test and power reactors. The material presented herein is useful for validating computational methodology and for performing neutronics calculations that accompany reactor vessel surveillance dosimetry measurements (see Master Matrix E706 and Practice E853). Briefly, the overall methodology involves: (1) methods-validation calculations based on at least

³ The last approved version of this historical standard is referenced on www.astm.org.

⁴ Available from Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

one well-documented benchmark problem, and (2) neutronics calculations for the facility of interest. The neutronics calculations of the facility of interest and of the benchmark problem should be performed consistently, with important modeling parameters kept the same or as similar as is feasible. In particular, the same energy group structure and common broad-group microscopic cross sections should be used for both problems. The neutronics calculations involve two tasks: (1) determination of the neutron source distribution in the reactor core by utilizing diffusion theory (or transport theory) calculations in conjunction with reactor power distribution measurements, and (2) performance of a fixed fission rate neutron source (fixed-source) transport theory calculation to determine the neutron fluence rate distribution in the reactor core, through the internals and in the pressure vessel. Some neutronics modeling details for the benchmark, test reactor, or the power reactor calculation will differ; therefore, the procedures described herein are general and apply to each case. (See NUREG/CR-5049, NUREG/CR-1861, NUREG/CR-3318, and NUREG/CR-3319.)

3.1.2 It is expected that transport calculations will be performed whenever pressure vessel surveillance dosimetry data become available and that quantitative comparisons will be performed as prescribed by 3.2.2. All dosimetry data accumulated that are applicable to a particular facility should be included in the comparisons.

3.2 *Validation*—Prior to performing transport calculations for a particular facility, the computational methods must be validated by comparing results with measurements made on a benchmark experiment. Criteria for establishing a benchmark experiment for the purpose of validating neutronics methodology should include those set forth in Guides E944 and E2006 as well as those prescribed in 3.2.1. A discussion of the limiting accuracy of benchmark validation discrete ordinate radiation transport procedures for the LWR surveillance program is given in Reference (1). Reference (2) provides details on the benchmark validation for a Monte Carlo radiation transport code.

3.2.1 *Requirements for Benchmarks*—In order for a particular experiment to qualify as a calculational benchmark, the following criteria are recommended:

3.2.1.1 Sufficient information must be available to accurately determine the neutron source distribution in the reactor core,

3.2.1.2 Measurements must be reported in at least two ex-core locations, well separated by steel or coolant,

3.2.1.3 Uncertainty estimates should be reported for dosimetry measurements and calculated fluences including calculated exposure parameters and calculated dosimetry activities,

3.2.1.4 Quantitative criteria, consistent with those specified in the methods validation 3.2.2, must be published and demonstrated to be achievable,

3.2.1.5 Differences between measurements and calculations should be consistent with the uncertainty estimates in 3.2.1.3,

3.2.1.6 Results for exposure parameter values of neutron fluence greater than 1 MeV and 0.1 MeV [$\phi(E > 1 \text{ MeV}$ and 0.1 MeV)] and of displacements per atom (dpa) in iron should be reported consistent with Practices E693 and E853.

3.2.1.7 Reaction rates (preferably established relative to neutron fluence standards) must be reported for $^{237}\text{Np}(n,f)$ or $^{238}\text{U}(n,f)$, and $^{58}\text{Ni}(n,p)$ or $^{54}\text{Fe}(n,p)$; additional reactions that aid in spectral characterization, such as provided by Cu, Ti, and Co-Al, should also be included in the benchmark measurements. The $^{237}\text{Np}(n,f)$ reaction is particularly important because it is sensitive to the same neutron energy region as the iron dpa. Practices E693 and E853 and Guides E844 and E944 discuss this criterion.

3.2.2 *Methodology Validation*—It is essential that the neutronics methodology employed for predicting neutron fluence in a reactor pressure vessel be validated by accurately predicting appropriate benchmark dosimetry results. In addition, the following documentation should be submitted: (1) convergence study results, and (2) estimates of variances and covariances for fluence rates and reaction rates arising from uncertainties in both the source and geometric modeling. For Monte Carlo calculations, the convergence study results should also include (3) an analysis of the figure-of-merit (FOM) as a function of particles history, and if applicable, (4) the description of the technique utilized to generate the weight window parameters.

3.2.2.1 For example, model specifications for discrete-ordinates method on which convergence studies should be performed include: (1) neutron cross-sections or energy group structure, (2) spatial mesh, and (3) angular quadrature. One-dimensional calculations may be performed to check the adequacy of group structure and spatial mesh. Two-dimensional calculations should be employed to check the adequacy of the angular quadrature. A P_3 cross section expansion is recommended along with a S_8 minimum quadrature.

3.2.2.2 Uncertainties that are propagated from known uncertainties in nuclear data need to be addressed in the analysis. The uncertainty analysis for discrete ordinates codes may be performed with sensitivity analysis as discussed in References (3, 4). In Monte Carlo analysis the uncertainties can be treated by a perturbation analysis as discussed in Reference (5). Appropriate computer programs and covariance data are available and sensitivity data may be obtained as an intermediate step in determining uncertainty estimates.⁵

3.2.2.3 Effects of known uncertainties in geometry and source distribution should be evaluated based on the following test cases: (1) reference calculation with a time-averaged source distribution and with best estimates of the core, and pressure vessel locations, (2) reference case geometry with maximum and minimum expected deviations in the source distribution, and (3) reference case source distribution with maximum expected spatial perturbations of the core, pressure vessel, and other pertinent locations.

3.2.2.4 Measured and calculated integral parameters should be compared for all test cases. It is expected that larger uncertainties are associated with geometry and neutron source specifications than with parameters included in the convergence study. Problems associated with space, energy, and angle discretizations can be identified and corrected. Uncertainties associated with geometry specifications are inherent in the

⁵ Much of the nuclear covariance and sensitivity data have been incorporated into a benchmark database employed with the LEPRICON Code system. See Ref (6).