



Edition 1.0 2021-03

INTERNATIONAL STANDARD

AMENDMENT 1

Information technology – Automated infrastructure management (AIM) systems – Requirements, data exchange and applications (standards.iteh.ai)

ISO/IEC 18598:2016/Amd 1:2021 https://standards.iteh.ai/catalog/standards/sist/46d899a0-8075-4351-b4c0-dd46de7c658e/iso-iec-18598-2016-amd-1-2021





THIS PUBLICATION IS COPYRIGHT PROTECTED Copyright © 2021 ISO/IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about ISO/IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Tel.: +41 22 919 02 11

IEC Central Office 3, rue de Varembé CH-1211 Geneva 20 Switzerland

info@iec.ch www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

ISO/IEC 18598:2016/Amd 1:2021

https://standards.iteh.ai/catalog/standards/sist/46d899a0-8075-4351-b4c0-dd46de7c658e/iso-iec-18598-2016-amd-1-2021



ISO/IEC 18598

Edition 1.0 2021-03

INTERNATIONAL STANDARD

AMENDMENT 1

Information technology – Automated infrastructure management (AIM) systems – Requirements, data exchange and applications

ISO/IEC 18598:2016/Amd 1:2021 https://standards.iteh.ai/catalog/standards/sist/46d899a0-8075-4351-b4c0-dd46de7c658e/iso-iec-18598-2016-amd-1-2021

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 35,200 ISBN 978-2-8322-9479-6

Warning! Make sure that you obtained this publication from an authorized distributor.

INFORMATION TECHNOLOGY – AUTOMATED INFRASTRUCTURE MANAGEMENT (AIM) SYSTEMS – REQUIREMENTS, DATA EXCHANGE AND APPLICATIONS

AMENDMENT 1

FOREWORD

- 1) ISO (the International Organization for Standardization) and IEC (the International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards through technical committees established by the respective organization to deal with particular fields of technical activity. ISO and IEC technical committees collaborate in fields of mutual interest. Other international organizations, governmental and non-governmental, in liaison with ISO and IEC, also take part in the work.
- 2) The formal decisions or agreements of IEC and ISO on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC and ISO National bodies.
- 3) IEC and ISO documents have the form of recommendations for international use and are accepted by IEC and ISO National bodies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC and ISO documents is accurate, IEC and ISO cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC and ISO National bodies undertake to apply IEC and ISO documents transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC and ISO document and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC and ISO do not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC and ISO marks of conformity. IEC and ISO are not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this document.
- 7) No liability shall attach to IEC and ISO or their directors, employees, servants or agents including individual experts and members of its technical committees and IEC and ISO National bodies for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses ansing out of the publication, use of, or reliance upon, this ISO/IEC document or any other IEC and ISO documents.dd46de7c658e/iso-iec-18598-2016-amd-1-2021
- 8) Attention is drawn to the Normative references cited in this document. Use of the referenced publications is indispensable for the correct application of this document.
- 9) Attention is drawn to the possibility that some of the elements of this ISO/IEC document may be the subject of patent rights. IEC and ISO shall not be held responsible for identifying any or all such patent rights.

Amendment 1 to ISO/IEC 18598 has been prepared by subcommittee SC 25: Interconnection of information technology equipment, of ISO/IEC joint technical committee 1: Information technology.

The text of this Amendment is based on the following documents:

FDIS	Report on voting
JTC1-SC25/2996/FDIS	JTC1-SC25/3011/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Amendment is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1, available at www.iec.ch/members experts/refdocs.

INTRODUCTION TO THE AMENDMENT

This amendment adds the following content to ISO/IEC 18598:2016:

- · updates to the data exchange model;
- an Annex E which addresses the optional application of AIM systems to cabling supporting remote powering in accordance with IEEE 802.3bt-2018;
- an Annex F which addresses formatting of data from field test equipment.

1 Scope

Add the following new paragraph after bullet d).

For AIM systems providing support functionality for remote powering as an option, this International Standard addresses additional administration requirements and recommendations.

iTeh STANDARD PREVIEW

3 Terms, definitions and abbreviations (s.iteh.ai)

3.1.16

ISO/IEC 18598:2016/Amd 1:2021

In the definition, replace a connector with corards/sist/46d899a0-8075-4351-b4c0-dd46de7c658e/iso-iec-18598-2016-amd-1-2021

Add the following new terms and definitions at the end of 3.1:

3.1.32

Power over Ethernet

PoE

remote powering in accordance with ISO/IEC/IEEE 8802-3

3.1.33

remote powering

power delivery from power sources to terminal equipment or powered devices over telecommunications cabling

EXAMPLE Power over Ethernet in accordance with ISO/IEC/IEEE 8802-3

3.2 Abbreviations

Add the following new abbreviations at the end of 3.2:

PD powered device

PSE power supply equipment

4 Conformance

Add the following new paragraph after bullet c):

AIM systems that provide support functionality for remote powering to conform to this International Standard shall conform with the requirements of Annex E in addition to the conformance requirements above.

6 AIM solutions: business benefits

6.2 Intrinsic benefits of stand-alone AIM systems

Insert the following new subclause after 6.2.5:

6.2.6 Documentation, monitoring and management of remote powering

AIM systems offering remote powering support provide users with the ability to automatically track remote powering usage in an installation to facilitate ease of assessing whether a given cable or cable bundle is capable of supporting specific remote powering types.

Due to the dynamic nature of the remote powering status of cables within a cable bundle (i.e. connections/disconnections from power supply equipment (PSE) ports and connections/disconnections of powered devices (PDs)), the above functionality can be achieved through a combination of ANDARD PREVIEW

- a) AIM system hardware capability for automatically detecting connection changes,
- b) AIM system software ability to extract end device and remote powering information from PSE using standardized networking protocols, 64.9 SNMP, and
- c) AIM system documentation of the electrical characteristics of the cables. dd46de7c658e/iso-iec-18598-2016-amd-1-2021

7 AIM solutions: Data exchange framework

7.4 Common data model definition

7.4.3 Element and attribute definitions

7.4.3.1 **General**

Table 5 - Attribute key

Replace the description of key "O" with the following:

This field and/or attributes to this field need not be present in all AIM systems, but system interoperability shall be provided.

7.4.3.5 Telecommunications equipment

Table 9 - Telecommunications equipment

Replace the attributes for "Cord (O)" with the following:

ID

Name (O)

Part Number (O)

Colour (O)

Vendor (O)

Length

Connector A

Connector B

Cable

Catalogue image (O)

Replace the attributes for "Connector (O)" with the following:

ID

Name (O)

Connector Type

Catalogue image (O)

iTeh STANDARD PREVIEW (standards.iteh.ai)

7.4.3.7 Work Order

ISO/IEC 18598:2016/Amd 1:2021

https://standards.iteh.ai/catalog/standards/sist/46d899a0-8075-4351-b4c0-

Table 11 – Work Order

dd46de7c658e/iso-iec-18598-2016-amd-1-2021

Replace "WorkOrderState" with "Work Order State".

Annex B (informative) Field descriptions

Table B.1 - AIM software fields

Replace the description of "Cable" with the following:

A physical cable containing either fibre or copper elements

Annex D (informative) Optional lower level data exchange framework

Table D.1 - Port level

Replace the description with the following:

Obtains port and cord information

Replace the response with the following:

Port status,

Cord Data (optional)

Insert the following new annexes:

Annex E (normative)

AIM systems providing remote powering support

E.1 General

Type 4 remote powering in accordance with IEEE 802.3bt-2018 using Ethernet transmission channels will support delivery of up to 90 W per cable.

Due to the dynamic nature of the connectivity changes in the premise's environments, there are many factors which determine remote powering capacity of a cable bundle and cables within that bundle (i.e. conductor and cable diameter, ambient temperature, installation conditions). For example, the number of remote powering cables in a bundle can change with time and monitoring of the number of these cables per bundle can provide the required information.

Cable management software and spreadsheets are not equipped with a mechanism to detect these changes in real time. AIM solutions offering support for remote powering are capable of automatically tracking information relevant to ensure appropriate remote powering delivery.

AIM systems providing support for remote powering shall provide the functionality described in E.2. (standards.iteh.ai)

E.2 Documentation and maintenance of information within AIM software

Once configured, an AIM system providing support for remote powering shall be able to

- a) define and assign a bundle ID to a single cable or a group of cables,
- b) track the cable bundle size for each bundle from a distributor,
- c) track the number of cables in a bundle connected to PSE ports (powered or not),
- d) track the number of cables in a bundle delivering PoE (powered),
- e) track PoE Type and Class for every delivering cable in a bundle,
- f) track PoE consumption for every PoE delivering cable in a bundle,
- g) track PoE allocated power for every PoE delivering cable in a bundle,
- h) automatically detect, document and monitor the presence and the remote powering functionality of PoE equipment connected to the network including:
 - 1) PoE type of each PoE capable switch (PSE), including number of PoE pairs (in accordance with ISO/IEC/IEEE 8802-3),
 - 2) PoE class of each PD,
 - 3) PoE consumption on each switch (PSE) port,
 - 4) allocated PoE level on each PSE port.

E.3 Management and usage of information within AIM software

Once configured, an AIM system providing support for remote powering shall be able to

 a) alert users when a number of cables in a bundle exceeds limit of 24 cables to ensure adequate thermal management for bundled cables by applying mitigation rules in accordance with ISO/IEC TS 29125),

- © ISO/IEC 2021
- b) provide ability for indicating if a circuit is powered prior to its disconnection to prevent possible damage to network equipment ports,
- c) generate reports with information necessary for assessment of the existing installation to support PoE containing the following information:
 - 1) bundle size,
 - 2) number of cables connected to PoE switch ports in a bundle,
 - 3) number of powered cables in a bundle,
 - 4) current PoE power usage per bundle,
 - 5) allocated PoE per bundle,
 - 6) average PoE usage per cable in a bundle,
 - 7) average allocated PoE per cable in a bundle.

iTeh STANDARD PREVIEW (standards.iteh.ai)

ISO/IEC 18598:2016/Amd 1:2021 https://standards.iteh.ai/catalog/standards/sist/46d899a0-8075-4351-b4c0-dd46de7c658e/iso-iec-18598-2016-amd-1-2021

Annex F (informative)

Data import from field test equipment

Import formats used for the import of data from field test equipment should be either

CSV data

or

XML-data.

iTeh STANDARD PREVIEW (standards.iteh.ai)

ISO/IEC 18598:2016/Amd 1:2021 https://standards.iteh.ai/catalog/standards/sist/46d899a0-8075-4351-b4c0-dd46de7c658e/iso-iec-18598-2016-amd-1-2021