



INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 49: Flame arresters – Performance requirements, test methods and limits
for use**

**Atmosphères explosives –
Partie 49: Arrête-flammes – Exigences de performance, méthodes d’essai et
limites d’utilisation**

[ISO/IEC 80079-49:2024](https://standards.iteh.ai/)

<https://standards.iteh.ai/catalog/standards/iso/d818a32f-420a-48d0-ac96-fe5b96955b08/iso-iec-80079-49-2024>





THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2024 ISO/IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about ISO/IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'ISO/IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

[ISO/IEC 80079-49:2024](https://standards.iteh.ai/catalog/standards/iso/d818a32f-420a-48d0-ac96-fe5b96955b08/iso-iec-80079-49-2024)

<https://standards.iteh.ai/catalog/standards/iso/d818a32f-420a-48d0-ac96-fe5b96955b08/iso-iec-80079-49-2024>

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications, symboles graphiques et le glossaire. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 500 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 25 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch



INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 49: Flame arresters – Performance requirements, test methods and limits
for use**

**Atmosphères explosives –
Partie 49: Arrête-flammes – Exigences de performance, méthodes d’essai et
limites d’utilisation**

<https://standards.iteh.ai/>
<https://standards.iteh.ai/catalog/standards/iso/d818a32f-420a-48d0-ac96-fe5b96955b08/iso-iec-80079-49-2024>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	9
3 Terms and definitions	9
4 Abbreviated terms and symbols	13
5 Hazards and flame arrester classifications.....	14
5.1 Flame transmission classification: deflagration, stable and unstable detonation.....	14
5.2 Flame transmission classification: stabilized burning.....	15
5.3 Index of tests	15
6 General requirements	16
6.1 Measuring instruments.....	16
6.2 Flow measurement (air)	17
6.3 Flame transmission test	17
6.3.1 General	17
6.3.2 Test mixtures.....	17
7 Specific requirements for static flame arresters	19
7.1 Construction requirements for prototype arresters.....	19
7.2 Design series.....	19
7.3 Flame transmission tests	20
7.3.1 General	20
7.3.2 Deflagration test	21
7.3.3 Tests for detonation flame arresters	24
7.3.4 Short time burning test	30
7.3.5 Endurance burning test.....	33
8 Specific requirements for liquid product detonation flame arresters	34
8.1 Liquid seals	34
8.2 Foot valves	35
8.3 Flame transmission test	36
9 Specific requirements for dynamic flame arresters (high velocity vent valves).....	37
9.1 General.....	37
9.2 Flame transmission tests	37
9.2.1 Low flow flame transmission test	37
9.2.2 Flame transmission test by opening and closing	39
9.2.3 Deflagration test	40
9.2.4 Endurance burning test.....	40
10 Specific requirements for hydraulic flame arresters.....	41
10.1 Equipment	41
10.2 Flame transmission tests	41
10.2.1 General	41
10.2.2 Short time burning test	41
10.2.3 Deflagration test	41
10.2.4 Detonation test	42
11 Test of flame arresters installed on or within gas conveying equipment	44
11.1 General.....	44

11.2	Flame transmission tests	44
11.2.1	General	44
11.2.2	Test procedure for gas conveying equipment with inlet pressure > 600 hPa	46
11.2.3	Test procedure for gas conveying equipment with inlet pressure ≤ 600 hPa	47
12	Instructions	47
13	Marking	48
13.1	Location	48
13.2	Flame arrester housing	49
13.2.1	General information	49
13.2.2	Warning markings	49
13.2.3	Examples of marking	50
13.3	Flame arrester element	51
14	Manufacturing and production	51
14.1	Construction	51
14.2	Housing	51
14.3	Joints	51
14.4	Pressure test	51
14.5	Leak test	52
Annex A (normative)	Flow measurement	53
A.1	General	53
A.2	In-line flame arresters	54
A.3	End-of-line flame arrester	54
A.3.1	General	54
A.3.2	Special flow measurement for dynamic flame arresters	55
A.4	Undamped oscillation tests of dynamic flame arrester (High velocity vent valves)	56
Annex B (informative)	Information for selecting flame arresters	58
Annex C (informative)	Recommended practice	59
Annex D (informative)	Evaluation of test results	60
Annex E (normative)	Application	62
E.1	General	62
E.2	Limits for use for static flame arresters	63
E.2.1	In-line flame arrester	63
E.2.2	Pre-volume flame arrester	63
E.2.3	Detonation flame arrester	63
E.2.4	Short time burn flame arrester	63
E.3	Limits for use for liquid detonation flame arresters	64
E.4	Limits for use for dynamic flame arresters (high velocity vent valves)	64
E.5	Limits for use for hydraulic flame arresters	64
Annex F (informative)	Significant changes between this document and EN ISO 16852:2016	67
Bibliography	69
Figure 1	– Test apparatus for end-of-line flame arrester for deflagration test	21
Figure 2	– Test apparatus for in-line flame arrester for deflagration test	22
Figure 3	– Test apparatus for pre-volume flame arrester for deflagration test	24

Figure 4 – Test apparatus for detonation flame arrester for detonation without restriction.....	26
Figure 5 – Test apparatus for detonation flame arrester for detonation with restriction	28
Figure 6 – Test apparatus for short time burning test	31
Figure 7 – Test apparatus for endurance burning test	33
Figure 8 – Liquid product detonation flame arrester	35
Figure 9 – End-of-line flame arrester incorporating a non-return valve (foot valve).....	35
Figure 10 – Test apparatus for liquid product detonation flame arresters	36
Figure 11 – Test apparatus for determining the non-hammering conditions for dynamic flame arresters.....	39
Figure 12 – Test apparatus for hydraulic flame arresters.....	43
Figure 13 – Test apparatus for the flame transmission test of flame arresters installed on or within gas conveying equipment.....	45
Figure 14 – Example of marking plate, burn rating "a".....	50
Figure 15 – Example of marking plate, burn rating "b".....	50
Figure A.1 – Test apparatus for recording the pressure drop/flow rate curve for in-line flame arresters.....	54
Figure A.2 – Test apparatus for recording the pressure drop/flow rate curve for end-of-line flame arresters with or without integrated pressure/vacuum valve	56
Figure A.3 – Test apparatus for determining the non-oscillating conditions for dynamic flame arresters.....	57
Figure D.1 – Decision process for stable detonation arrester (DET3 and DET4).....	60
Figure D.2 – Decision process for unstable detonation arrester (DET1 and DET2).....	61
Figure E.1 – Test apparatus for hydraulic flame arresters	66
Table 1 – Flame arrester classification for deflagration, stable and unstable detonation.....	15
Table 2 – Summary of tests to be conducted.....	16
Table 3 – Specification of gas-air mixtures for deflagration and detonation tests.....	18
Table 4 – Specification of gas-air mixtures for short time burning tests and burning tests of dynamic flame arresters	18
Table 5 – Specification of gas-air or vapour-air mixtures for endurance burning tests of static flame arresters	19
Table 6 – Design series	20
Table 7 – Ratio p_{md}/p_{TB}	27
Table 8 – Number of the individual tests and test parameters for the flame transmission test of flame arresters installed on or within gas conveying equipment with inlet pressures > 600 hPa	46
Table 9 – Number of the individual tests and test parameters for the flame transmission test of flame arresters installed on or within gas conveying equipment with inlet pressures ≤ 600 hPa	47
Table B.1 – Information for selecting flame arresters	58
Table F.1 – Significant changes with respect to EN ISO 16852:2016	67

EXPLOSIVE ATMOSPHERES –

Part 49: Flame arresters – Performance requirements, test methods and limits for use

FOREWORD

- 1) ISO (the International Organization for Standardization) and IEC (the International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards through technical committees established by the respective organization to deal with particular fields of technical activity. ISO and IEC technical committees collaborate in fields of mutual interest. Other international organizations, governmental and non-governmental, in liaison with ISO and IEC, also take part in the work.
- 2) The formal decisions or agreements of IEC and ISO on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC and ISO National bodies.
- 3) IEC and ISO documents have the form of recommendations for international use and are accepted by IEC and ISO National bodies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC and ISO documents is accurate, IEC and ISO cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC and ISO National bodies undertake to apply IEC and ISO documents transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC and ISO document and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC and ISO do not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC and ISO marks of conformity. IEC and ISO are not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this document.
- 7) No liability shall attach to IEC and ISO or their directors, employees, servants or agents including individual experts and members of its technical committees and IEC and ISO National bodies for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this ISO/IEC document or any other IEC and ISO documents.
- 8) Attention is drawn to the Normative references cited in this document. Use of the referenced publications is indispensable for the correct application of this document.
- 9) IEC and ISO draw attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC and ISO take no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC and ISO had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch> and www.iso.org/patents. IEC and ISO shall not be held responsible for identifying any or all such patent rights.

ISO/IEC 80079-49 has been prepared by subcommittee 31M: Non-electrical equipment and protective systems for explosive atmospheres, of ISO/IEC joint technical committee 1: Information technology.

This edition cancels and replaces ISO 16852:2016, which has been technically revised. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to ISO 16852:2016:

- a) adaptation of the relevant IEC TC 31 requirements on standards;
- b) modification of the upper limit of the temperature range from 150 °C to 200 °C under the condition that T_0 shall be not larger than 80 % of the auto ignition temperature of the gas-air-mixture;
- c) change of the term "explosion group" to "equipment group" due to editorial requirements in IEC/TC 31;
- d) clarification of the conditions and requirements for flame arresters whose intended operating conditions are outside the atmospheric conditions in 7.3.4 and 7.3.5;

- e) clarification of the requirements on the information for use in Clause 12 f) concerning the burn time;
- f) addition of a permission to the construction requirements both in 7.1 and 14.1 to substitute visual inspection by performing a flow test;
- g) addition of a flow chart for the evaluation of test results as Annex D.

The text of this International Standard is based on the following documents:

Draft	Report on voting
31M/212/FDIS	31M/223/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

A list of all parts in the ISO/IEC 80079 series, published under the general title *Explosive atmospheres*, can be found on the IEC website.

NOTE The following print types are used:

- Words in *italic* font in the text are defined in Clause 3.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1, available at www.iec.ch/members_experts/refdocs and www.iso.org/directives.

ITeH Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO/IEC 80079-49:2024](https://standards.iteh.ai/catalog/standards/iso/d818a32f-420a-48d0-ac96-fe5b96955b08/iso-iec-80079-49-2024)

<https://standards.iteh.ai/catalog/standards/iso/d818a32f-420a-48d0-ac96-fe5b96955b08/iso-iec-80079-49-2024>

INTRODUCTION

Flame arresters are protective systems fitted to openings of enclosures or to pipe work and are intended to allow fluid flow but prevent flame transmission if a flammable mixture is ignited. They have widely been used for decades in the chemical and oil industry, and a variety of national standards is available. This document was prepared with an aim to establish an international basis by harmonizing and incorporating recent national developments and standards as far as reasonable.

This document addresses performance requirements and test methods, as well as limits for use for flame arresters.

Only the minimum safety requirements for flame arresters to prevent flame transmission are specified.

The hazard identification of common applications found in industry leads to the specification of the test methods. These test methods reflect standard practical situations and, as such, form the heart of this document because they also allow classification of the various types of flame arresters and then determination of the limits of use.

A considerable number of test methods and test conditions had to be taken into account for two main reasons.

- a) Different types of flame arresters are covered with respect to the operating principle (static, hydraulic, liquid, dynamic) and each type clearly needs its specific test set-up and test procedure.
- b) It is necessary to adapt flame arresters to the special conditions of application (gas, installation) because of the conflicting demands of high flame quenching capability and low pressure loss. This situation is completely different from the otherwise similar principle of protection by flameproof enclosure, for example for electrical equipment, where the importance of process gas flow through any gaps is negligible and importance is placed on the flame quenching effect of the gap.

Consequently, in this document, the testing and classification related to Equipment Groups and installation conditions have been subdivided more than is usually the case in other parts of the ISO/IEC 80079 and IEC 60079 series of standards. In particular,

- Equipment Group IIA is subdivided into sub-groups IIA1 and IIA,
- Equipment Group IIB is subdivided into sub-groups IIB1, IIB2, IIB3 and IIB, and
- the type "detonation arrester" is divided into four sub-types, which take into account specific installation situations.

The test conditions lead to the limits for use which are most important for the user. This document specifies this safety relevant information and its dissemination through the manufacturer's written instructions for use and the marking of the flame arresters.

The limits for use are also a link to more general (operational) safety considerations and regulations, which remain the responsibility the user and regulators. Annex B and Annex C offer some guidance on these aspects.

EXPLOSIVE ATMOSPHERES –

Part 49: Flame arresters – Performance requirements, test methods and limits for use

1 Scope

This document specifies the requirements for flame arresters that prevent flame transmission when explosive gas-air or vapour-air mixtures are present. It establishes uniform principles for the classification, basic construction and information for use, including the marking of flame arresters, and specifies test methods to verify the safety requirements and determine safe limits of use.

This document is applicable to pressures ranging from 80 kPa to 160 kPa and temperatures ranging from $-20\text{ }^{\circ}\text{C}$ to $+200\text{ }^{\circ}\text{C}$.

NOTE 1 For flame arresters with operational conditions inside the scope, but outside atmospheric conditions, see Annex E.

NOTE 2 In designing and testing flame arresters for operation under conditions other than those specified above, this document can be used as a guide. This document can also be used to design any additional testing related to the specific conditions of use. This is particularly important when high temperatures and pressures are applied. The test mixtures might need to be modified in these cases.

This document does not apply to the following:

- external safety-related measurement and control equipment that might be required to keep the operational conditions within the established safe limits;

NOTE 3 Integrated measurement and control equipment, such as integrated temperature and flame sensors as well as parts which, for example, intentionally melt (retaining pin), burn away (weather hoods) or bend (bimetallic strips), are within the scope of this document.

- flame arresters used for explosive mixtures of vapours and gases, which tend to self-decompose (for example, acetylene) or which are chemically unstable;
- flame arresters used for carbon disulfide, due to its special properties;
- flame arresters whose intended use is for mixtures other than gas-air or vapour-air mixtures (for example, higher oxygen-nitrogen ratio, chlorine as oxidant);
- flame arrester test procedures for reciprocating internal combustion engines;

NOTE 4 Flame arresters for specific applications (e.g. reciprocating internal combustion engines) can use this document as a guide for design but be subject to testing related to their specific use.

- fast acting valves, extinguishing systems and other explosion isolating systems;
- Flame arresters used in gas detectors (those being covered for example, by IEC 60079-29-1 and IEC 62990-1).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-1, *Explosive atmospheres – Part 1: Equipment protection by flameproof enclosures "d"*

ISO/IEC 80079-34, *Explosive atmospheres – Part 34: Application of quality management systems for Ex Product manufacture*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60079-0 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1

flame arrester

device fitted to the opening of an enclosure, or to the connecting pipe work of a system of enclosures, and whose intended function is to allow flow but prevent the transmission of flame

<https://standards.iteh.ai/catalog/standards/iso/d818a32f-420a-48d0-ac96-fe5b96955b08/iso-iec-80079-49-2024>

3.2

housing

portion of a *flame arrester* (3.1) whose principal function is to provide a suitable enclosure for the *flame arrester element* (3.3) and allow mechanical connections to other systems

3.3

flame arrester element

portion of a *flame arrester* (3.1) whose principal function is to prevent flame transmission

3.4

stabilized burning

steady burning of a flame stabilized at, or close to, the *flame arrester element* (3.3)

3.5

short time burning

stabilized burning (3.4) for a specified time

3.6

endurance burning

stabilized burning (3.4) for an unlimited time

**3.7
explosion**

abrupt oxidation or decomposition reaction producing an increase in temperature, pressure, or both simultaneously

[SOURCE: ISO 8421-1:1987, 1.13]

**3.8
deflagration**

explosion (3.7) propagating at subsonic velocity

[SOURCE: ISO 8421-1:1987, 1.11]

**3.9
detonation**

explosion (3.7) propagating at supersonic velocity and characterized by a shock wave

[SOURCE: ISO 8421-1:1987, 1.12]

**3.10
stable detonation**

detonation (3.9) progressing through a confined system without significant variation of velocity and pressure characteristics

Note 1 to entry: For the atmospheric conditions, test mixtures and test procedures of this document, typical velocities range between 1 600 m/s and 2 200 m/s.

**3.11
unstable detonation**

detonation (3.9) during the transition of a combustion process from a *deflagration* (3.8) into a *stable detonation* (3.10)

Note 1 to entry: The transition occurs in a limited spatial zone, where the velocity of the combustion wave is not constant and where the explosion pressure is significantly higher than in a stable detonation. The position of this transition zone depends, amongst other factors, on pipe diameter, pipe configuration, test gas and explosion group.

Note 2 to entry: An unstable detonation presents a higher level of hazard than a stable detonation due to higher flame speeds and pressures.

**3.12
characteristic safety data of explosive mixtures**

**3.12.1
maximum experimental safe gap
MESG**

maximum gap of a joint of 25 mm in width which prevents any transmission of an explosion during tests made under the conditions specified in ISO/IEC 80079-20-1

[SOURCE: ISO/IEC 80079-20-1:2017, 3.4, modified – "in ISO/IEC 80079-20-1" added and Note 1 to entry deleted.]

**3.12.2
safe gap**

maximum gap of a joint of 25 mm in width which prevents any transmission of an explosion during tests made under the conditions specified in ISO/IEC 80079-20-1 for the specified vapour/gas mixture

3.12.3 equipment grouping

classification system of equipment related to the explosive atmosphere for which they are intended to be used

Note 1 to entry: In a large part of the safety equipment industry "explosion group" is used as an alternative term.

[SOURCE: ISO/IEC 80079-20-1:2017, 3.7, modified – Note 1 to entry replaced.]

3.13 bi-directional flame arrester

flame arrester (3.1) that prevents flame transmission from both sides

3.14 deflagration flame arrester DEF

flame arrester (3.1) designed to prevent the transmission of a *deflagration* (3.8)

Note 1 to entry: It can be an *end-of-line flame arrester* (3.21) or an *in-line flame arrester* (3.22).

3.15 detonation flame arrester DET

flame arrester (3.1) designed to prevent the transmission of a detonation

Note 1 to entry: It can be an *end-of-line flame arrester* (3.21) or an *in-line flame arrester* (3.22), and can be used for both *stable detonations* (3.10) and *unstable detonations* (3.11).

3.16 endurance flame arrester

flame arrester (3.1) that prevents flame transmission during and after *endurance burning* (3.6)

3.17 static flame arrester

flame arrester (3.1) designed to prevent flame transmission by quenching gaps

3.17.1 measurable type

flame arrester (3.1) where the quenching gaps of the *flame arrester element* (3.3) can be technically drawn, measured and controlled

3.17.2 non-measurable type

flame arrester (3.1) where the quenching gaps of the *flame arrester element* (3.3) cannot be technically drawn, measured or controlled

EXAMPLE Random structures such as knitted mesh, sintered materials and gravel beds.

3.18 dynamic flame arrester high velocity vent valve

deflagration proof (see 3.14) pressure relief valve designed always to have efflux velocities that prevent the flame propagation against the flow direction

Note 1 to entry: It can be endurance burn proof (see 3.16).

3.19

liquid product detonation flame arrester

flame arrester (3.1) in which the liquid product is used to form a liquid seal as a flame arrester medium, in order to prevent flame transmission of a stable or unstable detonation without restriction (type 4 or type 2)

Note 1 to entry: There are two types of liquid product detonation flame arrester for use in liquid product lines: liquid seals and foot valves.

3.19.1

liquid seal flame arrester

flame arrester (3.1) designed to use the liquid product to form a barrier to flame transmission

3.19.2

foot valve flame arrester

flame arrester (3.1) designed to use the liquid product combined with a non-return valve to form a barrier to flame transmission

3.20

hydraulic flame arrester

flame arrester (3.1) designed to break the flow of an explosive mixture into discrete bubbles in a water column, thus preventing flame transmission

3.21

end-of-line flame arrester

flame arrester (3.1) that is fitted with one pipe connection only

3.22

in-line flame arrester

flame arrester (3.1) that is fitted with two pipe connections, one on each side of the flame arrester

3.23

pre-volume flame arrester

VDEF

flame arrester (3.1) that, after ignition by an internal ignition source, prevents flame transmission from inside an explosion-pressure-resistant containment (for example, a vessel or closed pipe work) to the outside, or into the connecting pipe work

Note 1 to entry: Explosion-pressure resistance is a property of vessels and equipment designed to withstand the expected explosion pressure without becoming permanently deformed.

3.24

integrated temperature sensor

temperature sensor integrated into the flame arrester, as specified by the manufacturer of the flame arrester, in order to provide a signal suitable to activate counter measures