

**ISO/FDIS 817**

ISO/TC 86/SC 8

Secretariat: ANSI

Date: [2024-07-11](#)

**Refrigerants — Designation and safety classification**

*Fluides frigorigènes — Désignation et classification de sécurité*

FDIS stage

[ISO/FDIS 817](#)

<https://standards.iteh.ai/catalog/standards/iso/9341fc1c-3af5-41cb-aeb8-ba3cab01b99/iso-fdis-817>

**ISO/FDIS 817:2024(en)**

© ISO 2024

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
CP 401 • Ch. de Blandonnet 8  
CH-1214 Vernier, Geneva  
Phone: + 41 22 749 01 11  
E-mail: [copyright@iso.org](mailto:copyright@iso.org)  
Website: [www.iso.org](http://www.iso.org)

Published in Switzerland

iTeh Standards  
(<https://standards.iteh.ai>)  
Document Preview

[ISO/FDIS 817](#)

<https://standards.iteh.ai/catalog/standards/iso/9341fc1c-3af5-41cb-aeb8-ba3cab01b99/iso-fdis-817>

**Contents**

Foreword .....	iii
— Scope .....	iii
— Normative references .....	iii
— Terms, definitions, abbreviated terms and symbols .....	iii
— Terms and definitions .....	iii
— Abbreviated terms .....	iii
— Symbols .....	iii
— Numbering of refrigerants .....	iii
— Refrigerant Tables .....	iii
— Identifying numbers .....	iii
— Ether-based refrigerants .....	iii
— Blends .....	iii
— Miscellaneous organic compounds .....	iii
— Inorganic compounds .....	iii
— Designation prefixes .....	iii
— General prefixes .....	iii
— Composition-designating prefixes .....	iii
— Safety classifications .....	iii
— General .....	iii
— Matrix diagram of safety group classification system .....	iii
— Refrigerant classifications and property data .....	iii
— Refrigerant concentration limits .....	iii
— General .....	iii
— Data for calculations .....	iii
— Contaminants and impurities .....	iii
— Conversion of units — Volumic mass and altitude adjustment .....	iii
(informative) Examples of isomer designation .....	iii
(normative) Details of testing for flammability and fractionation analysis .....	iii
(normative) Refrigerant classifications and properties .....	iii
(normative) Calculation of ATEL for blends .....	iii
(informative) Data used to determine safety classification, refrigerant concentration limits and data for unclassified refrigerants .....	iii
(normative) Application instructions .....	iii
(normative) Data submission instructions .....	iii
(informative) Recommended significant figures reporting of quantities in applications to ISO 817-MA .....	iii
(informative) Examples of minimum composition tolerance .....	iii
Bibliography .....	iii
Foreword .....	vi
1 Scope .....	1
2 Normative references .....	1

ISO/FDIS 817:2024(en)

3	Terms, definitions, abbreviated terms and symbols .....	1
3.1	Terms and definitions .....	1
3.2	Abbreviated terms .....	6
3.3	Symbols .....	7
4	Numbering of refrigerants .....	8
4.1	Refrigerant Tables .....	8
4.2	Identifying numbers .....	8
4.2.1	General .....	8
4.2.2	First digit on the right .....	8
4.2.3	Second digit from the right .....	8
4.2.4	Third digit from the right .....	8
4.2.5	Fourth digit from the right .....	8
4.2.6	Presence of bromine (Br) or iodine (I) .....	8
4.2.7	Number of chlorine (Cl) atoms .....	9
4.2.8	Carbon atoms .....	9
4.2.9	Cyclic compounds .....	9
4.2.10	Isomers in the ethane and ethene series .....	9
4.2.11	Isomers in the propane series .....	9
4.2.12	Isomers in the propene series .....	10
4.2.13	Extension to compounds of four carbon atoms .....	10
4.2.14	Identification of stereoisomers .....	11
4.3	Ether-based refrigerants .....	11
4.3.1	General .....	11
4.3.2	Two-carbon, dimethyl ethers .....	11
4.3.3	Straight chain, three carbon ethers .....	11
4.3.4	Cyclic ethers .....	12
4.4	Blends .....	12
4.4.1	General .....	12
4.4.2	Zeotropes .....	12
4.4.3	Azeotropes .....	12
4.4.4	Blend tolerances .....	12
4.4.5	Composition uniqueness .....	12
4.5	Miscellaneous organic compounds .....	12
4.6	Inorganic compounds .....	13
4.6.1	General .....	13
4.6.2	Compounds with relative molar masses less than 100 .....	13
4.6.3	Compounds with relative molar masses equal to or greater than 100 .....	14
4.6.4	Two or more inorganic refrigerants with the same molar masses .....	14
5	Designation prefixes .....	14
5.1	General prefixes .....	14
5.2	Composition-designating prefixes .....	14
6	Safety classifications .....	15
6.1	General .....	15
6.1.1	Safety classification — Composition .....	15
6.1.2	Toxicity classification .....	15
6.1.3	Flammability classification .....	16
6.2	Matrix diagram of safety group classification system .....	18
7	Refrigerant classifications and property data .....	18
8	Refrigerant concentration limits .....	18
8.1	General .....	18
8.1.1	General .....	18
8.1.2	Acute-toxicity exposure limit (ATEL) .....	18

ISO/FDIS 817:2024(en)

<a href="#">8.1.3 Mortality</a>	18
<a href="#">8.1.4 Cardiac sensitization</a>	19
<a href="#">8.1.5 Anaesthetic or central nervous system (CNS) effects</a>	20
<a href="#">8.1.6 Other escape-impairing symptoms and permanent injury</a>	20
<a href="#">8.1.7 Oxygen deprivation limit (ODL)</a>	20
<a href="#">8.2 Data for calculations</a>	20
<a href="#">8.2.1 Data sources</a>	20
<a href="#">8.2.2 Consistent measures</a>	21
<a href="#">8.3 Contaminants and impurities</a>	21
<a href="#">8.4 Conversion of units — Volumic mass and altitude adjustment</a>	21
<a href="#">Annex A (informative) Examples of isomer designation</a>	23
<a href="#">Annex B (normative) Details of testing for flammability and fractionation analysis</a>	26
<a href="#">Annex C (normative) Refrigerant classifications and properties</a>	31
<a href="#">Annex D (normative) Calculation of ATEL for blends</a>	32
<a href="#">Annex E (informative) Data used to determine safety classification, refrigerant concentration limits and data for unclassified refrigerants</a>	35
<a href="#">Annex F (informative) Examples of minimum composition tolerance</a>	36
<a href="#">Bibliography</a>	39

iTeh Standards  
(<https://standards.iteh.ai>)  
Document Preview

[ISO/FDIS 817](#)

<https://standards.iteh.ai/catalog/standards/iso/9341fc1c-3af5-41cb-aeb8-ba3cab01b99/iso-fdis-817>

## ISO/FDIS 817:2024(en)

### Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at [www.iso.org/patents](http://www.iso.org/patents). ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by Technical Committee ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 8, *Refrigerants and refrigeration lubricants*.

This fourth edition cancels and replaces the third edition (ISO 817:2014), which has been technically revised. **It also incorporates the Amendments ISO 817:2014/Amd 1:2017 and ISO 817:2014/Amd 2:2021.**

The main changes are as follows:

- ~~The Scope~~ **the scope** has been expanded to include data necessary for safe applications of the refrigerants;
- ~~Rules~~ **the rules** of toxicity safety classification to consider acute and chronic toxicity, have been incorporated into ~~6.1.2~~ **6.1.2**;
- ~~Requirements~~ **requirements** to apply for designations, safety classifications, and refrigerant concentration limits for refrigerants, including blends, and requirements to submit new or revised data for refrigerants listed in ISO 817 tables, previously located in Annex F, ~~Annex G~~, and ~~Annex H~~, have been relocated to <https://standards.iso.org/iso/817/ma/en/>.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at [www.iso.org/members.html](http://www.iso.org/members.html).

## Refrigerants — Designation and safety classification

### 1 Scope

This document provides an unambiguous system for assigning designations to refrigerants. It also establishes a system for assigning a safety classification to refrigerants based on toxicity and flammability data, and provides a means of determining the refrigerant concentration limit. Tables listing the refrigerant designations, safety classifications, refrigerant concentration limits, and data necessary for safe use of the refrigerants are included based on data submitted with the application.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

[ISO/PAS 24499, Method of test for burning velocity measurement of A2L flammable gases](#)

ANSI/ASHRAE Standard 34, *Designation and Safety Classification of Refrigerants*

ASTM D8211, *Standard Test Method for Hot Surface Ignition Temperature of Gases on Flat Surface*

ASTM E681, *Standard Test Method for Concentration Limits of Flammability of Chemicals (Vapours and Gases)*

[ISO/PAS 24499, Method of test for burning velocity measurement of A2L flammable gases](#)

### 3 Terms, definitions, abbreviated terms and symbols

#### 3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

#### 3.1.1

##### acute toxicity

adverse health effect(s) from a single, short-term exposure

#### 3.1.2

##### acute-toxicity exposure limit

###### ATEL

maximum recommended *refrigerant* concentration determined in accordance with the established systems and intended to reduce the risks of *acute toxicity* (3.1.1.1) hazards to humans in the event of a *refrigerant* release

Note 1 to entry: The systems are specified in this document.

#### 3.1.3

##### anaesthetic effect

impairment of the ability to perceive pain and other sensory stimulation

## ISO/FDIS 817:2024(en)

### 3.1.4 approximate lethal concentration

#### ALC

concentration of a *refrigerant* that is lethal to even a single test animal but to less than 50% of the animals in that group when tested by the same conditions as for an LC<sub>50</sub> test

### 3.1.5 auto-ignition temperature

#### AIT

lowest temperature at or above which a substance can spontaneously ignite in air at standard atmospheric pressure without an external source of ignition, such as a flame or spark

### 3.1.6 azeotrope

*blend* composed of two or more *refrigerants* whose equilibrium vapour and liquid phase compositions are the same at a specific pressure, but can be different at other conditions

### 3.1.7 blend

mixture composed of two or more *refrigerants*

### 3.1.8 burning velocity

#### $S_u$

velocity, relative to the unburnt gas, at which a laminar flame propagates in a direction normal to the flame front, at the concentration of *refrigerant* with air giving the maximum velocity

Note 1 to entry: This value is expressed in centimetres per second.

### 3.1.9 central nervous system effect

#### CNS

treatment-related depression, distraction, stimulation, or other behavioural modification to a degree that could represent an impairment of the ability to escape from a hazard

### 3.1.10 chronic toxicity

adverse health effect(s) from long-term repeated exposures

### 3.1.11 combustion

exothermal reaction between an oxidant component (combustive) and a reducer (combustible fuel)

### 3.1.12 compound

substance composed of two or more atoms chemically bonded in definite proportions

### 3.1.13 critical point

point with conditions above which distinct liquid and gas phases do not exist

### 3.1.14 cyclic compound

organic compound whose structure is characterized by a closed ring of atoms



**3.1.15**  
**effective concentration 50-%**

**EC<sub>50</sub>**  
concentration of a *refrigerant* which causes a biological effect to 50-% of exposed animals in a test for anaesthetic or other effects

Note 1 to entry: This value is typically a calculated value from experimental data.

**3.1.16**  
**elevated temperature flame limit**

**ETFL**  
minimum concentration by volumic ratio (volume per cent) of the *refrigerant*, which is capable of propagating a *flame* through a homogeneous mixture of the *refrigerant* and air under the specified test conditions at 60,0 °C and 101,3 kPa

Note 1 to entry: The test conditions are specified in [6.1.36.1.3](#).

Note 2 to entry: 101,3 kPa is the standard atmospheric pressure at sea level.

**3.1.17**  
**equivalence ratio**

fraction of the combustible in the mixture divided by the combustible fraction at the stoichiometric conditions

Note 1 to entry: It can be written as (combustible fraction)/(combustible fraction)<sub>st</sub>.

Note 2 to entry: It is used in the determination of *burning velocity* ([3.1.8](#)).

Note 3 to entry: Lean mixtures have an equivalence ratio lower than one and rich mixtures have an equivalence ratio greater than one.

**3.1.18**  
**flame**

collection of gases of a rapid combustion, generally visible due to the emission of light

**3.1.19**  
**flame propagation**

combustion, causing a continuous *flame* ([3.1.183.1.18](#)) which moves upward and outward from the point of ignition without help from the ignition source

Note 1 to entry: Flame propagation as applied in the test method for determining LFL and flammability classification is specified in [B.1.7.B.1.7](#). Flame propagation as applied in the test method for determining *burning velocity* ([3.1.83.1.8](#)) is described in ISO/PAS 24499.

**3.1.20**  
**flame propagation velocity**

velocity at which a *flame* ([3.1.183.1.18](#)) propagates in a space

**3.1.21**  
**flammable**

property of a mixture in which a *flame* ([3.1.183.1.18](#)) is capable of self-propagating for a certain distance

**3.1.22**  
**fractionation**

change in composition of a *blend* ([3.1.73.1.7](#)) by preferential evaporation of the more volatile component(s) or condensation of the less volatile component(s)

Field Code Changed

## ISO/FDIS 817:2024(en)

### 3.1.23 heat of combustion HOC

heat evolved from a specified exothermic reaction of a substance with oxygen.

Note 1 to entry: The heat of combustion is as determined in accordance with [6.1.3.7](#).

Note 2 to entry: The heat of combustion for this document is expressed as a positive value for exothermic reactions in energy per unit mass (kJ/kg).

Note 3 to entry: The heat of combustion for Class 2L, 2, and 3 *refrigerants* is listed in Tables E.2 and E.3 available at <https://standards.iso.org/iso/817/ma/en>.

### 3.1.24 hot surface ignition temperature HSIT

lowest temperature at which a substance ignites in normal atmosphere when impinged upon a heated surface

Note 1 to entry: Refer to ASTM D8211.

### 3.1.25 immediately dangerous to life or health IDLH

atmospheric concentration of any toxic, corrosive, or asphyxiant substance that poses an immediate threat to life or would cause irreversible or delayed adverse health effects or would interfere with an individual's ability to escape from a dangerous atmosphere

Note 1 to entry: IDLH values are used by the National Institute for Occupational Safety and Health (NIOSH) as respirator selection criteria.

### 3.1.26 isomer

two or more compounds having the same chemical composition with differing molecular configurations

### 3.1.27 lethal concentration 50-%

atmospheric concentration that is lethal to 50-% of the exposed population

Note 1 to entry: LC<sub>50</sub> is associated with inhalation exposures.

### 3.1.28 lethal dose 50-%

oral or dermal dose that is lethal to 50-% of the exposed population

### 3.1.29 lower flammability limit

minimum concentration of the *refrigerant* that is capable of propagating a *flame* ([3.1.183.1.18](#)) through a homogeneous mixture of the *refrigerant* and air under the specified test conditions at 23,0-°C and 101,3-kPa

Note 1 to entry: The test conditions are specified in [6.1.36.1.3](#).

Note 2 to entry: The LFL is expressed as *refrigerant* percentage by volume.

Field Code Changed

## ISO/FDIS 817:2024(en)

### 3.1.30

#### lowest observed adverse effect level

##### LOAEL

lowest concentration of a *refrigerant* that causes any observed adverse effect on one or more test animals

### 3.1.31

#### no observed adverse effect level

##### NOAEL

highest concentration of a *refrigerant* at which no adverse effect is observed on even one test animal.

### 3.1.32

#### nominal composition

##### nominal formulation

design composition as stated in the *refrigerant blend* (3.1.73.1.7) application, excluding any tolerances

Note 1 to entry: Composition of the *refrigerant blends* (3.1.73.1.7) shall be as listed in Tables C.2 and C.3.

Note 2 to entry: When a container with the nominal composition is 80% or more liquid filled, the liquid composition can be considered the nominal composition.

### 3.1.33

#### occupational exposure limit

##### OEL

time-weighted average concentration for a normal 8-h workday and a 40-h work week to which nearly all workers can be repeatedly exposed without adverse effect

Note 1 to entry: The OEL is determined by an independent organization that (1) is composed of health science experts, (2) is experienced in generating OELs for *refrigerant* compounds and (3) formally publishes the derived OELs in a way that is publicly accessible.

### 3.1.34

#### olefin

unsaturated chemical compound containing at least one carbon-to-carbon double bond

3.1.35 <https://standards.iteh.ai/catalog/standards/iso/9341fc1c-3af5-41cb-aeb8-ba3cab01b99/iso-fdis-817>

#### oxygen deprivation limit

##### ODL

concentration of a *refrigerant* or other gas that can result in insufficient oxygen for normal breathing

### 3.1.36

#### quenching

effect of extinction of a *flame* (3.1.183.1.18) as it approaches a surface due to heat conduction losses, absorption of active chemical species and viscous effects on the surface

### 3.1.37

#### refrigerant

fluid used for heat transfer in a refrigerating system

Note 1 to entry: A refrigerant absorbs heat at a low temperature and a low pressure of the fluid and rejects it at a higher temperature and a higher pressure of the fluid, usually involving changes of the phase of the fluid.

### 3.1.38

#### relative molar mass

mass numerically equal to the molecular mass expressed in grams per mole, except that it is dimensionless

## ISO/FDIS 817:2024(en)

### 3.1.39

#### saturated organic compound

carbon-containing compound that has only single bonds between carbon atoms

### 3.1.40

#### stoichiometric concentration for combustion

$C_{st}$   
concentration of a fuel in a fuel-air mixture that contains exactly the necessary quantity of air (21-% O<sub>2</sub>/79-% N<sub>2</sub> by volume) needed for the complete oxidation of all compounds present

### 3.1.41

#### threshold limit value—short term exposure limit

##### TLV-STEL

15-minute [min](#) time weighted average exposure that should not be exceeded at any time during a workday

### 3.1.42

#### threshold limit value-time weighted average

##### TLV-TWA

time weighted average concentration for a normal 8-h workday and a 40-h work week, to which nearly all workers may be repeatedly exposed, day after day, without adverse effect

### 3.1.43

#### unsaturated organic compound

carbon-containing compound containing at least one double or triple bond between carbon atoms

### 3.1.44

#### workplace environmental exposure limit

##### WEEL

occupational exposure limit ([3.1.233.1.33](#)) set by the Toxicology Excellence for Risk Assessment (TERA)

### 3.1.45

#### worst-case formulation

##### WCF

composition that results from application of the tolerances to the nominal composition ([3.1.323.1.32](#)) resulting in the most toxic or the most flammable ([3.1.213.1.21](#)) formulation

### 3.1.46

#### worst-case fractionated formulation

##### WCFF

composition produced during fractionation ([3.1.223.1.22](#)) of the worst-case formulation ([3.1.453.1.45](#)) that results in the most toxic or most flammable ([3.1.21](#)) formulation

### 3.1.47

#### zeotrope

blend ([3.1.73.1.7](#)) composed of two or more refrigerants ([3.1.373.1.37](#)) whose equilibrium vapour and liquid phase compositions are not the same at any pressure below the critical pressure

## 4.23.2 Abbreviated terms

ACGIH	American Conference of Governmental Industrial Hygienists
AIT	auto-ignition temperature
ALC	approximate lethal concentration
ATEL	acute-toxicity exposure limit