

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Determination of power losses in high-voltage direct current (HVDC) converter stations with line-commutated converters

Détermination des pertes en puissance dans les postes de conversion en courant continu à haute tension (CCHT) munis de convertisseurs commutés par le réseau

IEC 61803:1999

<https://standards.iteh.ai/standards/iec/958a279-0d47-4e54-bce4-c731f15abb7f/iec-61803-1999>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

■ Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

■ IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

■ Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

■ Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

■ Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

■ Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

■ Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

■ Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Determination of power losses in high-voltage direct current (HVDC) converter stations with line-commutated converters

Détermination des pertes en puissance dans les postes de conversion en courant continu à haute tension (CCHT) munis de convertisseurs commutés par le réseau

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

CONTENTS

FOREWORD.....	4
1 Scope.....	6
2 Normative references	6
3 Definitions and symbols.....	7
3.1 Definitions	7
3.2 Letter symbols.....	8
4 General	8
4.1 Introduction	8
4.2 Ambient conditions	9
4.2.1 Outdoor standard reference temperature	9
4.2.2 Coolant standard reference temperature.....	9
4.2.3 Standard reference air pressure	9
4.3 Operating parameters.....	9
5 Determination of equipment losses	10
5.1 Thyristor valve losses.....	10
5.1.1 Thyristor conduction loss per valve.....	11
5.1.2 Thyristor spreading loss per valve.....	11
5.1.3 Other conduction losses per valve	12
5.1.4 D.C. voltage-dependent loss per valve	12
5.1.5 Damping loss per valve (resistor-dependent term).....	13
5.1.6 Damping loss per valve (change of capacitor energy term)	14
5.1.7 Turn-off losses per valve	14
5.1.8 Reactor loss per valve.....	14
5.1.9 Total valve losses	15
5.1.10 Temperature effects	15
5.1.11 No-load operation loss per valve	15
5.2 Converter transformer losses	16
5.2.1 General	16
5.2.2 No-load operation losses	16
5.2.3 Operating losses	16
5.2.4 Auxiliary power losses	17
5.3 AC filter losses	17
5.3.1 General	17
5.3.2 AC filter capacitor losses	18
5.3.3 AC filter reactor losses	18
5.3.4 AC filter resistor losses.....	19
5.3.5 Total a.c. filter losses	19
5.4 Shunt capacitor bank losses	19
5.5 Shunt reactor losses.....	19
5.6 DC smoothing reactor losses.....	19
5.7 DC filter losses.....	20
5.7.1 General	20
5.7.2 DC filter capacitor losses.....	21
5.7.3 DC filter reactor losses	21

5.7.4	DC filter resistor losses	21
5.7.5	Total d.c. filter losses	21
5.8	Auxiliaries and station service losses	22
5.9	Radio interference/PLC Series filter losses	22
5.10	Other equipment losses	23
Annex A (normative)	Calculation of harmonic currents and voltages	29
Annex B (informative)	Typical station losses	31
Annex C (informative)	Bibliography	32
Figure 1	– Typical high-voltage direct current (HVDC) equipment for one pole (auxiliary equipment is not shown)	24
Figure 2	– Simplified three-phase diagram of an HVDC 12-pulse converter	25
Figure 3	– Simplified equivalent circuit of a typical thyristor valve	25
Figure 4	– Current and voltage waveforms of a valve operating in a 12-pulse converter (commutation overshoots are not shown)	26
Figure 5	– Thyristor on-state characteristic	27
Figure 6	– Conduction current and voltage drop	27
Figure 7	– Distribution of commutating inductance between L1 and L2	28
Figure 8	– Thyristor current during reverse recovery	28

(<https://standards.iteh.ai>)
Document Preview

IEC 61803:1999

<https://standards.iteh.ai/document/standards/iec/958a279-0d47-4e54-bce4-c731f15abb7f/iec-61803-1999>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

DETERMINATION OF POWER LOSSES IN HIGH-VOLTAGE DIRECT CURRENT (HVDC) CONVERTER STATIONS WITH LINE- COMMUTATED CONVERTERS

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of IEC 61803 consists of the first edition (1999) [documents 22F/51/FDIS and 22F/56/RVD], its amendment 1 (2010) [documents 22F/214/CDV and 22F/224/RVC] and its corrigendum of October 1999. It bears the edition number 1.1.

The technical content is therefore identical to the base edition and its amendment and has been prepared for user convenience. A vertical line in the margin shows where the base publication has been modified by amendment 1. Additions and deletions are displayed in red, with deletions being struck through.

International Standard IEC 61803 has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronics.

Annex A forms an integral part of this standard.

Annexes B and C are for information only.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

(<https://standards.iteh.ai>)
Document Preview

IEC 61803:1999

<https://standards.iteh.ai/document/standards/iec/958a279-0d47-4e54-bce4-c731f15abb7f/iec-61803-1999>

DETERMINATION OF POWER LOSSES IN HIGH-VOLTAGE DIRECT CURRENT (HVDC) CONVERTER STATIONS WITH LINE- COMMUTATED CONVERTERS

1 Scope

This International Standard applies to all line-commutated high-voltage direct current (HVDC) converter stations used for power exchange in utility systems. This standard presumes the use of 12-pulse thyristor converters but can, with due care, also be used for 6-pulse thyristor converters.

In some applications, synchronous compensators or static var compensators (SVC) may be connected to the a.c. bus of the HVDC converter station. The loss determination procedures for such equipment are not included in this standard.

This standard presents a set of standard procedures for determining the total losses of an HVDC converter station. Typical HVDC equipment is shown in figure 1. The procedures cover all parts, except as noted above, and address no-load operation and operating losses together with their methods of calculation which use, wherever possible, measured parameters.

Converter station designs employing novel components or circuit configurations compared to the typical design assumed in this standard, or designs equipped with unusual auxiliary circuits that could affect the losses, shall be assessed on their own merits.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60076-1:1998, *Power transformers – Part 1: General*

IEC 60076-6, *Power transformers – Part 6: Reactors*

~~IEC 60289:1988, *Reactors*~~

IEC 60633:1998, *Terminology for high-voltage direct current (HVDC) transmission*

IEC 60700-1:1998, *Thyristor valves for high voltage direct current (HVDC) power transmission – Part 1: Electrical testing*

IEC 60747-6:1983, *Semiconductor devices – ~~Discrete devices~~ Part 6: Thyristors*

IEC 60871-1:1997, *Shunt capacitors for a.c. power systems having a rated voltage above 1 000 V – Part 1: General ~~performance, testing and rating~~ – ~~Safety requirements~~ – ~~Guide for installation and operation~~*

3 Definitions and symbols

For the purpose of this International Standard, the following definitions apply:

3.1 Definitions

3.1.1

auxiliary losses

the electric power required to feed the converter station auxiliary loads. The auxiliary losses depend on whether the station is in no-load operation or carrying load, in which case the auxiliary losses depend on the load level

3.1.2

no-load operation losses

the losses produced in an item of equipment with the converter station energized but with the converters blocked and all station service loads and auxiliary equipment connected as required for immediate pick-up of load

3.1.3

load level

this term specifies the direct current, direct voltage, firing angle, a.c. voltage, and converter transformer tap-changer position at which the converter station is operating

3.1.4

operating losses

the losses produced in an item of equipment at a given load level with the converter station energized and the converters operating

3.1.5

rated load

this load is related to operation at nominal values of d.c. current, d.c. voltage, a.c. voltage and converter firing angle. The a.c. system shall be assumed to be at nominal frequency and its 3-phase voltages are nominal and balanced. The position of the tap-changer of the converter transformer and the number of a.c. filters and shunt reactive elements connected shall be consistent with operation at rated load, coincident with nominal conditions

3.1.6

total station losses

the total station loss is the sum of all operating or no-load operation losses and the corresponding auxiliary losses

3.1.7

station essential auxiliary load

load whose failure will affect the conversion capability of the HVDC converter station (e.g. valve cooling), as well as load that must remain working in case of complete loss of a.c. power supply (e.g. battery chargers, operating mechanisms)

NOTE Total "operating losses" minus "no load operation losses" may be considered as being quantitatively equivalent to "load losses" as in conventional a.c. substation practice.

3.2 Letter symbols

α	firing (trigger) delay angle, in radians (rad)
μ	commutation overlap angle, in radians (rad)
f	a.c. system frequency, in hertz (Hz)
I_d	direct current, in the bridge d.c. connection, in amperes (A)
I_n	harmonic r.m.s. current of order n , in amperes (A)
L_1	the inductance, in henrys (H), referred to the valve winding, between the commutating voltage source and the point of common coupling between star- and delta-connected windings. L_1 shall include any external inductance between the transformer line-winding terminals and the point of connection of the a.c. harmonic filters
L_2	the inductance, in henrys (H), referred to the valve winding, between the point of common coupling between star- and delta-connected windings, and the valve. L_2 shall include the saturated inductance of the valve reactors
m	electromagnetic notch coupling factor, $m = L_1/(L_1 + L_2)$
n	harmonic order
N_t	the number of series-connected thyristors per valve
P	power loss in an item of equipment, in watts (W)
Q_n	quality factor at harmonic order n
R	resistance value, in ohms (W) (Ω)
U_d	direct voltage, in volts (V)
U_n	harmonic r.m.s. voltage of order n , in volts (V)
U_{vo}	r.m.s. value of the phase-to-phase no-load voltage on the valve side of the converter transformer excluding harmonics , in volts (V)
X_n	inductive reactance at harmonic order n , in ohms (Ω)

4 General

4.1 Introduction

Suppliers need to know in detail how and where losses are generated, since this affects component and equipment ratings. Purchasers are interested in a verifiable loss figure which allows equitable bid comparison and in a procedure after delivery which can objectively verify the guaranteed performance requirements of the supplier.

As a general principle, it would be desirable to determine the efficiency of an HVDC converter station by a direct measurement of its energy losses. However, attempts to determine the station losses by subtracting the measured output power from the measured input power should recognize that such measurements have an inherent inaccuracy, especially if performed at high voltage. The losses of an HVDC converter station at full load are generally less than 1 % of the transmitted power. Therefore, the loss measured as a small difference between two large quantities is not likely to be a sufficiently accurate indication of the actual losses.

In some special circumstances it may be possible, for example, to arrange a temporary test connection in which two converters are operated from the same a.c. source and also connected together via their d.c. terminals. In this connection, the power drawn from the a.c. source equals the losses in the circuit. However, the a.c. source must also provide var support and commutating voltage to the two converters. Once again, there are practical measurement difficulties.

In order to avoid the problems described above, this standard standardizes a method of calculating the HVDC converter station losses by summing the losses calculated for each item of equipment. The standardized calculation method will help the purchaser to meaningfully compare the competing bids. It will also allow an easy generation of performance curves for the wide range of operating conditions in which the performance has to be known. In the absence of an inexpensive experimental method which could be employed for an objective verification of losses during type tests, the calculation method is the next best alternative as it uses, wherever possible, experimental data obtained from measurements on individual equipment and components under conditions equivalent to those encountered in real operation.

It is important to note that the power loss in each item of equipment will depend on the ambient conditions under which it operates, as well as on the operating conditions or duty cycles to which it is subjected. Therefore, the ambient and operating conditions shall be defined for each item of equipment, based on the ambient and operating conditions of the entire HVDC converter station.

4.2 Ambient conditions

A set of standard reference ambient conditions shall be used for determining the power losses in HVDC converter stations.

4.2.1 Outdoor standard reference temperature

An outdoor ambient dry bulb temperature of 20 °C shall be used as the standard reference temperature for determining the total converter station losses. **Corresponding valve hall temperature may be defined by the supplier if necessary.** The equivalent wet-bulb temperature (where necessary) shall be defined by the purchaser.

NOTE If not defined, the wet-bulb temperature is recommended to be 14 °C which corresponds to approximately 50 % RH at 20 °C dry bulb temperature.

4.2.2 Coolant standard reference temperature

Where forced cooling is used for equipment, the flow rate and temperature of the coolant can influence the temperature rise and associated losses of that equipment. Therefore, the coolant temperatures and flow rates established by the purchaser and the supplier shall be used as a basis for determining the losses.

4.2.3 Standard reference air pressure

The reference air pressure to be used for the evaluation of total converter station power losses shall be the standard atmospheric pressure (101,3 kPa) corrected to the altitude of the installation in question.

4.3 Operating parameters

The losses of an HVDC converter station depend on its operating parameters.

The losses of HVDC converter stations are classified into three categories, termed the no-load operation losses, operating losses and auxiliary losses.

The operating losses and auxiliary losses are affected by the load level of the station because the numbers of certain types of energized equipment (for example harmonic filters and cooling equipment) may depend upon the load level and because losses in individual items of equipment themselves vary with the load level.

HVDC converter station losses shall be determined for nominal (balanced) a.c. system voltage and frequency, symmetrical impedances of the converter transformer and symmetrical firing angles. The transformer tap-changer shall be assumed to be in the position corresponding to nominal a.c. system voltage or as decided by the control system for the defined operating condition.

The operating losses shall be determined for the load levels specified by the purchaser, or at rated load if no such conditions are specified. For each load level, the valve-winding a.c. voltage, d.c. current, converter firing angle, shunt compensation and harmonic filtering equipment shall be consistent with the respective load level and other specified performance requirements, relating, for example, to harmonic distortion and reactive power. Cooling and other auxiliary equipment, as appropriate to the standard reference temperature (see 4.2.1 and 4.2.2), shall be assumed to be connected to support the respective load level.

For the no-load operation mode, converter transformers shall be energized and the converters blocked. All filters and reactive power compensation equipment shall be assumed to be disconnected except for those which are required to sustain operation at zero load in order, for example, to meet the specified reactive power requirements. Station service loads and auxiliary equipment (e.g. cooling-water pumps) shall be assumed to be connected as required for immediate pick-up of load for the converter station.

5 Determination of equipment losses

5.1 Thyristor valve losses

The loss production mechanisms applicable when the valves are blocked (no-load operation losses) are different from those applicable in normal operation (operating losses). Operating losses are dealt with in subclauses 5.1.1 to 5.1.10, and no-load operation losses are dealt with in 5.1.11. Auxiliary losses are dealt with in 5.8.

A simplified three-phase diagram of an HVDC 12-pulse converter is shown in figure 2. Individual valves are marked in the order of their conduction sequence.

A simplified equivalent circuit of a typical valve is shown in figure 3. Symbol th combines together the effects of N_t thyristors connected in series in the valve. C_{AC} and R_{AC} are the corresponding combined values of R-C damping circuits used for voltage sharing and overvoltage suppression. R_{DC} represents d.c. grading resistors and other resistive components which incur loss when the valve blocks voltage. It also includes the effects of the thyristor leakage current (see 5.1.4 and 5.1.11). C_s includes both stray capacitances and surge distribution capacitors (if used). L_s represents saturable reactors used to limit the di/dt stresses to safe values and to improve the distribution of fast rising voltages. R_s represents the resistances of the current conducting components of the valve such as the busbars, contact resistances, resistance of the windings of the saturable reactors etc. Power losses in the valve surge arrester (not shown) shall be neglected.

Figure 4 shows, as an example, current and voltage waveforms of valve 1 (according to figure 2) operating in rectifier and inverter modes. In the example shown, the firing instants of the valves of the upper bridge are delayed by 30° with respect to the valves of the lower bridge due to the phase shift between the two secondaries. For each valve, the length of the conduction intervals is $130^\circ (2\pi/3 + \mu)$. During commutations the valve current is assumed, for this standard, to be changing linearly whereas in reality the valve currents follow portions of sine waves. This simplification has negligible effect on the resulting losses, while the trapezoidal waveform significantly simplifies the calculations. The voltage blocked by the valve shows notches caused by commutations between individual valves.

5.1.1 Thyristor conduction loss per valve

This loss component is the product of the conduction current $i(t)$ and the corresponding ideal on-state voltage as shown in figures 5 and 6. Formula P_{V1a} shall be used provided that the d.c. bridge current is well smoothed. In the event that the root sum square value of the d.c. side harmonic currents, determined in accordance with clause A.4 (annex A), exceeds 5 % of the d.c. component, formula P_{V1b} shall be used instead.

$$P_{V1a} = \frac{N_t \times I_d}{3} \left[U_0 + R_0 \times I_d \times \left(\frac{2\pi - \mu}{2\pi} \right) \right]$$

$$P_{V1b} = \frac{N_t \times I_d \times U_0}{3} + \frac{N_t \times R_0}{3} \left(I_d^2 + \sum_{n=12}^{n=48} I_n^2 \right) \left(\frac{2\pi - \mu}{2\pi} \right)$$

where

U_0 is the current-independent component of the on-state voltage of the average thyristor (see note below), in volts;

R_0 is the slope resistance of the on-state characteristic of the average thyristor (see note below), in ohms;

I_n is the calculated r.m.s. value of the n th harmonic current in the bridge d.c. connection according to clause A.4, in amperes.

NOTE U_0 and R_0 (see figure 5) are determined from the fully spread on-state voltage measured at the appropriate current and junction temperature. The average value of U_0 and R_0 is obtained from production records of the thyristors manufactured for the specific project at 100 % and 50 % of nominal d.c. current. The temperature dependence of U_0 and R_0 is established from type tests or routine tests on a statistically significant number of the thyristors employed, and is used, where necessary, to correct U_0 and R_0 to the appropriate service junction temperature. If parallel connection of p thyristors is employed, the appropriate 100 % current is the nominal d.c. bridge current divided by p . The calculated result is then multiplied by p .

5.1.2 Thyristor spreading loss per valve

This loss component is an additional conduction loss of the thyristors arising from the delay in establishing full conduction of the silicon after the thyristor has been turned on. The additional loss is the product of the current and the voltage by which the thyristor voltage exceeds the ideal thyristor on-state voltage drop (see the hatched area in figure 6).

$$P_{V2} = N_t \times f \times \int_0^{t_1} [u_B(t) - u_A(t)] \times i(t) dt$$

where

t_1 is the length of the conduction interval, in seconds, which is given by:

$$t_1 = \frac{\frac{2}{3} \pi + \mu}{2\pi f};$$

$u_B(t)$ is the instantaneous on-state voltage, in volts, of a thyristor whose fully spread on-state voltage is typical for the thyristors used. The instantaneous on-state voltage shall be determined for the appropriate junction temperature measured with a trapezoidal current pulse exhibiting the correct amplitude and commutation overlap periods (see figures 5 and 6);

$u_A(t)$ is the calculated instantaneous on-state voltage of the average thyristor at the same junction temperature for the same current pulse but with the conducting area fully established throughout the conduction, as derived from its on-state characteristic represented by U_0 and R_0 only (see figure 6);

$i(t)$ is the instantaneous current in the thyristor, in amperes.

NOTE Instantaneous on-state voltage data, including the effects of spreading, are usually not available from production records. Measurements of typical thyristor on-state voltage, including spreading, should therefore be

obtained during the valve periodic firing and extinction type test (see IEC 60700-1) or, alternatively, from a separate laboratory test on a statistically significant number of thyristors.

5.1.3 Other conduction losses per valve

These are the conduction losses in the main circuit of the valve due to components other than the thyristors.

$$P_{V3} = \frac{R_s \cdot I_d^2}{3} \left(\frac{2\pi - \mu}{2\pi} \right)$$

where

R_s is the d.c. resistance of the valve terminal-to-terminal circuit excluding the thyristors, in ohms (see figure 3).

The value of R_s is determined by direct measurement on a representative valve section that includes all elements of the main circuit of a valve in the correct proportions, but in which the thyristors have been replaced by copper blocks of the appropriate dimensions and with contacts treated in the same way as for real thyristors. Alternatively, the resistance may be calculated, in which case the calculation methods shall be documented.

5.1.4 D.C. voltage-dependent loss per valve

This loss component is the loss in the shunt resistance R_{DC} of the valve (see figure 3), arising from the voltage which appears between valve terminals during the non-conducting interval (see figure 4). It includes losses due to thyristor off-state and reverse leakage, losses in d.c. grading resistors, other resistive circuits and elements connected in parallel with the thyristors, resistance of the coolant in coolant pipes, resistivity effects of the structure, fibre optics, etc.

$$P_{V4} = \frac{U_{v0}^2}{2\pi R_{DC}} \left\{ \frac{4}{3} \pi + \frac{\sqrt{3}}{4} [\cos(2\alpha) + \cos(2\alpha + 2\mu)] + \frac{6m^2 - 12m - 7}{8} [\sin(2\alpha) - \sin(2\alpha + 2\mu) + 2\mu] \right\}$$

$$P_{V4} = \frac{U_{v0}^2}{2\pi R_{DC}} \left\{ \frac{4}{3} \pi + \frac{\sqrt{3}}{4} [\cos(2\alpha) + \cos(2\alpha + 2\mu)] + \frac{6m^2 - 12m - 7}{8} [\sin(2\alpha) - \sin(2\alpha + 2\mu) + 2\mu] \right\}$$

where

R_{DC} is the effective off-state d.c. resistance of a complete valve determined by measuring the current drawn during the valve terminal-to-terminal d.c. voltage type test (see IEC 60700) in ohms. If a type test is not performed on the thyristor valve, R_{DC} shall be determined by reference to a previous type test (see also note 2 below);

$$m = L_1 / (L_1 + L_2);$$

L_1 is the inductance, in henrys, referred to the valve winding, between the commutating voltage source and the point of common coupling between star- and delta-connected windings. L_1 shall include any external inductance between the transformer line-winding terminals and the point of connection of the a.c. harmonic filters (see figure 7);

L_2 is the inductance, in henrys, referred to the valve winding, between the point of common coupling between star- and delta-connected windings, and the valve. L_2 shall include the saturated inductance of the valve reactors (see figure 7).

The value of L_2 shall be the same for both secondaries ($L_{2d} = L_{2y}$) (see notes 3 and 4 below).

NOTE 1 The equation for P_{V4} is valid for $\mu < \pi/6$ (30°) only.