

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

**Power transformers –  
Part 1: General**

**Transformateurs de puissance –  
Partie 1: Généralités**

WITKO & MN

iTech Standards  
(<https://standards.iteh.ai>)  
Document Preview

[IEC 60076-1:1993](#)

<https://standards.iteh.ai/catalog/standards/iec/aa5d1f0d-bd23-4493-a3e4-5cf3a462bfad/iec-60076-1-1993>



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2000 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

### A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: [www.iec.ch/searchpub/cur\\_fut-f.htm](http://www.iec.ch/searchpub/cur_fut-f.htm)

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: [www.iec.ch/webstore/custserv/custserv\\_entry-f.htm](http://www.iec.ch/webstore/custserv/custserv_entry-f.htm)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

**Power transformers –  
Part 1: General**

**Transformateurs de puissance –  
Partie 1: Généralités**

<https://standards.iteh.ai/standards/iec/aa561f0d-bd23-4493-a3e4-5cf3a462bfad/iec-60076-1-1993>

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE  
CODE PRIX

**CN**

## CONTENTS

	Page
FOREWORD .....	4
Clause	
1 Scope and service conditions.....	5
1.1 Scope .....	5
1.2 Service conditions.....	5
2 Normative references.....	6
3 Definitions.....	7
3.1 General.....	7
3.2 Terminals and neutral point.....	8
3.3 Windings.....	9
3.4 Rating.....	10
3.5 Tappings.....	11
3.6 Losses and no-load current.....	13
3.7 Short-circuit impedance and voltage drop.....	13
3.8 Temperature rise .....	14
3.9 Insulation.....	14
3.10 Connections.....	14
3.11 Kinds of tests.....	15
3.12 Meteorological data with respect to cooling.....	16
4 Rating.....	16
4.1 Rated power .....	16
4.2 Loading cycle.....	17
4.3 Preferred values of rated power.....	17
4.4 Operation at higher than rated voltage and/or at disturbed frequency.....	17
5 Requirements for transformers having a tapped winding .....	17
5.1 General – Notation of tapping range .....	17
5.2 Tapping voltage – tapping current. Standard categories of tapping voltage variation. Maximum voltage tapping .....	18
5.3 Tapping power. Full-power tappings – reduced-power tappings .....	21
5.4 Specification of tappings in enquiry and order.....	22
5.5 Specification of short-circuit impedance.....	22
5.6 Load loss and temperature rise.....	23
6 Connection and phase displacement symbols for three-phase transformers .....	23
7 Rating plates.....	26
7.1 Information to be given in all cases.....	26
7.2 Additional information to be given when applicable .....	26
8 Miscellaneous requirements.....	27
8.1 Dimensioning of neutral connection .....	27
8.2 Oil preservation system .....	27
8.3 Load rejection on generator transformers.....	28
9 Tolerances.....	28

Clause	Page
10 Tests .....	3 0
10.1 General requirements for routine, type and special tests .....	30
10.2 Measurement of winding resistance .....	3 1
10.3 Measurement of voltage ratio and check of phase displacement .....	3 2
10.4 Measurement of short-circuit impedance and load loss .....	3 2
10.5 Measurement of no-load loss and current .....	3 2
10.6 Measurement of the harmonics of the no-load current.....	3 3
10.7 Measurement of zero-sequence impedance(s) on three-phase transformers .....	3 3
10.8 Tests on on-load tap-changers.....	3 4
11 Electromagnetic compatibility (EMC) .....	3 4
Annex A (normative) Information required with enquiry and order.....	3 5
Annex B (informative) Examples of specifications for transformers with tappings.....	3 8
Annex C (informative) Specification of short-circuit impedance by boundaries.....	4 0
Annex D (informative) Three-phase transformer connections.....	4 1
Annex E (normative) Temperature correction of load loss.....	4 4
Annex F (informative) Bibliography.....	4 5
Figure 1a) – Constant flux voltage variation CFVV .....	2 0
Figure 1b) – Variable flux voltage variation VFVV.....	2 0
Figure 1c) – Combined voltage variation CbVV.....	2 1
Figure 2 – Illustration of 'clock number' notation – three examples .....	2 4
Figure C.1 – Example of specification of short-circuit impedance by boundaries.....	4 0
Figure D.1 – Common connections.....	4 1
Figure D.2 – Additional connections .....	4 2
Figure D.3 – Designation of connections of three-phase auto-transformers by connection symbols. Auto-transformer Ya0. ....	4 3
Figure D.4 – Example of three single-phase transformers connected to form a three-phase bank (connection symbol Yd5).....	4 3

# INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

## POWER TRANSFORMERS –

### Part 1: General

#### FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

<https://standards.itec.org/standards/60076-1-1999/>  
This International Standard has been prepared by IEC by technical committee 14: Power transformers. 1993

This consolidated version of IEC 60076-1 consists of the second edition (1993) [documents 14(CO)75 and 14(CO)77], its amendment 1 (1999) [documents 14/344/FDIS and 14/345/RVD] and its corrigendum of June 1997.

The technical content is therefore identical to the base edition and its amendment and has been prepared for user convenience.

It bears the edition number 2.1.

A vertical line in the margin shows where the base publication has been modified by amendment 1.

IEC 60076 consists of the following parts, under the general title: *Power transformers*.

Part 1:1993, General.

Part 2:1993, Temperature rise.

Part 3:1980, Insulation levels and dielectric tests.

Part 5:1976, Ability to withstand short circuit.

Annexes A and E form an integral part of this standard.

Annexes B, C, D and F are for information only.

# POWER TRANSFORMERS –

## Part 1: General

### 1 Scope and service conditions

#### 1.1 Scope

This part of International Standard IEC 60076 applies to three-phase and single-phase power transformers (including auto-transformers) with the exception of certain categories of small and special transformers such as:

- single-phase transformers with rated power less than 1 kVA and three-phase transformers less than 5 kVA;
- instrument transformers;
- transformers for static convertors;
- traction transformers mounted on rolling stock;
- starting transformers;
- testing transformers;
- welding transformers.

When IEC standards do not exist for such categories of transformers, this part of IEC 60076 may still be applicable either as a whole or in part.

For those categories of power transformers and reactors which have their own IEC standards, this part is applicable only to the extent in which it is specifically called up by cross-reference in the other standard.\*

At several places in this part it is specified or recommended that an 'agreement' shall be reached concerning alternative or additional technical solutions or procedures. Such agreement is to be made between the manufacturer and the purchaser. The matters should preferably be raised at an early stage and the agreements included in the contract specification.

#### 1.2 Service conditions

##### 1.2.1 Normal service conditions

This part of IEC 60076 gives detailed requirements for transformers for use under the following conditions:

a) Altitude

A height above sea-level not exceeding 1 000 m (3 300 ft).

b) Temperature of ambient air and cooling medium

A temperature of ambient air not below  $-25\text{ °C}$  and not above  $+40\text{ °C}$ . For water-cooled transformers, a temperature of cooling water at the inlet not exceeding  $+25\text{ °C}$ .

---

\* Such standards exist for dry-type transformers (IEC 60726), for reactors in general (IEC 60289), for traction transformers and reactors (IEC 60310), and are under preparation for static convertor transformers.



Further limitations, with regard to cooling are given for:

- oil-immersed transformers in IEC 60076-2;
- dry-type transformers in IEC 60726.

c) Wave shape of supply voltage

A supply voltage of which the wave shape is approximately sinusoidal.

NOTE This requirement is normally not critical in public supply systems but may have to be considered in installations with considerable convertor loading. In such cases there is a conventional rule that the deformation shall neither exceed 5 % total harmonic content nor 1 % even harmonic content. Also note the importance of current harmonics for load loss and temperature rise.

d) Symmetry of three-phase supply voltage

For three-phase transformers, a set of three-phase supply voltages which are approximately symmetrical.

e) Installation environment

An environment with a pollution rate (see IEC 60137 and IEC 60815) that does not require special consideration regarding the external insulation of transformer bushings or of the transformer itself.

An environment not exposed to seismic disturbance which would otherwise require special consideration in the design. (This is assumed to be the case when the ground acceleration level  $a_g$  is below 2 m/s.)\*

### 1.2.2 Provision for unusual service conditions

Any unusual service conditions which may lead to special consideration in the design of a transformer shall be stated in the enquiry and the order. These may be factors such as high altitude, extreme high or low temperature, tropical humidity, seismic activity, severe contamination, unusual voltage or load current wave shapes and intermittent loading. They may also concern conditions for shipment, storage and installation, such as weight or space limitations (see annex A).

Supplementary rules for rating and testing are given in other publications for:

- Temperature rise and cooling in high ambient temperature or at high altitude: IEC 60076-2 for oil-immersed transformers, and IEC 60726 for dry-type transformers.
- External insulation at high altitude: IEC 60076-3 and IEC 60076-3-1 for oil-immersed transformers, and IEC 60726 for dry-type transformers.

## 2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of IEC 60076. At the time of publication, the editions indicated were valid. All normative documents are subject to revision, and parties to agreements based on this part of IEC 60076 are encouraged to investigate the possibility of applying the most recent edition of the normative documents indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

\* See IEC 60068-3-3.



IEC 60050(421):1990, *International Electrotechnical Vocabulary – Chapter 421: Power transformers and reactors*

IEC 60068-3-3:1991, *Environmental testing – Part 3: Guidance. Seismic test methods for equipments*

IEC 60076-2:1993, *Power transformers – Part 2: Temperature rise*

IEC 60076-3:1980, *Power transformers – Part 3: Insulation levels and dielectric tests*

IEC 60076-3-1:1987, *Power transformers – Part 3: Insulation levels and dielectric tests. External clearances in air*

IEC 60076-5:1976, *Power transformers – Part 5: Ability to withstand short circuit*

IEC 60137:1984, *Bushings for alternating voltages above 1 000 V*

IEC 60354:1991, *Loading guide for oil-immersed power transformers*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60551:1987, *Determination of transformer and reactor sound levels*

IEC 60606:1978, *Application guide for power transformers*

IEC 60726:1982, *Dry-type power transformers*

IEC 60815:1986, *Guide for the selection of insulators in respect of polluted conditions*

IEC 60905:1987, *Loading guide for dry-type power transformers*

ISO 3:1973, *Preferred numbers – Series of preferred numbers*

ISO 9001:1987, *Quality systems – Model for quality assurance in design/development, production, installation and servicing*

### **3 Definitions**

For the purpose of this part of IEC 60076, the following definitions shall apply. Other terms use the meanings ascribed to them in the International Electrotechnical Vocabulary (IEV).

#### **3.1 General**

##### **3.1.1**

##### **power transformer**

a static piece of apparatus with two or more windings which, by electromagnetic induction, transforms a system of alternating voltage and current into another system of voltage and current usually of different values and at the same frequency for the purpose of transmitting electrical power [IEV 421-01-01, modified]

**3.1.2****auto-transformer\***

a transformer in which at least two windings have a common part [IEV 421-01-11]

**3.1.3****booster transformer**

a transformer of which one winding is intended to be connected in series with a circuit in order to alter its voltage and/or shift its phase. The other winding is an energizing winding [IEV 421-01-12, modified]

**3.1.4****oil-immersed type transformer**

a transformer of which the magnetic circuit and windings are immersed in oil [IEV 421-01-14]

NOTE For the purpose of this part any insulating liquid, mineral oil or other product, is regarded as oil.

**3.1.5****dry-type transformer**

a transformer of which the magnetic circuit and windings are not immersed in an insulating liquid [IEV 421-01-16]

**3.1.6****oil preservation system**

the system in an oil-immersed transformer by which the thermal expansion of the oil is accommodated. Contact between the oil and external air may sometimes be diminished or prevented

**3.2 Terminals and neutral point****3.2.1****terminal**

a conducting element intended for connecting a winding to external conductors

**3.2.2****line terminal**

a terminal intended for connection to a line conductor of a network [IEV 421-02-01]

**3.2.3****neutral terminal**

a) For three-phase transformers and three-phase banks of single-phase transformers:

The terminal or terminals connected to the common point (the neutral point) of a star-connected or zigzag connected winding.

b) For single-phase transformers:

The terminal intended for connection to a neutral point of a network [IEV 421-02-02, modified]

**3.2.4****neutral point**

the point of a symmetrical system of voltages which is normally at zero potential

**3.2.5****corresponding terminals**

terminals of different windings of a transformer, marked with the same letter or corresponding symbol [IEV 421-02-03]

\* Where there is a need to express that a transformer is not auto-connected, use is made of terms such as separate winding transformer, or double-wound transformer (see IEV 421-01-13).

### 3.3 Windings

#### 3.3.1 winding

the assembly of turns forming an electrical circuit associated with one of the voltages assigned to the transformer

NOTE For a three-phase transformer, the 'winding' is the combination of the phase windings (see 3.3.3). [IEV 421-03-01, modified]

#### 3.3.2 tapped winding

a winding in which the effective number of turns can be changed in steps

#### 3.3.3 phase winding

the assembly of turns forming one phase of a three-phase winding

NOTE The term 'phase winding' should not be used for identifying the assembly of all coils on a specific leg. [IEV 421-03-02, modified]

#### 3.3.4 high-voltage winding\*

the winding having the highest rated voltage [IEV 421-03-03]

#### 3.3.5 low-voltage winding\*

the winding having the lowest rated voltage [IEV 421-03-04]

NOTE For a booster transformer, the winding having the lower rated voltage may be that having the higher insulation level.

#### 3.3.6 intermediate-voltage winding\*

a winding of a multi-winding transformer having a rated voltage intermediate between the highest and lowest winding rated voltages [IEV 421-03-05]

#### 3.3.7 auxiliary winding

a winding intended only for a small load compared with the rated power of the transformer [IEV 421-03-08]

#### 3.3.8 stabilizing winding

a supplementary delta-connected winding provided in a star-star-connected or star-zigzag-connected transformer to decrease its zero-sequence impedance, see 3.7.3 [IEV 421-03-09, modified]

NOTE A winding is referred to as a stabilizing winding only if it is not intended for three-phase connection to an external circuit.

#### 3.3.9 common winding

the common part of the windings of an auto-transformer [IEV 421-03-10]

\* The winding which receives active power from the supply source in service is referred to as a 'primary winding', and that which delivers active power to a load as a 'secondary winding'. These terms have no significance as to which of the windings has the higher rated voltage and should not be used except in the context of direction of active power flow (see IEV 421-03-06 and 07). A further winding in the transformer, usually with lower value of rated power than the secondary winding, is then often referred to as 'tertiary winding', see also definition 3.3.8.

### 3.3.10

#### **series winding**

the part of the winding of an auto-transformer or the winding of a booster transformer which is intended to be connected in series with a circuit [IEV 421-03-11]

### 3.3.11

#### **energizing winding**

the winding of a booster transformer which is intended to supply power to the series winding [IEV 421-03-12]

## 3.4 Rating

### 3.4.1

#### **rating**

those numerical values assigned to the quantities which define the operation of the transformer in the conditions specified in this part of IEC 60076 and on which the manufacturer's guarantees and the tests are based

### 3.4.2

#### **rated quantities**

quantities (voltage, current, etc.), the numerical values of which define the rating

NOTE 1 For transformers having tapplings, rated quantities are related to the principal tapping (see 3.5.2), unless otherwise specified. Corresponding quantities with analogous meaning, related to other specific tapplings, are called tapping quantities (see 3.5.10).

NOTE 2 Voltages and currents are always expressed by their r.m.s. values, unless otherwise specified.

### 3.4.3

#### **rated voltage of a winding ( $U_r$ )**

the voltage assigned to be applied, or developed at no-load, between the terminals of an untapped winding, or of a tapped winding connected on the principal tapping (see 3.5.2). For a three-phase winding it is the voltage between line terminals [IEV 421-04-01, modified]

NOTE 1 The rated voltages of all windings appear simultaneously at no-load when the voltage applied to one of them has its rated value.

NOTE 2 For single-phase transformers intended to be connected in star to form a three-phase bank, the rated voltage is indicated as phase-to-phase voltage, divided by  $\sqrt{3}$  for example  $U_r = 400\sqrt{3}$  kV.

NOTE 3 For the series winding of a three-phase booster transformer which is designed as an open winding (see 3.10.5) the rated voltage is indicated as if the winding were connected in star, for example  $U_r = 23\sqrt{3}$  kV.

### 3.4.4

#### **rated voltage ratio**

the ratio of the rated voltage of a winding to the rated voltage of another winding associated with a lower or equal rated voltage [IEV 421-04-02]

### 3.4.5

#### **rated frequency ( $f_r$ )**

the frequency at which the transformer is designed to operate [IEV 421-04-03, modified]

### 3.4.6

#### **rated power ( $S_r$ )**

a conventional value of apparent power assigned to a winding which, together with the rated voltage of the winding, determines its rated current

NOTE 1 Both windings of a two-winding transformer have the same rated power which by definition is the rated power of the whole transformer.

NOTE 2 For a multi-winding transformer, half the arithmetic sum of the rated power values of all windings (separate windings, not auto-connected) gives a rough estimate of its physical size as compared with a two-winding transformer.

### 3.4.7

#### rated current ( $I_r$ )

the current flowing through a line terminal of a winding which is derived from rated power  $S_r$  and rated voltage  $U_r$  for the winding [IEV 421-04-05, modified]

NOTE 1 For a three-phase winding the rated current  $I_r$  is given by:

$$I_r = \frac{S_r}{\sqrt{3} \times U_r} \text{ A}$$

NOTE 2 For single-phase transformer windings intended to be connected in delta to form a three-phase bank the rated current is indicated as line current divided by  $\sqrt{3}$ , for example:

$$I_r = \frac{500}{\sqrt{3}} \text{ A}$$

## 3.5 Tappings

### 3.5.1

#### tapping

in a transformer having a tapped winding, a specific connection of that winding, representing a definite effective number of turns in the tapped winding and, consequently, a definite turns ratio between this winding and any other winding with fixed number of turns

NOTE One of the tappings is the principal tapping, and other tappings are described in relation to the principal tapping by their respective tapping factors. See definitions of these terms below.

### 3.5.2

#### principal tapping

the tapping to which the rated quantities are related [IEV 421-05-02]

### 3.5.3

#### tapping factor (corresponding to a given tapping)

The ratio:

$$\frac{U_d}{U_r} \text{ (tapping factor) or } 100 \frac{U_d}{U_r} \text{ (tapping factor expressed as a percentage)}$$

where

$U_r$  is the rated voltage of the winding (see 3.4.3);

$U_d$  is the voltage which would be developed at no-load at the terminals of the winding, at the tapping concerned, by applying rated voltage to an untapped winding.

NOTE This definition is not appropriate in relation to a series winding of a booster transformer (see 3.1.3), and in that case the percentage notation would be referred to the voltage of the energizing winding or of the winding of an associated system transformer. [IEV 421-05-03, modified]

### 3.5.4

#### plus tapping

a tapping whose tapping factor is higher than 1 [IEV 421-05-04]

### 3.5.5

#### minus tapping

a tapping whose tapping factor is lower than 1 [IEV 421-05-05]

### 3.5.6

#### **tapping step**

the difference between the tapping factors, expressed as a percentage, of two adjacent tappings [IEV 421-05-06]

### 3.5.7

#### **tapping range**

the variation range of the tapping factor, expressed as a percentage, compared with the value '100'

NOTE If this factor ranges from  $100 + a$  to  $100 - b$ , the tapping range is said to be:  $+a$  %,  $-b$  % or  $\pm a$  %, if  $a = b$ . [IEV 421-05-07]

### 3.5.8

#### **tapping voltage ratio (of a pair of windings)**

the ratio which is equal to the rated voltage ratio:

- multiplied by the tapping factor of the tapped winding if this is the high-voltage winding;
- divided by the tapping factor of the tapped winding if this is the low-voltage winding. [IEV 421-05-08]

NOTE While the rated voltage ratio is, by definition, at least equal to 1, the tapping voltage ratio can be lower than 1 for certain tappings when the rated voltage ratio is close to 1.

### 3.5.9

#### **tapping duty**

the numerical values assigned to the quantities, analogous to rated quantities, which refer to tappings other than the principal tapping (see clause 5, and IEC 60606) [IEV 421-05-09, modified]

### 3.5.10

#### **tapping quantities**

those quantities the numerical values of which define the tapping duty of a particular tapping (other than the principal tapping)

NOTE Tapping quantities exist for any winding in the transformer, not only for the tapped winding, (see 5.2 and 5.3).

The tapping quantities are:

- tapping voltage (analogous to rated voltage, 3.4.3);
- tapping power (analogous to rated power, 3.4.6);
- tapping current (analogous to rated current, 3.4.7). [IEV 421-05-10, modified]

### 3.5.11

#### **full-power tapping**

a tapping whose tapping power is equal to the rated power [IEV 421-05-14]

### 3.5.12

#### **reduced-power tapping**

a tapping whose tapping power is lower than the rated power [IEV 421-05-15]

### 3.5.13

#### **on-load tap-changer**

a device for changing the tapping connections of a winding, suitable for operation while the transformer is energized or on load [IEV 421-11-01]