

International **Standard**

ISO 24062

Measurement of fluid flow in closed conduits — Clamp-on ultrasonic transit-time meters for liquids and gases iTeh Standards

Mesurage du débit des fluides dans les conduites fermées — Débitmètres non intrusifs à ultrasons à temps de transit pour les liquides et les gaz Document Preview

First edition 2023-12

https://standards.iteh.ai/catalog/standards/iso/8359db50-44af-4aab-94a0-d07f0c8b74f3/iso-24062-2023

iTeh Standards (https://standards.iteh.ai) Document Preview

ISO 24062:2023

https://standards.iteh.ai/catalog/standards/iso/8359db50-44af-4aa5-94a0-d07f0c8b74f3/iso-24062-2023



COPYRIGHT PROTECTED DOCUMENT

© ISO 2023

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office CP 401 • Ch. de Blandonnet 8 CH-1214 Vernier, Geneva Phone: +41 22 749 01 11 Email: copyright@iso.org

Website: www.iso.org
Published in Switzerland

Co	Contents					
For	eword		v			
Intr	oductio	on	vi			
1	Scop	oe	1			
2	-	mative references				
3	Terms and definitions					
3	3.1	Quantities				
	3.2	Meter design				
	3.3	Thermodynamic conditions				
	3.4	Statistics				
	3.5	Calibration				
	3.6	Symbols and subscripts				
4	Drin	ciple of measurement				
4	4.1	General				
	4.2	Generic description				
		4.2.1 Transducers				
		4.2.2 Ultrasonic path configurations				
		4.2.3 Electronic unit functionality				
	4.3	Special considerations				
		4.3.1 Gas	10			
		4.3.2 Extreme temperatures	10			
	4.4	Additional measurements				
		4.4.1 Standard volume flow				
		4.4.2 Heat flow				
		4.4.3 Mass flow	11			
5	Test	and calibration	11			
	5.1	General Bocument Freview	11			
	5.2	Individual testing — Flow calibration under flowing conditions	11			
		5.2.1 General				
		5.2.2 Laboratory flow calibration 24002.2023	12			
6	Inst	allation	13			
	6.1	General				
	6.2	Installation location	13			
		6.2.1 Upstream and downstream straight pipe length requirements and path				
		configuration				
	6.3	Transmitter programming				
	6.4	Pressure and temperature inputs				
	6.5	Transducer installation				
		6.5.1 Transducer type				
		6.5.2 Transducer orientation				
		6.5.3 Coupling				
	6.6	Gas considerations				
	6.7	Cable				
	6.8	Additional installation effects				
	0.0	6.8.1 Non-steady flow				
		6.8.2 Contamination by secondary phase				
		6.8.3 Vibration				
		6.8.4 Thermal insulation				
		6.8.5 Stratification				
		6.8.6 Wall roughness signal considerations	19			
		6.8.7 Non-Newtonian fluids				
	6.9	Operational diagnostics				
		6.0.1 Fluid speed of sound	10			

		6.9.2	Gain	20
		6.9.3	Signal to noise ratio	20
7	Maiı	ntenanc	:e	20
8	Unce	ertainty	in measurement	20
	8.1	Gene	ral	20
	8.2	Math	ematical model	21
	8.3	Evalu	nation of the contributory variances	22
		8.3.1	Uncertainty of the cross-sectional area, $u(A)$. Uncertainty in the velocity profile, $u(K_p)$. Uncertainty of the path-geometry factor, $u(K_g)$ and time measurement. Uncertainty of time measurement.	22
		8.3.2	Uncertainty in the velocity profile, $u(K_n)$	23
		8.3.3	Uncertainty of the path-geometry factor, $u(K_{\sigma})$ and time measurement	24
		8.3.4	Uncertainty of time measurement	24
		8.3.5	Uncertainty of the delay time, $u(t_0)$ Effect of multiple paths	24
		8.3.6	Effect of multiple paths	24
	8.4 Ad		tional effects on measurement uncertainty	25
		8.4.1	Effect of pipe material on sound speed	25
		8.4.2	Effect of fluid sound speed	25
		8.4.3	Reproducibility of transmitter mounting	25
		8.4.4	External influences	25
Ann	ex A (ir	ıformati	ive) Example of uncertainty calculation	26
Rihl	iogran	hv		33

iTeh Standards (https://standards.iteh.ai) Document Preview

ISO 24062:2023

https://standards.iteh.ai/catalog/standards/iso/8359db50-44af-4aa5-94a0-d07f0c8b74f3/iso-24062-2023

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 30, *Measurement of fluid flow in closed conduits*, Subcommittee SC 5, *Velocity and mass methods*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

ISO 24062:2023

https://standards.iteh.ai/catalog/standards/iso/8359db50-44at-4aa5-94a0-d0//t0c8b//4t3/iso-24062-2023

Introduction

Non-intrusive (clamp-on) ultrasonic meters (USMs) have become one of the accepted flow measurement technologies for a wide range of applications, including process and control measurements. Non-intrusiveness also brings characteristics relevant for economics, safety, and environment. Ultrasonic technology has inherent features such as no pressure loss and wide rangeability. USMs can deliver diagnostic information through which it may be possible to demonstrate that an ultrasonic flowmeter is performing in accordance with specification.

This document provides a description of the non-intrusive (clamp-on) meter, typical application areas, the measures which should be used in assessing the likely performance in terms of error, repeatability and reproducibility when used under ideal and non-ideal operational conditions.

iTeh Standards (https://standards.iteh.ai) Document Preview

ISO 24062:2023

https://standards.iteh.ai/catalog/standards/iso/8359db50-44af-4aa5-94a0-d07f0c8b74f3/iso-24062-2023

Measurement of fluid flow in closed conduits — Clamp-on ultrasonic transit-time meters for liquids and gases

1 Scope

This document specifies requirements and recommendations for non-intrusive (clamp-on) ultrasonic flowmeters (USMs), which use the transit time of ultrasonic signals to measure the volumetric flowrate in closed conduits. Transit time flowmeters are predominantly used on single-phase fluids (liquid and gases) but can also be used where small quantities of additional phases are present.

This document specifies performance, calibration, and output characteristics, and deals with installation conditions.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 4006, Measurement of fluid flow in closed conduits — Vocabulary and symbols

3 Terms and definitions tps://standards.iteh.ai)

For the purposes of this document, the terms and definitions given in ISO 4006 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at https://www.iso.org/obp
- IEC Electropedia: available at https://www.electropedia.org/

3.1 Quantities

3.1.1

volume flowrate

 q_{V}

$$q_V = \frac{\mathrm{d}V}{\mathrm{d}t}$$

where

V is volume:

t is time

[SOURCE: ISO 80000-4:2006, 4-31^[2]]

3.1.2

mean flow velocity

 v_p volume flowrate (3.1.1) divided by the cross-sectional area of the pipe

3.1.3

path velocity

 V_I

average fluid velocity on an ultrasonic path

3.1.4

Reynolds number

 Re_D

dimensionless parameter expressing the ratio between the inertia and viscous forces in the fluid

$$Re_D = \frac{\rho v_A D}{\mu} = \frac{v_A D}{v_{\rm kv}}$$

where

 ρ is density;

 v_A is the mean flow velocity;

D is the pipe internal diameter;

 μ is the dynamic viscosity;

 $v_{\rm ky}$ is the kinematic viscosity

3.2 Meter design

3.2.1

ultrasonic path

path travelled by an ultrasonic signal between a pair of ultrasonic transducers

3.2.2

electronic unit

part of the meter that controls the transducers, processes the signals into a flowrate and provides outputs (see 4.2.3)

ISO 24062:2023

https://standards.iteh.ai/catalog/standards/iso/8359db50-44af-4aa5-94a0-d07f0c8b74f3/iso-24062-2023

3.3 Thermodynamic conditions

3.3.1

metering conditions

conditions, at the point of measurement, of the fluid of which the volume flow is to be measured

Note 1 to entry: Also known as operating conditions or actual conditions.

3.3.2

standard conditions

defined temperature and pressure conditions used in the measurement of fluid quantity so that the standard volume is the volume that would be occupied by a quantity of fluid if it were at standard temperature and pressure

Note 1 to entry: Standard conditions may be defined by regulation or contract.

Note 2 to entry: Not preferred alternatives: reference conditions, base conditions, normal conditions, etc (see ISO 91[3]).

Note 3 to entry: Metering and standard conditions relate only to the volume of the fluid to be measured or indicated and should not be confused with rated operating conditions or reference conditions (see ISO/IEC Guide 99:2007, 4.9 and 4.11^{4}), which refer to influence quantities (see ISO/IEC Guide 99:2007, 2.52 4).

3.4 Statistics

3.4.1

error

measured quantity value minus a reference quantity value

[SOURCE: ISO/IEC Guide 99:2007, 2.16^[4]]

3.4.2

repeatability (of results of measurements)

closeness of the agreement between the results of successive measurements of the same measurand carried out under the same conditions of measurement

Note 1 to entry: These conditions are called repeatability conditions.

Note 2 to entry: Repeatability conditions include:

- the same measurement procedure;
- the same observer:
- the same measuring instrument, used under the same conditions;
- the same location;
- repetition over a short period of time.

Note 3 to entry: Repeatability may be expressed quantitatively in terms of the dispersion characteristics of the results.

[SOURCE: ISO/IEC Guide 98-3:2008, B.2.15[5]]

3.4.3

reproducibility (of results of measurements)

closeness of the agreement between the results of measurements of the same measurand carried out under changed conditions of measurement

Note 1 to entry: A valid statement of reproducibility requires specification of the conditions changed.

Note 2 to entry: The changed conditions may include: 59db50-44af-4aa5-94a0-d07f0c8b74f3/iso-24062-2023

- principle of measurement;
- method of measurement:
- observer;
- measuring instrument;
- reference standard;
- location;
- conditions of use;
- time

Note 3 to entry: Reproducibility may be expressed quantitatively in terms of the dispersion characteristics of the results.

Note 4 to entry: Results are here usually understood to be corrected results.

[SOURCE: ISO/IEC Guide 98-3:2008, B.2.16^[5]]

3.4.4

resolution

smallest difference between indications of a meter that can be meaningfully distinguished

3.4.5

zero flow

meter reading when the fluid is at rest, i.e. both axial and non-axial velocity components are essentially zero

3.4.6

uncertainty (of measurement)

parameter, associated with the result of measurement, that characterizes the dispersion of the values that could reasonably be attributed to the measurand

Note 1 to entry: The parameter may be, for example, a standard deviation (or a given multiple of it), or the half-width of an interval having a stated level of confidence.

Note 2 to entry: Uncertainty of measurement comprises, in general, many components. Some of these components may be evaluated from the statistical distribution of the results of a series of measurements and can be characterized by experimental standard deviations. The other components, which can also be characterized by standard deviations, are evaluated from assumed probability distributions based on experience or other information.

Note 3 to entry: It is understood that the result of the measurement is the best estimate of the value of the measurand, and that all components of uncertainty, including those arising from systematic effects, such as components associated with corrections and reference standards, contribute to the dispersion.

[SOURCE: ISO/IEC Guide 98-3:2008, B.2.18^[5]]

3.4.7

standard uncertainty

11

uncertainty of the result of a measurement expressed as a standard deviation

[SOURCE: ISO/IEC Guide 98-3:2008, 2.3.1^[5]]

3.4.8

expanded uncertainty

U

quantity defining an interval about the result of a measurement that may be expected to encompass a large fraction of the distribution of values that could reasonably be attributed to the measurand

[SOURCE: ISO/IEC Guide 98-3:2008, 2.3.5^[5]] ISO

Note 1 to entry: The large fraction is normally 95 % and is generally associated with a coverage factor k = 1,96.

Note 2 to entry: The expanded uncertainty is often referred to as the uncertainty.

3.4.9

coverage factor

numerical factor used as a multiplier of the standard uncertainty in order to obtain an *expanded uncertainty* (3.4.8)

[SOURCE: ISO/IEC Guide 98-3:2008, 2.3.6^[5]]

3.5 Calibration

3.5.1

flow calibration

calibration of a meter against a reference using fluid flowing through the meter

3.6 Symbols and subscripts

The symbols and subscripts used in this document are given in Table 1 and Table 2.

Table 1 — Symbols

Quantity	Symbol	Dimensiona	SI unit
Cross-sectional area of pipe	A	L^2	m ²
Speed of sound in fluid	С	LT ⁻¹	m/s
Internal pipe diameter	$D_{\rm i}$	L	m
External pipe diameter	D_{e}	L	m
Integers (1.2.3. ,,,)	i,j,n	_	1
Calibration factor	K	_	1
Path-geometry factor	K_{g}	L ^b or LT ^{-1 c}	m ^b or m/s ^c
Velocity profile correction factor	K _p	_	1
Minimum distance to a specified upstream flow disturbance	l_{\min}	L	m
Path length	$l_{\rm p}$	L	m
Absolute pressure	р	ML ⁻¹ T ⁻²	Pa
Volume flowrate	q_V	L ³ T ⁻¹	m ³ /s
Pipe Reynolds number	Re_D	_	1
Transit time	$t_{ m tr}$	Т	S
Delay time	t_0	Т	S
Compressibility	Z	M ⁻¹ LT ⁻	Pa ⁻¹
Pipe wall thickness	δ	L	m
Dynamic viscosity	μ	ML-1T-1	Pa s
Kinematic viscosity I len Standa	$ u_{\rm kv} $	L ² T ⁻¹	m²/s
Density of the fluid	ρ	ML ⁻³	kg/m ³
Angle between ultrasonic path and pipe axis / \$12010000000000000000000000000000000000	0.11ϕ 1.2	l) –	rad

 $M \equiv mass; L \equiv length; T \equiv time; \Theta \equiv temperature.$ Document Preview

https://standards.iteh.ai/catalog/standards/**Table 2**) --- **Subscripts** 5-94a0-d07f0c8b74f3/iso-24062-2023

Subscript	Meaning
cal	under calibration conditions
meas	measured (uncorrected)
op	under operational conditions
true	actual (corrected)

Principle of measurement

4.1 General

This subclause is a generic description of USMs for liquids and gases. It recognizes the scope for variation within commercial designs and the potential for new developments. For the purpose of description, USMs are considered to consist of several components, namely:

- transducers and mounting arrangement
- b) electronic data processing and presentation unit.

Non-refracting configuration.

Refracting configuration.

4.2 Generic description

Ultrasonic transit time clamp-on flowmeters measure non-intrusively. Figure 1 outlines the basic system setup to demonstrate the principle. A pair of transducers is located on the outside of the pipe. The transducers are alternatively working as transmitter and receiver. Ultrasonic pulses are sent through the fluid, in the flow direction, and against it. The transit-time $t_{\rm me_dn}$ of the ultrasonic signal propagating in the flow direction (down-stream) is shorter than the transit-time $t_{\rm me_up}$ of the signal propagating against the flow direction (up-stream). The average flow velocity v_l on the sound path is directly proportional to the measured difference Δt in transit time.

$$v_{l} = \frac{c_{t}}{\cos \phi_{t}} \frac{\Delta t}{\left(t_{\text{me_up}} + t_{\text{me_dn}} - 2t_{0}\right)} \tag{1}$$

The delay time t_0 is the portion of the transit time outside the flowing fluid. The average of the transit times measured upstream and downstream is the transit time $t_{\rm tr}$ at zero flow:

$$t_{\rm tr} = \frac{1}{2} (t_{\rm me_up} + t_{\rm me_dn})$$
 (2)

The angle ϕ_t and the sound speed c_t in the coupling wedge define the propagation angles δ and ϕ in the pipe wall and the fluid according to Snell's law:

$$K_{\rm g} = \frac{c_t}{\cos \phi_t} = \frac{c_\Delta}{\cos \phi_\delta} = \frac{c}{\cos \phi} \tag{3}$$

 $K_{\rm g}$ could be denoted as the path-geometry factor, according to. [6] The ultrasonic signal is shifted in axial direction while propagating through the flowing fluid. $K_{\rm g}$ defines the ratio of the shift to the time difference measured. With Formulae (2) and (3), Formula (1) results in:

$$v_l = K_g \frac{\Delta t}{2(t_{tr} - t_0)}$$
 Document Preview (4)

When multiple paths are installed a weighted sum of the path velocities is calculated.

The mean velocity is obtained by applying a velocity profile factor, K_p , which expresses the relationship between the mean velocity v_A and the measured path velocity v_l :

$$v_A = K_p \cdot v_l \tag{5}$$

The velocity profile factor $K_{\rm p}$ is calculated by the meter based on an empirical model of the flow profile assuming a fully developed turbulent flow profile. The model is parameterized by the Reynolds number and the roughness of the inner pipe wall. The influence of upstream flow disturbances can be corrected based on experimental or validated computational evaluation.

The volume flowrate is given as the product of the mean velocity and the cross-sectional area A of the pipe:

$$q_V = A \cdot V_A \tag{6}$$

With Formulae (4), (5) and (6) the meter formula for the volume flowrate would be:

$$q_V = A \cdot K_p \cdot K_g \frac{\Delta t}{2(t_{tr} - t_0)} \tag{7}$$