



**International
Standard**

ISO 20466

**Guidance for performance grading
of recovered reverse osmosis (RO)
membranes for water reuse**

**First edition
2024-12**

**iTeh Standards
(<https://standards.itih.ai>)
Document Preview**

[ISO 20466:2024](https://standards.itih.ai/catalog/standards/iso/c9d3d7be-220e-492c-9324-6e42c602159f/iso-20466-2024)

<https://standards.itih.ai/catalog/standards/iso/c9d3d7be-220e-492c-9324-6e42c602159f/iso-20466-2024>

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO 20466:2024

<https://standards.iteh.ai/catalog/standards/iso/c9d3d7be-220e-492c-9324-6e42c602159f/iso-20466-2024>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2024

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword.....iv

Introduction.....v

1 Scope.....1

2 Normative references.....1

3 Terms, definitions and abbreviated terms.....1

 3.1 Terms and definitions1

 3.2 Abbreviated terms.....3

4 Concept of grade classification for recovered RO membranes.....3

 4.1 General.....3

 4.2 Purpose of classifying the grade of recovered RO membranes3

 4.3 Applications of recovered RO membranes.....3

 4.4 Recommended information for recovered RO membranes3

 4.5 Displaying of the information4

5 Grade classification.....5

 5.1 Method of performance tests5

 5.2 Classification of membrane type.....5

 5.3 Grade of rejection.....5

 5.4 Grade of flow rate.....6

 5.5 Example of classification.....7

Annex A (informative) Standard test methods and conditions for recovered RO membranes8

Bibliography.....12

Itch Standards
(<https://standards.itech.ai>)
Document Preview

<https://standards.itech.ai/catalog/standards/iso/c9d3d7be-220e-492c-9324-6e42c602159f/iso-20466-2024>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 282, *Water reuse*, Subcommittee SC 3, *Risk and performance evaluation of water reuse systems*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

ISO 20466:2024

<https://standards.iteh.ai/catalog/standards/iso/c9d3d7be-220e-492c-9324-6e42c602159f/iso-20466-2024>

Introduction

Reverse osmosis (RO) membranes are used in various applications such as seawater desalination, ultrapure water production, wastewater treatment, advanced treatment of secondary treated wastewater for reuse, etc. However, the performance of RO membranes gradually declines due to aging and membrane fouling caused by long-term use. At present, used RO membranes are disposed of as consumable materials after several years of use.^[1]

However, used RO membranes, if recovered by an appropriate process such as chemical cleaning, can be reused for various water reclamation and reuse applications, with lower costs than those involved in new membrane production.^{[2][3]} For example, in Japan, disposed RO membranes from Fukuoka seawater desalination plant have been reused for boiler feed water production in the waste water processing centre (sewage plant).

If a used membrane is graded based on its performance, then an appropriate membrane can be selected for each purpose for water reuse. For example, a Grade C1 membrane (lower salt rejection rate and higher flow rate) is suitable for reuse in treating sewage for irrigation usage, while a Grade A1 membrane (higher salt rejection and higher flow rate) is preferable for processing treated sewage for boiler feed water usage.

By reducing membrane disposal, the use of recovered RO membranes can contribute to sustainable development goals (SDGs). Membrane life extension will promote the reduction of old membrane disposal (GOAL12), and less production of new membranes will reduce the carbon footprint (GOAL13). Furthermore, reusing and repurposing RO membranes will also result in an inexpensive and safe water supply to more people (GOAL6).

In order to promote the use of recovered RO membranes, users need information on the membranes, including their performance. This will enable new users to apply the membranes to their intended purpose.

(<https://standards.iteh.ai>)
Document Preview

ISO 20466:2024

<https://standards.iteh.ai/catalog/standards/iso/c9d3d7be-220e-492c-9324-6e42c602159f/iso-20466-2024>

Guidance for performance grading of recovered reverse osmosis (RO) membranes for water reuse

1 Scope

This document provides guidance and requirements for grade classification of performance of recovered reverse osmosis (RO) membranes for water reuse systems.

This standard is applicable to the spiral-wound type of recovered membranes from seawater reverse osmosis (SWRO) and brackish water reverse osmosis (BWRO) systems.

This standard is to ensure consistency in the performance of recovered RO membranes. It does not specify any method or process for the recovery of RO membranes.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 20670:2023, *Water reuse — Vocabulary*

3 Terms, definitions and abbreviated terms

For the purposes of this document, the terms and definitions given in ISO 20670 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 Terms and definitions

3.1.1

differential pressure

delta-P

hydraulic pressure drop across the element feed channel that is a differential pressure from the feed water inlet to the concentrate outlet

[SOURCE: AWWA M53]

3.1.2

element

component containing the membrane, generally replaceable, such as a spiral wound cartridge

[SOURCE: ASTM D6161]

3.1.3

flux

membrane throughput

Note 1 to entry: Flux is usually expressed in volume of *permeate* (3.1.6) per unit membrane surface area, for example litre per square metre per hour ($\text{l/m}^2\cdot\text{h}$) at a given temperature or normalized temperature (more than 20 °C).

Note 2 to entry: Flux can also be expressed in number of moles, or volume or mass of specified component per unit time per unit membrane surface area.

[SOURCE: ISO 20468-5:2021, 3.1.8, modified — part of the original definition was moved to Note 1 to entry.]

3.1.4

flow rate

mass or volume of fluid passing through the primary device per unit time

[SOURCE: ISO 5167-1:2022, 3.3.1, modified — the admitted term “rate of flow” was removed.]

3.1.5

new membrane manufacturer

company organizations or firms that produce new *reverse osmosis (RO)* (3.1.10) membranes

3.1.6

permeate

portion of the feed stream that passes through a membrane

[SOURCE: ISO 20468-5:2021, 3.1.16]

3.1.7

recovered membrane supplier

company or organization that supplies or sells recovered *reverse osmosis (RO)* (3.1.10) membranes and takes responsibility for quality and performance characteristics of the recovered membranes

3.1.8

recovered RO membrane

used *reverse osmosis (RO)* (3.1.10) membrane that can be reused after *recovery* (3.1.9) process

3.1.9

recovery process

recovery

process to restore performance of a used *reverse osmosis (RO)* (3.1.10) membrane to a certain applicable level by washing, chemical cleaning, reforming, surface coating, etc.

3.1.10

reverse osmosis RO

separation process in which one component of a solution is removed from another component by flowing the feed stream under pressure across a semipermeable membrane that causes selective movement of solvent against its osmotic pressure difference

Note 1 to entry: Reverse osmosis (RO) removes ions based on electrochemical forces, colloids, and organics down to a molecular weight of 150, practically reported in units of Daltons. It can also be called hyperfiltration.

[SOURCE: ISO 20468-5:2021, 3.1.19]

3.1.11

used RO membrane

reverse osmosis (RO) (3.1.10) membrane that has been used for a certain period of time and is in need of replacement

3.1.12

water reuse

use of treated wastewater for beneficial use

Note 1 to entry: Synonymous with water reclamation.

[SOURCE: ISO 20670:2023, 3.109, modified — Note 1 to entry was added.]

3.2 Abbreviated terms

SWRO	seawater reverse osmosis
BWRO	brackish water reverse osmosis
RO	reverse osmosis

4 Concept of grade classification for recovered RO membranes

4.1 General

During a long-term operation period, RO membranes are regularly and repeatedly cleaned with chemicals. When the membranes reach their end-of-life due to deterioration of performance, they are typically disposed as waste.

A used RO membrane that is treated by an appropriate recovery process is regarded as a recovered RO membrane. A recovered RO membrane that conforms to the requirements of this document is a marketable product.

Even if the membrane is reused several times, it may be referred to as a recovered RO membrane as long as it is subjected to an appropriate recovery step.

This document does not require any guarantee or warranty of performance of the recovered RO membrane. Depending on the requirements of users, a guarantee or warranty, or both, can be specified as the responsibility of the supplier.

4.2 Purpose of classifying the grade of recovered RO membranes

Classifying the grade of a recovered RO membrane based on its performance characteristics, as well as verifying that a comprehensive performance test has been performed, can help users choose an appropriate membrane for their applications.

Successful system design and construction or installation of a recovered RO membrane process for water reuse can be achieved by the appropriate grading of the membrane.

Engineers should design the recovered RO membrane process after verifying membrane specifications such as rejection and flow rate.

Clarifying these performance parameters and their expected ranges is a mandatory requirement for the appropriate design of a system, including the feed pump head, piping size and system capacity.

In addition, the design philosophy which is specified in ISO 20468-5 can also be applied to systems with recovered RO membranes.

4.3 Applications of recovered RO membranes

A recovered RO membrane may be applied for water reuse applications, but should not be applied for potable use as per ISO 20469.

There are various possible applications; these include cascade implementations in which RO membranes that are initially used for seawater desalination are subsequently reused for tertiary treatment of sewage or reused in the same process, or both.

4.4 Recommended information for recovered RO membranes

A unique serial number should be provided to each recovered RO membrane. As a minimum, the grade, serial number and recovered membrane supplier name should be displayed on the surface of the membrane element.

The following information, as a minimum, should be recorded for each recovered RO membrane, and can be referenced via URL based on the serial number.

- a) Serial number.
- b) Grade.
- c) Differential pressure.
- d) History of the membrane's usage.
- e) Recovered membrane supplier information.
- f) Performance test information.

These items are summarized in [Table 1](#).

Table 1 — Required information

Items	Contents
Serial no.	A unique serial number is assigned to each recovered RO membrane.
Grade	A grade is provided as a matrix of rejection and flow rate during a performance test, which is the responsibility of the supplier. In addition, an SWRO membrane is classified as "S-", a BWRO membrane is classified as "B-".
History of the membrane's usage	History of the RO membrane is essential information for users to grasp its deterioration level. The history shows the track of usage information [raw water type, application, years of operation, membrane area (m ²)] of the RO membrane.
Recovered membrane supplier information	This includes supplier name, address, contact information, etc.
Performance test information	This describes the performance test's method and conditions (e.g. NaCl concentration, temperature, pH, feed pressure, etc.) and the test result (flow rate, rejection, differential pressure). Refer to Annex A .

If any one of these is missing, the membrane cannot be regarded as conforming to the requirements of this document.

The following is an example of required information recorded for an RO membrane:

- a) Serial no.: 1234-567A
- b) Grade: S-A1
- c) Differential pressure: 5 KPa
- d) History: Three years of operation with groundwater treatment at semiconductor factories
- e) Recovered membrane supplier:
 - Name: XYZ company
 - Address: 1-2-3 A Street B-city, C-state, D-country
 - Contact: Tel xxxxxx, URL xxxxxx
- f) Performance test method: See [Annex A](#)

4.5 Displaying of the information

In order to distinguish recovered RO membranes from brand new ones and show their grade, all recovered RO membranes should be marked in a permanent manner with a serial number on the lateral surface of the